

Water

Greater Vancouver Water District 2015 Quality Control Annual Report

Volume 2



Foreword

This report has been produced to meet the requirement for water suppliers to produce an annual report on water quality as per the BC Drinking Water Protection Regulation and as described in the Water Quality Monitoring and Reporting Plan. Volume I of the annual report uses data summaries and graphics to highlight the water quality issues and Volume II provides Chemical and Physical Monitoring results (the actual data). Both Volume I and Volume II will be available on the Metro Vancouver website.

This report discusses numerous water quality parameters with potential health effects. For detailed information on drinking water health effects, the following web sites are suggested:

Health Canada:

<http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index-eng.php>

US EPA:

<http://www.epa.gov/safewater/mcl.html>

World Health Organization:

http://www.who.int/water_sanitation_health/publications/2011/dwg_guidelines/en/index.html

2015

<u>Parameter</u>			<u>Reason Guideline Established</u>
	<u>Canadian Guideline Limits - MAC</u>	<u>Aesthetic Objective (AO)</u>	
Alkalinity as CaCO ₃ (mg/L)	None		
Aluminium Dissolved (µg/L)	None		
Aluminium Total (µg/L)	None		
Antimony Total (µg/L)	6		Health
Arsenic Total (µg/L)	10		Health
Atrazine (µg/L)	5		
Azinphos-Methyl (µg/L)	20		
Barium Total (µg/L)	1000		Health
Benzene (µg/L)	5		Health
Benzo(a)pyrene (µg/L)	0.01		Health
Boron Total (mg/L)	5		Health
Bromate (mg/L)	0.01		Health
Bromide (mg/L)	None		
Bromodichloromethane (µg/L)	None		
Bromoform (µg/L)	None		
Bromoxynil (µg/L)	5		Health
Cadmium Total (µg/L)	5		Health
Calcium Total (µg/L)	None		
Carbaryl (µg/L)	90		Health
Carbofuran (µg/L)	90		Health
Carbon Organic Dissolved (mg/L)	None		
Carbon Organic Total (mg/L)	None		
Carbon Tetrachloride (µg/L)	2		Health
Chlorate (mg/L)	1.0		Health
Chloride Total (mg/L)	None	≤ 250	Aesthetic
Chlorine (mg/L)	None		
Chlorpyrifos (µg/L)	90		Health
Chromium Total (µg/L)	50		Health
Color Apparent (ACU)	None		
Color True (TCU)	None	≤ 15	Aesthetic
Conductivity (umhos/cm)	None		
Copper Total (µg/L)	None	≤ 1000	Aesthetic
Cyanide Total (mg/L)	0.2		Health
Diazinon (µg/L)	20		Health
Dicamba (µg/L)	120		Health
Dichlofop-Methyl (µg/L)	9		Health
Dichlorobenzene, 1,2- (µg/L)	200	≤ 3	Health
Dichlorobenzene, 1,4- (µg/L)	5	≤ 1	Health
Dichloroethane, 1,2- (µg/L)	5		Health
Dichloroethylene, 1,1- (µg/L)	14		Health
Dichloromethane (µg/L)	50		Health

<u>Parameter</u>	<u>Canadian Guideline Limits - MAC</u>	<u>Aesthetic Objective (AO)</u>	<u>Reason Guideline Established</u>
Dichlorophenol, 2,4- (µg/L)	900	≤ 0.3	Health
Dichlorophenoxyacetic acid, 2,4-(2,4-D)	100		Health
Dimethoate (µg/L)	20		Health
Diquat (µg/L)	70		Health
Diuron (µg/L)	150		Health
Ethylbenzene (µg/L)	140	≤ 1.6	Health
Fluoride (mg/L)	1.5		Health
Glyphosate (µg/L)	280		Health
Haloacetic acids Total HAA (µg/L)	80		Health
Hardness as CaCO ₃ (mg/L)	None		
Iron Dissolved (µg/L)	None		
Iron Total (µg/L)	None	≤ 300	Aesthetic
Lead Total (µg/L)	10		Health
Magnesium Total (µg/L)	None		
Malathion (µg/L)	190		Health
Manganese Dissolved (µg/L)	None		
Manganese Total (µg/L)	None	≤ 50	Aesthetic
Mercury Total (µg/L)	1		Health
2-Methyl-4-chlorophenoxyacetic acid (MCPA) (µg/L)	100		Health
Methyl tertiary-butyl ether (MTBE) (µg/L)	None	≤ 15	
Metolachlor (µg/L)	50		Health
Metribuzin (µg/L)	80		Health
Molybdenum Total (µg/L)	None		
Monochlorobenzene (µg/L)	80	≤ 30	Health
Nickel Total (µg/L)	None		
Nitrilotriacetic acid (NTA) (µg/L)	400		Health
Nitrogen - Ammonia as N (mg/L)	None		
Nitrogen - Nitrate as N (mg/L)	45		Health
Nitrogen - Nitrite as N (mg/L)	3		Health
Paraquat (µg/L)	7		Health
Pentachlorophenol (µg/L)	60	≤ 30	Health
pH (pH units)	6.5 to 8.5		Aesthetic
Phenols (mg/L)	None		
Phorate (µg/L)	2		Health
Phosphorus Total (mg/L)	None		
Picloram (µg/L)	190		Health
Potassium Total (µg/L)	None		
Residue Total (mg/L)	None		
Residue Total Dissolved (mg/L)	None	≤ 500	Aesthetic

<u>Parameter</u>	<u>Canadian Guideline Limits - MAC</u>	<u>Aesthetic Objective (AO)</u>	<u>Reason Guideline Established</u>
Residue Total Fixed (mg/L)	None		
Residue Total Volatile (mg/L)	None		
Selenium Total (µg/L)	50		Health
Silica as SiO ₂ (mg/L)	None		
Silver Total (µg/L)	None		
Simazine (µg/L)	10		Health
Sodium Total (µg/L)	None	≤ 200,000	Aesthetic
Sulphate (mg/L)	None	≤ 500	Aesthetic
Temperature (°C)	None	≤ 15°C	Aesthetic
Terbufos (µg/L)	1		Health
Tetrachloroethylene (µg/L)	30		Health
Tetrachlorophenol, 2,3,4,6- (µg/L)	100	≤ 1	Health
Trihalomethanes Total THM (µg/L)	100		Health
Toluene (µg/L)	60	≤ 24	Health
Trichloroethylene (µg/L)	5		Health
Trichlorophenol, 2,4,6- (µg/L)	5	≤ 2	Health
Trifluralin (µg/L)	45		Health
Turbidity (NTU) - Filtered	<1		
Turbidity (NTU) - Unfiltered Source	None		
Uranium Total (µg/L)	20		Health
UV254 (Abs/cm)	None		
UV254 App (Abs/cm)			
Vinyl Chloride (µg/L)	2		Health
Xylene Total (µg/L)	90	≤ 20	Health
Zinc Total (µg/L)	None	≤ 5000	Aesthetic

MAC = Maximum Acceptable Concentration

Analysis - Capilano	Units	Date Sampled	Source	Treated
Alkalinity as CaCO3	mg/L	2/2/2015	2.9	
Alkalinity as CaCO3	mg/L	3/2/2015	2.2	
Alkalinity as CaCO3	mg/L	4/7/2015	2.3	
Alkalinity as CaCO3	mg/L	5/4/2015	2.8	7.4
Alkalinity as CaCO3	mg/L	6/1/2015	3.1	7.9
Alkalinity as CaCO3	mg/L	7/6/2015	3.7	10
Alkalinity as CaCO3	mg/L	8/10/2015	4.3	11
Alkalinity as CaCO3	mg/L	9/8/2015	3.2	8.1
Alkalinity as CaCO3	mg/L	10/13/2015	3.6	9.2
Alkalinity as CaCO3	mg/L	11/9/2015	2.6	6.9
Alkalinity as CaCO3	mg/L	12/7/2015	2.4	6.7
Aluminium Dissolved	µg/L	2/2/2015	116	
Aluminium Dissolved	µg/L	4/7/2015	99	
Aluminium Dissolved	µg/L	6/1/2015	75	25
Aluminium Dissolved	µg/L	8/10/2015	36	17
Aluminium Dissolved	µg/L	10/13/2015	71	20
Aluminium Dissolved	µg/L	12/7/2015	102	37
Aluminum Total	µg/L	2/2/2015	331	
Aluminum Total	µg/L	4/7/2015	174	
Aluminum Total	µg/L	4/16/2015		34
Aluminum Total	µg/L	4/22/2015		32
Aluminum Total	µg/L	4/27/2015	142	30
Aluminum Total	µg/L	5/4/2015		29
Aluminum Total	µg/L	5/5/2015	133	30
Aluminum Total	µg/L	5/11/2015		27
Aluminum Total	µg/L	5/19/2015	107	26
Aluminum Total	µg/L	5/25/2015	116	29
Aluminum Total	µg/L	6/1/2015	98	26
Aluminum Total	µg/L	6/8/2015	93	28
Aluminum Total	µg/L	6/15/2015	90	28
Aluminum Total	µg/L	6/22/2015	84	25
Aluminum Total	µg/L	6/29/2015	80	25
Aluminum Total	µg/L	7/6/2015	80	25
Aluminum Total	µg/L	7/13/2015	74	24
Aluminum Total	µg/L	7/20/2015	70	24
Aluminum Total	µg/L	7/27/2015	68	20
Aluminum Total	µg/L	8/4/2015	67	19
Aluminum Total	µg/L	8/10/2015	65	18
Aluminum Total	µg/L	8/17/2015	67	18
Aluminum Total	µg/L	8/24/2015	64	17
Aluminum Total	µg/L	8/31/2015	101	16
Aluminum Total	µg/L	9/8/2015	245	24
Aluminum Total	µg/L	9/14/2015	187	72
Aluminum Total	µg/L	9/21/2015	150	22
Aluminum Total	µg/L	9/28/2015	141	26
Aluminum Total	µg/L	10/5/2015	125	33

Analysis - Capilano	Units	Date Sampled	Source	Treated
Aluminum Total	µg/L	10/13/2015	120	25
Aluminum Total	µg/L	10/19/2015	113	29
Aluminum Total	µg/L	10/20/2015	112	28
Aluminum Total	µg/L	10/26/2015	98	20
Aluminum Total	µg/L	11/2/2015	104	23
Aluminum Total	µg/L	11/9/2015	285	LA
Aluminum Total	µg/L	11/16/2015	260	40
Aluminum Total	µg/L	11/23/2015	224	36
Aluminum Total	µg/L	11/30/2015	181	35
Aluminum Total	µg/L	12/7/2015	219	39
Aluminum Total	µg/L	12/14/2015	210	53
Aluminum Total	µg/L	12/21/2015	186	45
Antimony Total	µg/L	4/16/2015		<0.5
Antimony Total	µg/L	4/22/2015		<0.5
Antimony Total	µg/L	4/27/2015		<0.5
Antimony Total	µg/L	5/4/2015		<0.5
Antimony Total	µg/L	5/5/2015	<0.5	<0.5
Antimony Total	µg/L	5/11/2015		<0.5
Antimony Total	µg/L	5/19/2015		<0.5
Antimony Total	µg/L	6/1/2015	<0.5	<0.5
Antimony Total	µg/L	10/20/2015	<0.5	<0.5
Antimony Total	µg/L	12/7/2015	<0.5	<0.5
Arsenic Total	µg/L	4/16/2015		<0.5
Arsenic Total	µg/L	4/22/2015		<0.5
Arsenic Total	µg/L	4/27/2015		<0.5
Arsenic Total	µg/L	5/4/2015		<0.5
Arsenic Total	µg/L	5/5/2015	<0.5	<0.5
Arsenic Total	µg/L	5/11/2015		<0.5
Arsenic Total	µg/L	5/19/2015		<0.5
Arsenic Total	µg/L	6/1/2015	<0.5	<0.5
Arsenic Total	µg/L	10/20/2015	<0.5	<0.5
Arsenic Total	µg/L	12/7/2015	<0.5	<0.5
Barium Total	µg/L	4/16/2015		2.8
Barium Total	µg/L	4/22/2015		2.8
Barium Total	µg/L	4/27/2015		2.7
Barium Total	µg/L	5/4/2015		2.9
Barium Total	µg/L	5/5/2015	2.6	3
Barium Total	µg/L	5/11/2015		2.8
Barium Total	µg/L	5/19/2015		2.9
Barium Total	µg/L	6/1/2015	2.7	2.9
Barium Total	µg/L	10/20/2015	3.5	3.9
Barium Total	µg/L	12/7/2015	3.2	3.2
Benzene	ppb	4/16/2015		<0.5
Benzene	ppb	4/22/2015		<0.5
Benzene	ppb	4/27/2015		<0.5
Benzene	ppb	5/4/2015		<0.5

Analysis - Capilano	Units	Date Sampled	Source	Treated
Benzene	ppb	5/11/2015		<0.5
Benzene	ppb	5/19/2015		<0.5
Boron Total	µg/L	4/16/2015		<10
Boron Total	µg/L	4/22/2015		<10
Boron Total	µg/L	4/27/2015		<10
Boron Total	µg/L	5/4/2015		<10
Boron Total	µg/L	5/5/2015	<10	<10
Boron Total	µg/L	5/11/2015		<10
Boron Total	µg/L	5/19/2015		<10
Boron Total	µg/L	6/1/2015	<10	<10
Boron Total	µg/L	10/20/2015	<10	<10
Boron Total	µg/L	12/7/2015	<10	<10
Bromate	mg/L	5/20/2015		<0.01
Bromate	mg/L	8/18/2015		<0.01
Bromate	mg/L	11/25/2015		<0.01
Bromide	mg/L	5/20/2015		<0.01
Bromide	mg/L	8/18/2015		<0.01
Bromide	mg/L	11/25/2015		<0.01
Bromodichloromethane	ppb	2/17/2015	<1	
Bromodichloromethane	ppb	5/20/2015	<1	<1
Bromodichloromethane	ppb	8/18/2015	<1	1
Bromodichloromethane	ppb	11/25/2015	<1	<1
Bromoform	ppb	2/17/2015	<1	
Bromoform	ppb	5/20/2015	<1	<1
Bromoform	ppb	8/18/2015	<1	<1
Bromoform	ppb	11/25/2015	<1	<1
BTEX	ppb	4/16/2015		<1
BTEX	ppb	4/22/2015		<1
BTEX	ppb	4/27/2015		<1
BTEX	ppb	5/4/2015		<1
BTEX	ppb	5/11/2015		<1
BTEX	ppb	5/19/2015		<1
Cadmium Total	µg/L	4/16/2015		<0.2
Cadmium Total	µg/L	4/22/2015		<0.2
Cadmium Total	µg/L	4/27/2015		<0.2
Cadmium Total	µg/L	5/4/2015		<0.2
Cadmium Total	µg/L	5/5/2015	<0.2	<0.2
Cadmium Total	µg/L	5/11/2015		<0.2
Cadmium Total	µg/L	5/19/2015		<0.2
Cadmium Total	µg/L	6/1/2015	<0.2	<0.2
Cadmium Total	µg/L	10/20/2015	<0.2	<0.2
Cadmium Total	µg/L	12/7/2015	<0.2	<0.2
Calcium Total	µg/L	2/2/2015	1270	
Calcium Total	µg/L	3/2/2015	1060	
Calcium Total	µg/L	4/7/2015	1060	
Calcium Total	µg/L	4/16/2015		3340

Analysis - Capilano	Units	Date Sampled	Source	Treated
Calcium Total	µg/L	4/22/2015		3320
Calcium Total	µg/L	4/27/2015		3170
Calcium Total	µg/L	5/4/2015	1200	3390
Calcium Total	µg/L	5/5/2015	1210	3610
Calcium Total	µg/L	5/11/2015		3380
Calcium Total	µg/L	5/19/2015		3370
Calcium Total	µg/L	6/1/2015	1260	3460
Calcium Total	µg/L	7/6/2015	1400	4210
Calcium Total	µg/L	8/10/2015	1510	4490
Calcium Total	µg/L	9/8/2015	1540	3970
Calcium Total	µg/L	10/13/2015	1580	4070
Calcium Total	µg/L	10/20/2015	1570	4290
Calcium Total	µg/L	11/9/2015	1360	LA
Calcium Total	µg/L	12/7/2015	1200	3340
Carbon Organic - Dissolved	mg/L	1/19/2015	2.5	
Carbon Organic - Dissolved	mg/L	1/26/2015	2.4	
Carbon Organic - Dissolved	mg/L	2/2/2015	2.2	
Carbon Organic - Dissolved	mg/L	2/10/2015	2.4	
Carbon Organic - Dissolved	mg/L	2/16/2015	2.3	
Carbon Organic - Dissolved	mg/L	2/23/2015	2.1	
Carbon Organic - Dissolved	mg/L	3/2/2015	2	
Carbon Organic - Dissolved	mg/L	3/9/2015	1.9	
Carbon Organic - Dissolved	mg/L	3/16/2015	2	
Carbon Organic - Dissolved	mg/L	3/23/2015	2.1	
Carbon Organic - Dissolved	mg/L	3/30/2015	2.2	
Carbon Organic - Dissolved	mg/L	4/7/2015	2.1	
Carbon Organic - Dissolved	mg/L	4/13/2015	2.1	
Carbon Organic - Dissolved	mg/L	4/20/2015	2	0.6
Carbon Organic - Dissolved	mg/L	4/27/2015	2	0.6
Carbon Organic - Dissolved	mg/L	5/4/2015	1.9	0.6
Carbon Organic - Dissolved	mg/L	5/11/2015	1.9	0.6
Carbon Organic - Dissolved	mg/L	5/19/2015	1.8	0.6
Carbon Organic - Dissolved	mg/L	5/25/2015	1.8	0.6
Carbon Organic - Dissolved	mg/L	6/1/2015	1.8	0.6
Carbon Organic - Dissolved	mg/L	6/8/2015	1.7	0.6
Carbon Organic - Dissolved	mg/L	6/15/2015	1.7	0.6
Carbon Organic - Dissolved	mg/L	6/22/2015	1.7	0.7
Carbon Organic - Dissolved	mg/L	6/29/2015	1.6	0.7
Carbon Organic - Dissolved	mg/L	7/6/2015	1.5	0.7
Carbon Organic - Dissolved	mg/L	7/13/2015	1.5	0.7
Carbon Organic - Dissolved	mg/L	7/20/2015	1.4	0.7
Carbon Organic - Dissolved	mg/L	7/27/2015	1.3	0.7
Carbon Organic - Dissolved	mg/L	8/4/2015	1.4	0.7
Carbon Organic - Dissolved	mg/L	8/10/2015	1.3	0.7
Carbon Organic - Dissolved	mg/L	8/17/2015	1.5	0.7
Carbon Organic - Dissolved	mg/L	8/24/2015	1.3	0.6

Analysis - Capilano	Units	Date Sampled	Source	Treated
Carbon Organic - Dissolved	mg/L	8/31/2015	1.3	0.6
Carbon Organic - Dissolved	mg/L	9/8/2015	2.1	0.9
Carbon Organic - Dissolved	mg/L	9/14/2015	2.1	0.9
Carbon Organic - Dissolved	mg/L	9/21/2015	2.2	0.9
Carbon Organic - Dissolved	mg/L	9/28/2015	2.2	1
Carbon Organic - Dissolved	mg/L	10/5/2015	2.1	0.9
Carbon Organic - Dissolved	mg/L	10/13/2015	2	0.9
Carbon Organic - Dissolved	mg/L	10/19/2015	2.3	0.9
Carbon Organic - Dissolved	mg/L	10/26/2015	2	1
Carbon Organic - Dissolved	mg/L	11/2/2015	2.1	0.9
Carbon Organic - Dissolved	mg/L	11/9/2015	2.6	0.9
Carbon Organic - Dissolved	mg/L	11/16/2015	2.6	0.9
Carbon Organic - Dissolved	mg/L	11/23/2015	2.4	0.8
Carbon Organic - Dissolved	mg/L	11/30/2015	2.3	0.8
Carbon Organic - Dissolved	mg/L	12/7/2015	2.4	0.7
Carbon Organic - Dissolved	mg/L	12/14/2015	2.2	0.7
Carbon Organic - Dissolved	mg/L	12/21/2015	2	0.7
Carbon Organic - Total	mg/L	1/19/2015	2.5	
Carbon Organic - Total	mg/L	1/26/2015	2.5	
Carbon Organic - Total	mg/L	2/2/2015	2.3	
Carbon Organic - Total	mg/L	2/10/2015	2.4	
Carbon Organic - Total	mg/L	2/16/2015	2.54	
Carbon Organic - Total	mg/L	2/17/2015	2.6	
Carbon Organic - Total	mg/L	2/18/2015	2.6	
Carbon Organic - Total	mg/L	2/19/2015	2.7	
Carbon Organic - Total	mg/L	2/20/2015	2.58	
Carbon Organic - Total	mg/L	2/21/2015	2.6	
Carbon Organic - Total	mg/L	2/23/2015	2.1	
Carbon Organic - Total	mg/L	3/2/2015	2.1	
Carbon Organic - Total	mg/L	3/9/2015	2	
Carbon Organic - Total	mg/L	3/16/2015	2.1	
Carbon Organic - Total	mg/L	3/23/2015	2	
Carbon Organic - Total	mg/L	3/30/2015	2.2	
Carbon Organic - Total	mg/L	4/7/2015	2.1	
Carbon Organic - Total	mg/L	4/13/2015	2.1	
Carbon Organic - Total	mg/L	4/20/2015	2	0.6
Carbon Organic - Total	mg/L	4/27/2015	2.1	0.6
Carbon Organic - Total	mg/L	5/4/2015	2	0.6
Carbon Organic - Total	mg/L	5/11/2015	1.9	0.6
Carbon Organic - Total	mg/L	5/19/2015	1.9	0.6
Carbon Organic - Total	mg/L	5/25/2015	1.9	0.6
Carbon Organic - Total	mg/L	6/1/2015	1.8	0.6
Carbon Organic - Total	mg/L	6/8/2015	1.7	0.6
Carbon Organic - Total	mg/L	6/15/2015	1.7	0.7
Carbon Organic - Total	mg/L	6/22/2015	1.7	0.6
Carbon Organic - Total	mg/L	6/29/2015	1.6	0.7

Analysis - Capilano	Units	Date Sampled	Source	Treated
Carbon Organic - Total	mg/L	7/6/2015	1.5	0.7
Carbon Organic - Total	mg/L	7/13/2015	1.4	0.7
Carbon Organic - Total	mg/L	7/20/2015	1.5	0.7
Carbon Organic - Total	mg/L	7/27/2015	1.4	0.7
Carbon Organic - Total	mg/L	8/4/2015	1.3	0.7
Carbon Organic - Total	mg/L	8/10/2015	1.3	0.6
Carbon Organic - Total	mg/L	8/17/2015	1.4	0.6
Carbon Organic - Total	mg/L	8/24/2015	1.3	0.7
Carbon Organic - Total	mg/L	8/31/2015	1.5	0.6
Carbon Organic - Total	mg/L	9/8/2015	2.1	1
Carbon Organic - Total	mg/L	9/14/2015	2	0.9
Carbon Organic - Total	mg/L	9/21/2015	2.2	0.9
Carbon Organic - Total	mg/L	9/28/2015	2.2	0.9
Carbon Organic - Total	mg/L	10/5/2015	2.1	0.9
Carbon Organic - Total	mg/L	10/13/2015	2.1	0.9
Carbon Organic - Total	mg/L	10/19/2015	2.2	0.9
Carbon Organic - Total	mg/L	10/26/2015	2	0.9
Carbon Organic - Total	mg/L	11/2/2015	2.1	0.9
Carbon Organic - Total	mg/L	11/9/2015	2.7	0.9
Carbon Organic - Total	mg/L	11/16/2015	2.6	0.9
Carbon Organic - Total	mg/L	11/23/2015	2.4	0.8
Carbon Organic - Total	mg/L	11/30/2015	2.2	0.8
Carbon Organic - Total	mg/L	12/7/2015	2.5	0.7
Carbon Organic - Total	mg/L	12/14/2015	2.3	0.7
Carbon Organic - Total	mg/L	12/21/2015	2.1	0.7
Chlorate	mg/L	5/20/2015		0.03
Chlorate	mg/L	8/18/2015		0.07
Chlorate	mg/L	11/25/2015		0.02
Chloride	mg/L	2/2/2015	0.5	
Chloride	mg/L	3/2/2015	<0.5	
Chloride	mg/L	4/7/2015	<0.5	
Chloride	mg/L	5/4/2015	<0.5	2.3
Chloride	mg/L	5/20/2015		2.3
Chloride	mg/L	6/1/2015	<0.5	2.3
Chloride	mg/L	7/6/2015	0.5	2.4
Chloride	mg/L	8/10/2015	0.6	2.3
Chloride	mg/L	8/18/2015		2.5
Chloride	mg/L	9/8/2015	0.7	3
Chloride	mg/L	10/13/2015	0.7	2.9
Chloride	mg/L	11/9/2015	0.7	3.1
Chloride	mg/L	11/25/2015		2.9
Chloride	mg/L	12/7/2015	0.5	2.7
Chlorine Free	mg/L	4/16/2015		0.77
Chlorine Free	mg/L	4/17/2015		0.73
Chlorine Free	mg/L	4/18/2015		0.73
Chlorine Free	mg/L	4/19/2015		0.81

Analysis - Capilano	Units	Date Sampled	Source	Treated
Chlorine Free	mg/L	4/20/2015		0.83
Chlorine Free	mg/L	4/21/2015		0.8
Chlorine Free	mg/L	4/22/2015		0.82
Chlorine Free	mg/L	4/23/2015		0.83
Chlorine Free	mg/L	4/24/2015		0.83
Chlorine Free	mg/L	4/25/2015		0.8
Chlorine Free	mg/L	4/26/2015		0.82
Chlorine Free	mg/L	4/27/2015		0.79
Chlorine Free	mg/L	4/28/2015		0.78
Chlorine Free	mg/L	4/29/2015		0.76
Chlorine Free	mg/L	4/30/2015		0.95
Chlorine Free	mg/L	5/1/2015		0.79
Chlorine Free	mg/L	5/2/2015		0.83
Chlorine Free	mg/L	5/3/2015		0.79
Chlorine Free	mg/L	5/4/2015		0.73
Chlorine Free	mg/L	5/5/2015		0.74
Chlorine Free	mg/L	5/6/2015		0.63
Chlorine Free	mg/L	5/7/2015		0.82
Chlorine Free	mg/L	5/8/2015		0.76
Chlorine Free	mg/L	5/9/2015		0.79
Chlorine Free	mg/L	5/10/2015		0.82
Chlorine Free	mg/L	5/11/2015		0.76
Chlorine Free	mg/L	5/12/2015		0.8
Chlorine Free	mg/L	5/13/2015		0.66
Chlorine Free	mg/L	5/14/2015		0.76
Chlorine Free	mg/L	5/15/2015		0.65
Chlorine Free	mg/L	5/16/2015		0.78
Chlorine Free	mg/L	5/17/2015		0.78
Chlorine Free	mg/L	5/18/2015		0.78
Chlorine Free	mg/L	5/19/2015		0.63
Chlorine Free	mg/L	5/20/2015		0.73
Chlorine Free	mg/L	5/21/2015		0.67
Chlorine Free	mg/L	5/22/2015		0.77
Chlorine Free	mg/L	5/23/2015		0.77
Chlorine Free	mg/L	5/24/2015		0.81
Chlorine Free	mg/L	5/25/2015		0.72
Chlorine Free	mg/L	5/26/2015		0.77
Chlorine Free	mg/L	5/27/2015		0.79
Chlorine Free	mg/L	5/28/2015		0.7
Chlorine Free	mg/L	5/29/2015		0.69
Chlorine Free	mg/L	5/30/2015		0.82
Chlorine Free	mg/L	5/31/2015		0.79
Chlorine Free	mg/L	6/1/2015		0.72
Chlorine Free	mg/L	6/2/2015		0.8
Chlorine Free	mg/L	6/3/2015		0.54
Chlorine Free	mg/L	6/4/2015		0.71

Analysis - Capilano	Units	Date Sampled	Source	Treated
Chlorine Free	mg/L	6/5/2015		0.66
Chlorine Free	mg/L	6/6/2015		0.8
Chlorine Free	mg/L	6/7/2015		0.8
Chlorine Free	mg/L	6/8/2015		0.73
Chlorine Free	mg/L	6/9/2015		0.74
Chlorine Free	mg/L	6/10/2015		0.77
Chlorine Free	mg/L	6/11/2015		0.73
Chlorine Free	mg/L	6/12/2015		0.8
Chlorine Free	mg/L	6/13/2015		0.77
Chlorine Free	mg/L	6/14/2015		0.8
Chlorine Free	mg/L	6/15/2015		0.68
Chlorine Free	mg/L	6/16/2015		0.7
Chlorine Free	mg/L	6/17/2015		0.78
Chlorine Free	mg/L	6/18/2015		0.55
Chlorine Free	mg/L	6/19/2015		0.78
Chlorine Free	mg/L	6/20/2015		0.8
Chlorine Free	mg/L	6/21/2015		0.76
Chlorine Free	mg/L	6/22/2015		0.81
Chlorine Free	mg/L	6/23/2015		0.71
Chlorine Free	mg/L	6/24/2015		0.61
Chlorine Free	mg/L	6/25/2015		0.75
Chlorine Free	mg/L	6/26/2015		0.72
Chlorine Free	mg/L	6/27/2015		0.81
Chlorine Free	mg/L	6/28/2015		0.85
Chlorine Free	mg/L	6/29/2015		0.63
Chlorine Free	mg/L	6/30/2015		0.73
Chlorine Free	mg/L	7/1/2015		0.8
Chlorine Free	mg/L	7/2/2015		0.86
Chlorine Free	mg/L	7/3/2015		0.82
Chlorine Free	mg/L	7/4/2015		0.8
Chlorine Free	mg/L	7/5/2015		0.8
Chlorine Free	mg/L	7/6/2015		<0.01
Chlorine Free	mg/L	7/7/2015		0.64
Chlorine Free	mg/L	7/8/2015		0.79
Chlorine Free	mg/L	7/9/2015		0.61
Chlorine Free	mg/L	7/10/2015		0.76
Chlorine Free	mg/L	7/11/2015		0.82
Chlorine Free	mg/L	7/12/2015		0.79
Chlorine Free	mg/L	7/13/2015		0.75
Chlorine Free	mg/L	7/14/2015		0.36
Chlorine Free	mg/L	7/15/2015		0.74
Chlorine Free	mg/L	7/16/2015		0.71
Chlorine Free	mg/L	7/17/2015		0.63
Chlorine Free	mg/L	7/18/2015		0.77
Chlorine Free	mg/L	7/19/2015		0.74
Chlorine Free	mg/L	7/20/2015		0.76

Analysis - Capilano	Units	Date Sampled	Source	Treated
Chlorine Free	mg/L	7/21/2015		0.67
Chlorine Free	mg/L	7/22/2015		0.77
Chlorine Free	mg/L	7/23/2015		0.69
Chlorine Free	mg/L	7/24/2015		0.62
Chlorine Free	mg/L	7/25/2015		0.65
Chlorine Free	mg/L	7/26/2015		0.71
Chlorine Free	mg/L	7/27/2015		0.69
Chlorine Free	mg/L	7/28/2015		0.73
Chlorine Free	mg/L	7/29/2015		0.62
Chlorine Free	mg/L	7/30/2015		0.66
Chlorine Free	mg/L	7/31/2015		0.75
Chlorine Free	mg/L	8/1/2015		0.79
Chlorine Free	mg/L	8/2/2015		0.79
Chlorine Free	mg/L	8/3/2015		0.78
Chlorine Free	mg/L	8/4/2015		0.65
Chlorine Free	mg/L	8/5/2015		0.7
Chlorine Free	mg/L	8/6/2015		0.72
Chlorine Free	mg/L	8/7/2015		0.74
Chlorine Free	mg/L	8/8/2015		0.77
Chlorine Free	mg/L	8/9/2015		0.71
Chlorine Free	mg/L	8/10/2015		0.65
Chlorine Free	mg/L	8/11/2015		0.74
Chlorine Free	mg/L	8/12/2015		0.73
Chlorine Free	mg/L	8/13/2015		0.79
Chlorine Free	mg/L	8/14/2015		0.73
Chlorine Free	mg/L	8/15/2015		0.72
Chlorine Free	mg/L	8/16/2015		0.73
Chlorine Free	mg/L	8/17/2015		0.72
Chlorine Free	mg/L	8/18/2015		0.49
Chlorine Free	mg/L	8/19/2015		0.69
Chlorine Free	mg/L	8/20/2015		0.79
Chlorine Free	mg/L	8/21/2015		0.6
Chlorine Free	mg/L	8/22/2015		0.76
Chlorine Free	mg/L	8/23/2015		0.78
Chlorine Free	mg/L	8/24/2015		0.83
Chlorine Free	mg/L	8/25/2015		0.66
Chlorine Free	mg/L	8/26/2015		0.55
Chlorine Free	mg/L	8/27/2015		0.61
Chlorine Free	mg/L	8/28/2015		0.61
Chlorine Free	mg/L	8/29/2015		0.73
Chlorine Free	mg/L	8/30/2015		0.72
Chlorine Free	mg/L	8/31/2015		0.46
Chlorine Free	mg/L	9/1/2015		0.72
Chlorine Free	mg/L	9/2/2015		0.74
Chlorine Free	mg/L	9/3/2015		0.73
Chlorine Free	mg/L	9/4/2015		0.75

Analysis - Capilano	Units	Date Sampled	Source	Treated
Chlorine Free	mg/L	9/5/2015		0.76
Chlorine Free	mg/L	9/6/2015		0.74
Chlorine Free	mg/L	9/7/2015		0.76
Chlorine Free	mg/L	9/8/2015		0.76
Chlorine Free	mg/L	9/9/2015		0.68
Chlorine Free	mg/L	9/10/2015		0.57
Chlorine Free	mg/L	9/11/2015		0.61
Chlorine Free	mg/L	9/12/2015		0.82
Chlorine Free	mg/L	9/13/2015		0.74
Chlorine Free	mg/L	9/14/2015		0.73
Chlorine Free	mg/L	9/15/2015		0.77
Chlorine Free	mg/L	9/16/2015		0.65
Chlorine Free	mg/L	9/17/2015		0.63
Chlorine Free	mg/L	9/18/2015		0.74
Chlorine Free	mg/L	9/19/2015		0.72
Chlorine Free	mg/L	9/20/2015		0.74
Chlorine Free	mg/L	9/21/2015		0.67
Chlorine Free	mg/L	9/22/2015		0.68
Chlorine Free	mg/L	9/23/2015		0.62
Chlorine Free	mg/L	9/24/2015		0.74
Chlorine Free	mg/L	9/25/2015		0.64
Chlorine Free	mg/L	9/26/2015		0.72
Chlorine Free	mg/L	9/27/2015		0.73
Chlorine Free	mg/L	9/28/2015		0.69
Chlorine Free	mg/L	9/29/2015		0.76
Chlorine Free	mg/L	9/30/2015		0.65
Chlorine Free	mg/L	10/1/2015		0.77
Chlorine Free	mg/L	10/2/2015		0.71
Chlorine Free	mg/L	10/3/2015		0.71
Chlorine Free	mg/L	10/4/2015		0.75
Chlorine Free	mg/L	10/5/2015		0.77
Chlorine Free	mg/L	10/7/2015		0.8
Chlorine Free	mg/L	10/8/2015		0.81
Chlorine Free	mg/L	10/9/2015		0.66
Chlorine Free	mg/L	10/10/2015		0.76
Chlorine Free	mg/L	10/11/2015		0.71
Chlorine Free	mg/L	10/12/2015		0.76
Chlorine Free	mg/L	10/13/2015		0.74
Chlorine Free	mg/L	10/14/2015		0.69
Chlorine Free	mg/L	10/15/2015		0.66
Chlorine Free	mg/L	10/16/2015		0.69
Chlorine Free	mg/L	10/17/2015		0.76
Chlorine Free	mg/L	10/18/2015	0.73	0.73
Chlorine Free	mg/L	10/19/2015		0.61
Chlorine Free	mg/L	10/20/2015		0.72
Chlorine Free	mg/L	10/21/2015		0.75

Analysis - Capilano	Units	Date Sampled	Source	Treated
Chlorine Free	mg/L	10/22/2015		0.7
Chlorine Free	mg/L	10/23/2015		0.69
Chlorine Free	mg/L	10/24/2015		0.72
Chlorine Free	mg/L	10/25/2015		0.74
Chlorine Free	mg/L	10/26/2015		0.72
Chlorine Free	mg/L	10/27/2015		0.71
Chlorine Free	mg/L	10/28/2015		0.6
Chlorine Free	mg/L	10/29/2015		0.72
Chlorine Free	mg/L	10/30/2015		0.69
Chlorine Free	mg/L	10/31/2015		0.72
Chlorine Free	mg/L	11/1/2015		0.77
Chlorine Free	mg/L	11/2/2015		0.69
Chlorine Free	mg/L	11/3/2015		0.51
Chlorine Free	mg/L	11/4/2015		0.67
Chlorine Free	mg/L	11/5/2015		0.77
Chlorine Free	mg/L	11/6/2015		0.7
Chlorine Free	mg/L	11/7/2015		0.75
Chlorine Free	mg/L	11/8/2015		0.79
Chlorine Free	mg/L	11/9/2015		0.58
Chlorine Free	mg/L	11/10/2015		0.68
Chlorine Free	mg/L	11/11/2015		0.76
Chlorine Free	mg/L	11/12/2015		0.58
Chlorine Free	mg/L	11/13/2015		0.8
Chlorine Free	mg/L	11/14/2015		0.78
Chlorine Free	mg/L	11/15/2015		0.76
Chlorine Free	mg/L	11/16/2015		0.68
Chlorine Free	mg/L	11/17/2015		0.73
Chlorine Free	mg/L	11/18/2015		0.53
Chlorine Free	mg/L	11/19/2015		0.67
Chlorine Free	mg/L	11/20/2015		0.66
Chlorine Free	mg/L	11/21/2015		0.79
Chlorine Free	mg/L	11/22/2015		0.77
Chlorine Free	mg/L	11/23/2015		0.7
Chlorine Free	mg/L	11/24/2015		0.54
Chlorine Free	mg/L	11/25/2015		0.61
Chlorine Free	mg/L	11/26/2015		0.79
Chlorine Free	mg/L	11/27/2015		0.7
Chlorine Free	mg/L	11/28/2015		0.83
Chlorine Free	mg/L	11/29/2015		0.78
Chlorine Free	mg/L	11/30/2015		0.69
Chlorine Free	mg/L	12/1/2015		0.72
Chlorine Free	mg/L	12/2/2015		0.72
Chlorine Free	mg/L	12/3/2015		0.72
Chlorine Free	mg/L	12/4/2015		0.73
Chlorine Free	mg/L	12/5/2015		0.8
Chlorine Free	mg/L	12/6/2015		0.79

Analysis - Capilano	Units	Date Sampled	Source	Treated
Chlorine Free	mg/L	12/7/2015		0.71
Chlorine Free	mg/L	12/8/2015		0.79
Chlorine Free	mg/L	12/10/2015		0.71
Chlorine Free	mg/L	12/11/2015		0.67
Chlorine Free	mg/L	12/12/2015		0.79
Chlorine Free	mg/L	12/13/2015		0.77
Chlorine Free	mg/L	12/14/2015		0.76
Chlorine Free	mg/L	12/15/2015		0.7
Chlorine Free	mg/L	12/16/2015		0.58
Chlorine Free	mg/L	12/17/2015		0.75
Chlorine Free	mg/L	12/18/2015		0.58
Chlorine Free	mg/L	12/19/2015		0.78
Chlorine Free	mg/L	12/20/2015		0.82
Chlorine Free	mg/L	12/21/2015		0.67
Chlorine Free	mg/L	12/22/2015		0.76
Chlorine Free	mg/L	12/23/2015		0.56
Chlorine Free	mg/L	12/24/2015		0.73
Chlorine Free	mg/L	12/26/2015		0.7
Chlorine Free	mg/L	12/27/2015		0.72
Chlorine Free	mg/L	12/28/2015		0.77
Chlorine Free	mg/L	12/29/2015		0.78
Chlorine Free	mg/L	12/30/2015		0.79
Chlorine Free	mg/L	12/31/2015		0.74
Chlorine Total	mg/L	4/16/2015		0.92
Chlorine Total	mg/L	4/17/2015		0.85
Chlorine Total	mg/L	4/18/2015		0.8
Chlorine Total	mg/L	4/19/2015		0.85
Chlorine Total	mg/L	4/20/2015		LA
Chlorine Total	mg/L	4/21/2015		0.83
Chlorine Total	mg/L	4/22/2015		0.83
Chlorine Total	mg/L	4/23/2015		0.84
Chlorine Total	mg/L	4/24/2015		0.84
Chlorine Total	mg/L	4/25/2015		0.85
Chlorine Total	mg/L	4/26/2015		0.85
Chlorine Total	mg/L	4/27/2015		0.81
Chlorine Total	mg/L	4/28/2015		0.82
Chlorine Total	mg/L	4/29/2015		0.78
Chlorine Total	mg/L	4/30/2015		0.95
Chlorine Total	mg/L	5/1/2015		0.8
Chlorine Total	mg/L	5/2/2015		0.84
Chlorine Total	mg/L	5/3/2015		0.86
Chlorine Total	mg/L	5/4/2015		0.84
Chlorine Total	mg/L	5/5/2015		0.83
Chlorine Total	mg/L	5/6/2015		0.83
Chlorine Total	mg/L	5/7/2015		0.85
Chlorine Total	mg/L	5/8/2015		0.78

Analysis - Capilano	Units	Date Sampled	Source	Treated
Chlorine Total	mg/L	5/9/2015		0.82
Chlorine Total	mg/L	5/10/2015		0.86
Chlorine Total	mg/L	5/11/2015		0.85
Chlorine Total	mg/L	5/12/2015		0.82
Chlorine Total	mg/L	5/13/2015		0.68
Chlorine Total	mg/L	5/14/2015		0.83
Chlorine Total	mg/L	5/15/2015		0.67
Chlorine Total	mg/L	5/16/2015		0.8
Chlorine Total	mg/L	5/17/2015		0.8
Chlorine Total	mg/L	5/18/2015		0.85
Chlorine Total	mg/L	5/19/2015		0.64
Chlorine Total	mg/L	5/20/2015		0.8
Chlorine Total	mg/L	5/21/2015		0.69
Chlorine Total	mg/L	5/22/2015		0.86
Chlorine Total	mg/L	5/23/2015		0.81
Chlorine Total	mg/L	5/24/2015		0.84
Chlorine Total	mg/L	5/25/2015		0.82
Chlorine Total	mg/L	5/26/2015		0.86
Chlorine Total	mg/L	5/27/2015		0.83
Chlorine Total	mg/L	5/28/2015		0.72
Chlorine Total	mg/L	5/29/2015		0.75
Chlorine Total	mg/L	5/30/2015		0.84
Chlorine Total	mg/L	5/31/2015		0.86
Chlorine Total	mg/L	6/1/2015		0.84
Chlorine Total	mg/L	6/2/2015		0.84
Chlorine Total	mg/L	6/3/2015		0.55
Chlorine Total	mg/L	6/4/2015		0.78
Chlorine Total	mg/L	6/5/2015		0.67
Chlorine Total	mg/L	6/6/2015		0.87
Chlorine Total	mg/L	6/7/2015		0.83
Chlorine Total	mg/L	6/8/2015		0.75
Chlorine Total	mg/L	6/9/2015		0.83
Chlorine Total	mg/L	6/10/2015		0.79
Chlorine Total	mg/L	6/11/2015		0.74
Chlorine Total	mg/L	6/12/2015		0.89
Chlorine Total	mg/L	6/13/2015		0.8
Chlorine Total	mg/L	6/14/2015		0.9
Chlorine Total	mg/L	6/15/2015		0.75
Chlorine Total	mg/L	6/16/2015		0.72
Chlorine Total	mg/L	6/17/2015		0.87
Chlorine Total	mg/L	6/18/2015		0.57
Chlorine Total	mg/L	6/19/2015		0.9
Chlorine Total	mg/L	6/20/2015		0.84
Chlorine Total	mg/L	6/21/2015		0.83
Chlorine Total	mg/L	6/22/2015		0.82
Chlorine Total	mg/L	6/23/2015		0.82

Analysis - Capilano	Units	Date Sampled	Source	Treated
Chlorine Total	mg/L	6/24/2015		0.63
Chlorine Total	mg/L	6/25/2015		LA
Chlorine Total	mg/L	6/26/2015		0.76
Chlorine Total	mg/L	6/27/2015		0.89
Chlorine Total	mg/L	6/28/2015		0.9
Chlorine Total	mg/L	6/29/2015		0.67
Chlorine Total	mg/L	6/30/2015		0.8
Chlorine Total	mg/L	7/1/2015		0.85
Chlorine Total	mg/L	7/2/2015		0.86
Chlorine Total	mg/L	7/3/2015		0.85
Chlorine Total	mg/L	7/4/2015		0.84
Chlorine Total	mg/L	7/5/2015		0.91
Chlorine Total	mg/L	7/6/2015		<0.05
Chlorine Total	mg/L	7/7/2015		0.67
Chlorine Total	mg/L	7/8/2015		0.85
Chlorine Total	mg/L	7/9/2015		0.64
Chlorine Total	mg/L	7/10/2015		0.83
Chlorine Total	mg/L	7/11/2015		0.85
Chlorine Total	mg/L	7/12/2015		0.85
Chlorine Total	mg/L	7/13/2015		0.85
Chlorine Total	mg/L	7/14/2015		0.38
Chlorine Total	mg/L	7/15/2015		0.84
Chlorine Total	mg/L	7/16/2015		0.86
Chlorine Total	mg/L	7/17/2015		0.65
Chlorine Total	mg/L	7/18/2015		0.85
Chlorine Total	mg/L	7/19/2015		0.81
Chlorine Total	mg/L	7/20/2015		0.82
Chlorine Total	mg/L	7/21/2015		0.75
Chlorine Total	mg/L	7/22/2015		0.84
Chlorine Total	mg/L	7/23/2015		0.74
Chlorine Total	mg/L	7/24/2015		0.81
Chlorine Total	mg/L	7/25/2015		0.85
Chlorine Total	mg/L	7/26/2015		0.79
Chlorine Total	mg/L	7/27/2015		0.86
Chlorine Total	mg/L	7/28/2015		0.81
Chlorine Total	mg/L	7/29/2015		0.64
Chlorine Total	mg/L	7/30/2015		0.73
Chlorine Total	mg/L	7/31/2015		0.84
Chlorine Total	mg/L	8/1/2015		0.84
Chlorine Total	mg/L	8/2/2015		0.82
Chlorine Total	mg/L	8/3/2015		0.79
Chlorine Total	mg/L	8/4/2015		0.76
Chlorine Total	mg/L	8/5/2015		0.73
Chlorine Total	mg/L	8/6/2015		0.81
Chlorine Total	mg/L	8/7/2015		0.84
Chlorine Total	mg/L	8/8/2015		0.78

Analysis - Capilano	Units	Date Sampled	Source	Treated
Chlorine Total	mg/L	8/9/2015		0.76
Chlorine Total	mg/L	8/10/2015		0.72
Chlorine Total	mg/L	8/11/2015		0.8
Chlorine Total	mg/L	8/12/2015		0.82
Chlorine Total	mg/L	8/13/2015		0.86
Chlorine Total	mg/L	8/14/2015		0.78
Chlorine Total	mg/L	8/15/2015		0.74
Chlorine Total	mg/L	8/16/2015		0.76
Chlorine Total	mg/L	8/17/2015		0.74
Chlorine Total	mg/L	8/18/2015		0.53
Chlorine Total	mg/L	8/19/2015		0.76
Chlorine Total	mg/L	8/20/2015		0.8
Chlorine Total	mg/L	8/21/2015		0.68
Chlorine Total	mg/L	8/22/2015		0.8
Chlorine Total	mg/L	8/23/2015		0.85
Chlorine Total	mg/L	8/24/2015		0.86
Chlorine Total	mg/L	8/25/2015		0.69
Chlorine Total	mg/L	8/26/2015		0.57
Chlorine Total	mg/L	8/27/2015		0.68
Chlorine Total	mg/L	8/28/2015		0.65
Chlorine Total	mg/L	8/29/2015		0.82
Chlorine Total	mg/L	8/30/2015		0.76
Chlorine Total	mg/L	8/31/2015		0.51
Chlorine Total	mg/L	9/1/2015		0.87
Chlorine Total	mg/L	9/2/2015		0.8
Chlorine Total	mg/L	9/3/2015		0.82
Chlorine Total	mg/L	9/4/2015		0.81
Chlorine Total	mg/L	9/5/2015		0.81
Chlorine Total	mg/L	9/6/2015		0.78
Chlorine Total	mg/L	9/7/2015		0.8
Chlorine Total	mg/L	9/8/2015		0.82
Chlorine Total	mg/L	9/9/2015		0.73
Chlorine Total	mg/L	9/10/2015		0.6
Chlorine Total	mg/L	9/11/2015		0.64
Chlorine Total	mg/L	9/12/2015		0.85
Chlorine Total	mg/L	9/13/2015		0.81
Chlorine Total	mg/L	9/14/2015		0.8
Chlorine Total	mg/L	9/15/2015		0.81
Chlorine Total	mg/L	9/16/2015		0.74
Chlorine Total	mg/L	9/17/2015		0.72
Chlorine Total	mg/L	9/18/2015		0.78
Chlorine Total	mg/L	9/19/2015		0.77
Chlorine Total	mg/L	9/20/2015		0.81
Chlorine Total	mg/L	9/21/2015		0.78
Chlorine Total	mg/L	9/22/2015		0.75
Chlorine Total	mg/L	9/23/2015		0.69

Analysis - Capilano	Units	Date Sampled	Source	Treated
Chlorine Total	mg/L	9/24/2015		0.81
Chlorine Total	mg/L	9/25/2015		0.73
Chlorine Total	mg/L	9/26/2015		0.76
Chlorine Total	mg/L	9/27/2015		0.78
Chlorine Total	mg/L	9/28/2015		0.75
Chlorine Total	mg/L	9/29/2015		0.79
Chlorine Total	mg/L	9/30/2015		0.67
Chlorine Total	mg/L	10/1/2015		0.79
Chlorine Total	mg/L	10/2/2015		0.82
Chlorine Total	mg/L	10/3/2015		0.78
Chlorine Total	mg/L	10/4/2015		0.78
Chlorine Total	mg/L	10/5/2015		0.84
Chlorine Total	mg/L	10/7/2015		0.8
Chlorine Total	mg/L	10/8/2015		0.85
Chlorine Total	mg/L	10/9/2015		0.73
Chlorine Total	mg/L	10/10/2015		0.87
Chlorine Total	mg/L	10/11/2015		0.77
Chlorine Total	mg/L	10/12/2015		0.83
Chlorine Total	mg/L	10/13/2015		0.84
Chlorine Total	mg/L	10/14/2015		0.78
Chlorine Total	mg/L	10/15/2015		0.71
Chlorine Total	mg/L	10/16/2015		0.78
Chlorine Total	mg/L	10/17/2015		0.81
Chlorine Total	mg/L	10/18/2015	0.78	0.78
Chlorine Total	mg/L	10/19/2015		0.79
Chlorine Total	mg/L	10/20/2015		0.79
Chlorine Total	mg/L	10/21/2015		0.81
Chlorine Total	mg/L	10/22/2015		0.76
Chlorine Total	mg/L	10/23/2015		0.71
Chlorine Total	mg/L	10/24/2015		0.79
Chlorine Total	mg/L	10/25/2015		0.8
Chlorine Total	mg/L	10/26/2015		0.77
Chlorine Total	mg/L	10/27/2015		0.82
Chlorine Total	mg/L	10/28/2015		0.65
Chlorine Total	mg/L	10/29/2015		0.77
Chlorine Total	mg/L	10/30/2015		0.81
Chlorine Total	mg/L	10/31/2015		0.75
Chlorine Total	mg/L	11/1/2015		0.83
Chlorine Total	mg/L	11/2/2015		0.73
Chlorine Total	mg/L	11/3/2015		0.53
Chlorine Total	mg/L	11/4/2015		0.73
Chlorine Total	mg/L	11/5/2015		0.79
Chlorine Total	mg/L	11/6/2015		0.72
Chlorine Total	mg/L	11/7/2015		0.79
Chlorine Total	mg/L	11/8/2015		0.84
Chlorine Total	mg/L	11/9/2015		0.7

Analysis - Capilano	Units	Date Sampled	Source	Treated
Chlorine Total	mg/L	11/10/2015		0.71
Chlorine Total	mg/L	11/11/2015		0.81
Chlorine Total	mg/L	11/12/2015		0.62
Chlorine Total	mg/L	11/13/2015		0.83
Chlorine Total	mg/L	11/14/2015		0.83
Chlorine Total	mg/L	11/15/2015		0.78
Chlorine Total	mg/L	11/16/2015		0.78
Chlorine Total	mg/L	11/17/2015		0.73
Chlorine Total	mg/L	11/18/2015		0.56
Chlorine Total	mg/L	11/19/2015		0.74
Chlorine Total	mg/L	11/20/2015		0.76
Chlorine Total	mg/L	11/21/2015		0.81
Chlorine Total	mg/L	11/22/2015		0.83
Chlorine Total	mg/L	11/23/2015		0.78
Chlorine Total	mg/L	11/24/2015		0.57
Chlorine Total	mg/L	11/25/2015		0.65
Chlorine Total	mg/L	11/26/2015		0.8
Chlorine Total	mg/L	11/27/2015		0.76
Chlorine Total	mg/L	11/28/2015		0.85
Chlorine Total	mg/L	11/29/2015		0.82
Chlorine Total	mg/L	11/30/2015		0.73
Chlorine Total	mg/L	12/1/2015		0.8
Chlorine Total	mg/L	12/2/2015		0.8
Chlorine Total	mg/L	12/3/2015		0.77
Chlorine Total	mg/L	12/4/2015		0.8
Chlorine Total	mg/L	12/5/2015		0.84
Chlorine Total	mg/L	12/6/2015		0.82
Chlorine Total	mg/L	12/7/2015		0.79
Chlorine Total	mg/L	12/8/2015		0.81
Chlorine Total	mg/L	12/10/2015		0.75
Chlorine Total	mg/L	12/11/2015		0.68
Chlorine Total	mg/L	12/12/2015		0.8
Chlorine Total	mg/L	12/13/2015		0.81
Chlorine Total	mg/L	12/14/2015		0.82
Chlorine Total	mg/L	12/15/2015		0.78
Chlorine Total	mg/L	12/16/2015		0.63
Chlorine Total	mg/L	12/17/2015		0.8
Chlorine Total	mg/L	12/18/2015		0.62
Chlorine Total	mg/L	12/19/2015		0.82
Chlorine Total	mg/L	12/20/2015		0.83
Chlorine Total	mg/L	12/21/2015		0.7
Chlorine Total	mg/L	12/22/2015		0.82
Chlorine Total	mg/L	12/23/2015		0.58
Chlorine Total	mg/L	12/24/2015		0.77
Chlorine Total	mg/L	12/26/2015		0.78
Chlorine Total	mg/L	12/27/2015		0.79

Analysis - Capilano	Units	Date Sampled	Source	Treated
Chlorine Total	mg/L	12/28/2015		0.79
Chlorine Total	mg/L	12/29/2015		0.81
Chlorine Total	mg/L	12/30/2015		0.81
Chlorine Total	mg/L	12/31/2015		0.81
Chlorodibromomethane	ppb	2/17/2015	<1	
Chlorodibromomethane	ppb	5/20/2015	<1	<1
Chlorodibromomethane	ppb	8/18/2015	<1	<1
Chlorodibromomethane	ppb	11/25/2015	<1	<1
Chloroform	ppb	2/17/2015	<1	
Chloroform	ppb	5/20/2015	<1	16
Chloroform	ppb	8/18/2015	<1	17
Chloroform	ppb	11/25/2015	<1	17
Chromium Total	µg/L	4/16/2015		<0.05
Chromium Total	µg/L	4/22/2015		<0.05
Chromium Total	µg/L	4/27/2015		<0.05
Chromium Total	µg/L	5/4/2015		<0.05
Chromium Total	µg/L	5/5/2015	0.12	<0.05
Chromium Total	µg/L	5/11/2015		<0.05
Chromium Total	µg/L	5/19/2015		<0.05
Chromium Total	µg/L	6/1/2015	0.06	<0.05
Chromium Total	µg/L	10/20/2015	0.24	0.2
Chromium Total	µg/L	12/7/2015	0.1	<0.05
Cobalt Total	µg/L	4/16/2015		<0.5
Cobalt Total	µg/L	4/22/2015		<0.5
Cobalt Total	µg/L	4/27/2015		<0.5
Cobalt Total	µg/L	5/4/2015		<0.5
Cobalt Total	µg/L	5/5/2015	<0.5	<0.5
Cobalt Total	µg/L	5/11/2015		<0.5
Cobalt Total	µg/L	5/19/2015		<0.5
Cobalt Total	µg/L	10/20/2015	<0.5	<0.5
Color - Apparent	ACU	1/19/2015	34	
Color - Apparent	ACU	1/26/2015	34	
Color - Apparent	ACU	2/2/2015	34	
Color - Apparent	ACU	2/10/2015	23	
Color - Apparent	ACU	2/16/2015	22	
Color - Apparent	ACU	2/23/2015	23	
Color - Apparent	ACU	3/2/2015	21	
Color - Apparent	ACU	3/9/2015	22	
Color - Apparent	ACU	3/16/2015	20	
Color - Apparent	ACU	3/23/2015	22	
Color - Apparent	ACU	3/30/2015	23	
Color - Apparent	ACU	4/7/2015	23	
Color - Apparent	ACU	4/13/2015	24	
Color - Apparent	ACU	4/20/2015	22	<1
Color - Apparent	ACU	4/27/2015	22	<1
Color - Apparent	ACU	5/4/2015	19	<1

Analysis - Capilano	Units	Date Sampled	Source	Treated
Color - Apparent	ACU	5/11/2015	21	<1
Color - Apparent	ACU	5/19/2015	18	1
Color - Apparent	ACU	5/25/2015	20	<1
Color - Apparent	ACU	6/1/2015	20	<1
Color - Apparent	ACU	6/8/2015	17	<1
Color - Apparent	ACU	6/15/2015	18	<1
Color - Apparent	ACU	6/22/2015	19	<1
Color - Apparent	ACU	6/29/2015	17	<1
Color - Apparent	ACU	7/6/2015	18	<1
Color - Apparent	ACU	7/13/2015	18	<1
Color - Apparent	ACU	7/20/2015	19	<1
Color - Apparent	ACU	7/27/2015	21	1
Color - Apparent	ACU	8/4/2015	20	<1
Color - Apparent	ACU	8/10/2015	21	7
Color - Apparent	ACU	8/17/2015	23	7
Color - Apparent	ACU	8/24/2015	24	6
Color - Apparent	ACU	8/31/2015	30	6
Color - Apparent	ACU	9/8/2015	25	2
Color - Apparent	ACU	9/14/2015	24	4
Color - Apparent	ACU	9/21/2015	23	2
Color - Apparent	ACU	9/28/2015	25	3
Color - Apparent	ACU	10/5/2015	20	2
Color - Apparent	ACU	10/13/2015	24	2
Color - Apparent	ACU	10/19/2015	24	<1
Color - Apparent	ACU	10/26/2015	21	<1
Color - Apparent	ACU	11/2/2015	22	<1
Color - Apparent	ACU	11/9/2015	26	1
Color - Apparent	ACU	11/16/2015	25	1
Color - Apparent	ACU	11/23/2015	25	<1
Color - Apparent	ACU	11/30/2015	22	<1
Color - Apparent	ACU	12/7/2015	24	<1
Color - Apparent	ACU	12/14/2015	23	<1
Color - Apparent	ACU	12/21/2015	21	<1
Color - True	TCU	1/19/2015	17	
Color - True	TCU	1/26/2015	18	
Color - True	TCU	2/2/2015	17	
Color - True	TCU	2/10/2015	17	
Color - True	TCU	2/16/2015	16	
Color - True	TCU	2/23/2015	15	
Color - True	TCU	3/2/2015	16	
Color - True	TCU	3/9/2015	15	
Color - True	TCU	3/16/2015	15	
Color - True	TCU	3/23/2015	15	
Color - True	TCU	3/30/2015	17	
Color - True	TCU	4/7/2015	17	
Color - True	TCU	4/13/2015	14	

Analysis - Capilano	Units	Date Sampled	Source	Treated
Color - True	TCU	4/20/2015	15	<1
Color - True	TCU	4/27/2015	14	<1
Color - True	TCU	5/4/2015	14	2
Color - True	TCU	5/11/2015	14	<1
Color - True	TCU	5/19/2015	13	<1
Color - True	TCU	5/25/2015	14	<1
Color - True	TCU	6/1/2015	13	<1
Color - True	TCU	6/8/2015	12	<1
Color - True	TCU	6/15/2015	12	<1
Color - True	TCU	6/22/2015	12	<1
Color - True	TCU	6/29/2015	11	<1
Color - True	TCU	7/6/2015	10	<1
Color - True	TCU	7/13/2015	10	<1
Color - True	TCU	7/20/2015	11	<1
Color - True	TCU	7/27/2015	11	<1
Color - True	TCU	8/4/2015	11	<1
Color - True	TCU	8/10/2015	11	<1
Color - True	TCU	8/17/2015	12	<1
Color - True	TCU	8/24/2015	13	<1
Color - True	TCU	8/31/2015	14	<1
Color - True	TCU	9/8/2015	18	<1
Color - True	TCU	9/14/2015	12	<1
Color - True	TCU	9/21/2015	15	2
Color - True	TCU	9/28/2015	16	<1
Color - True	TCU	10/5/2015	14	1
Color - True	TCU	10/13/2015	14	<1
Color - True	TCU	10/19/2015	15	<1
Color - True	TCU	10/26/2015	13	<1
Color - True	TCU	11/2/2015	14	<1
Color - True	TCU	11/9/2015	18	<1
Color - True	TCU	11/16/2015	17	<1
Color - True	TCU	11/23/2015	17	<1
Color - True	TCU	11/30/2015	15	<1
Color - True	TCU	12/7/2015	17	<1
Color - True	TCU	12/14/2015	15	<1
Color - True	TCU	12/21/2015	14	<1
Conductivity	µmhos/cm	1/19/2015	12	
Conductivity	µmhos/cm	1/26/2015	11	
Conductivity	µmhos/cm	2/2/2015	12	
Conductivity	µmhos/cm	2/10/2015	9	
Conductivity	µmhos/cm	2/16/2015	9	
Conductivity	µmhos/cm	2/17/2015	9	
Conductivity	µmhos/cm	2/18/2015	9	
Conductivity	µmhos/cm	2/19/2015	9	
Conductivity	µmhos/cm	2/20/2015	9	
Conductivity	µmhos/cm	2/21/2015	9	

Analysis - Capilano	Units	Date Sampled	Source	Treated
Conductivity	µmhos/cm	2/23/2015	9	
Conductivity	µmhos/cm	3/2/2015	9	
Conductivity	µmhos/cm	3/9/2015	9	
Conductivity	µmhos/cm	3/16/2015	11	
Conductivity	µmhos/cm	3/23/2015	10	
Conductivity	µmhos/cm	3/30/2015	10	
Conductivity	µmhos/cm	4/7/2015	10	
Conductivity	µmhos/cm	4/13/2015	9	
Conductivity	µmhos/cm	4/20/2015	9	26
Conductivity	µmhos/cm	4/27/2015	10	26
Conductivity	µmhos/cm	5/4/2015	10	27
Conductivity	µmhos/cm	5/11/2015	11	27
Conductivity	µmhos/cm	5/19/2015	11	27
Conductivity	µmhos/cm	5/25/2015	11	27
Conductivity	µmhos/cm	6/1/2015	11	27
Conductivity	µmhos/cm	6/8/2015	11	26
Conductivity	µmhos/cm	6/15/2015	11	29
Conductivity	µmhos/cm	6/22/2015	11	29
Conductivity	µmhos/cm	6/29/2015	12	28
Conductivity	µmhos/cm	7/6/2015	13	32
Conductivity	µmhos/cm	7/13/2015	13	33
Conductivity	µmhos/cm	7/20/2015	13	32
Conductivity	µmhos/cm	7/27/2015	14	33
Conductivity	µmhos/cm	8/4/2015	14	33
Conductivity	µmhos/cm	8/10/2015	14	34
Conductivity	µmhos/cm	8/17/2015	14	33
Conductivity	µmhos/cm	8/24/2015	14	32
Conductivity	µmhos/cm	8/31/2015	15	29
Conductivity	µmhos/cm	9/8/2015	14	31
Conductivity	µmhos/cm	9/14/2015	14	32
Conductivity	µmhos/cm	9/21/2015	14	31
Conductivity	µmhos/cm	9/28/2015	14	32
Conductivity	µmhos/cm	10/5/2015	15	33
Conductivity	µmhos/cm	10/13/2015	15	34
Conductivity	µmhos/cm	10/19/2015	14	34
Conductivity	µmhos/cm	10/26/2015	15	31
Conductivity	µmhos/cm	11/2/2015	15	30
Conductivity	µmhos/cm	11/9/2015	13	28
Conductivity	µmhos/cm	11/16/2015	12	27
Conductivity	µmhos/cm	11/23/2015	12	27
Conductivity	µmhos/cm	11/30/2015	13	27
Conductivity	µmhos/cm	12/7/2015	12	27
Conductivity	µmhos/cm	12/14/2015	11	24
Conductivity	µmhos/cm	12/21/2015	12	26
Copper Total	µg/L	4/16/2015		0.7
Copper Total	µg/L	4/22/2015		0.6

Analysis - Capilano	Units	Date Sampled	Source	Treated
Copper Total	µg/L	4/27/2015		0.5
Copper Total	µg/L	5/4/2015		0.6
Copper Total	µg/L	5/5/2015	1.8	0.6
Copper Total	µg/L	5/11/2015		<0.5
Copper Total	µg/L	5/19/2015		0.6
Copper Total	µg/L	6/1/2015	3.4	<0.5
Copper Total	µg/L	10/20/2015	2.9	<0.5
Copper Total	µg/L	12/7/2015	7.1	<0.5
Cyanide Total	mg/L	6/1/2015	<0.02	<0.02
Cyanide Total	mg/L	12/7/2015	<0.02	<0.02
Dibromoacetic Acid	ppb	2/17/2015	<0.5	
Dibromoacetic Acid	ppb	5/20/2015	<0.5	<0.5
Dibromoacetic Acid	ppb	8/18/2015	<0.5	<0.5
Dibromoacetic Acid	ppb	11/25/2015	<0.5	<0.5
Dichloroacetic Acid	ppb	2/17/2015	<1	
Dichloroacetic Acid	ppb	5/20/2015	<1	7
Dichloroacetic Acid	ppb	8/18/2015	<1	7
Dichloroacetic Acid	ppb	11/25/2015	<1	9
Ethyl Benzene	ppb	4/16/2015		<0.5
Ethyl Benzene	ppb	4/22/2015		<0.5
Ethyl Benzene	ppb	4/27/2015		<0.5
Ethyl Benzene	ppb	5/4/2015		<0.5
Ethyl Benzene	ppb	5/11/2015		<0.5
Ethyl Benzene	ppb	5/19/2015		<0.5
Fluoride	mg/L	2/2/2015	<0.05	
Fluoride	mg/L	3/2/2015	<0.05	
Fluoride	mg/L	4/7/2015	<0.05	
Fluoride	mg/L	5/4/2015	<0.05	<0.05
Fluoride	mg/L	6/1/2015	<0.05	<0.05
Fluoride	mg/L	7/6/2015	<0.05	<0.05
Fluoride	mg/L	8/10/2015	<0.05	<0.05
Fluoride	mg/L	9/8/2015	<0.05	<0.05
Fluoride	mg/L	10/13/2015	<0.05	<0.05
Fluoride	mg/L	11/9/2015	<0.05	<0.05
Fluoride	mg/L	12/7/2015	<0.05	<0.05
HAA - Total Haloacetic Acid	ppb	2/17/2015	<3	
HAA - Total Haloacetic Acid	ppb	5/20/2015	<3	16.5
HAA - Total Haloacetic Acid	ppb	8/18/2015	<3	21.9
HAA - Total Haloacetic Acid	ppb	11/25/2015	<3	23.1
Hardness as CaCO3	mg/L	2/2/2015	3.95	
Hardness as CaCO3	mg/L	3/2/2015	3.26	
Hardness as CaCO3	mg/L	4/7/2015	3.26	
Hardness as CaCO3	mg/L	5/4/2015	3.65	9.13
Hardness as CaCO3	mg/L	6/1/2015	3.81	9.34
Hardness as CaCO3	mg/L	7/6/2015	4.23	11.3
Hardness as CaCO3	mg/L	8/10/2015	4.58	12.1

Analysis - Capilano	Units	Date Sampled	Source	Treated
Hardness as CaCO3	mg/L	9/8/2015	4.76	10.7
Hardness as CaCO3	mg/L	10/13/2015	4.8	11
Hardness as CaCO3	mg/L	11/9/2015	4.3	
Hardness as CaCO3	mg/L	12/7/2015	3.73	8.99
Iron Dissolved	µg/L	1/19/2015	78	
Iron Dissolved	µg/L	1/26/2015	62	
Iron Dissolved	µg/L	2/2/2015	60	
Iron Dissolved	µg/L	2/10/2015	38	
Iron Dissolved	µg/L	2/16/2015	25	
Iron Dissolved	µg/L	2/23/2015	23	
Iron Dissolved	µg/L	3/2/2015	25	
Iron Dissolved	µg/L	3/9/2015	30	
Iron Dissolved	µg/L	3/16/2015	35	
Iron Dissolved	µg/L	3/23/2015	37	
Iron Dissolved	µg/L	3/30/2015	25	
Iron Dissolved	µg/L	4/7/2015	28	
Iron Dissolved	µg/L	4/13/2015	32	
Iron Dissolved	µg/L	4/20/2015	32	<5
Iron Dissolved	µg/L	4/27/2015	34	<5
Iron Dissolved	µg/L	5/4/2015	47	<5
Iron Dissolved	µg/L	5/11/2015	46	<5
Iron Dissolved	µg/L	5/19/2015	36	<5
Iron Dissolved	µg/L	5/25/2015	46	<5
Iron Dissolved	µg/L	6/1/2015	43	<5
Iron Dissolved	µg/L	6/8/2015	47	<5
Iron Dissolved	µg/L	6/15/2015	51	<5
Iron Dissolved	µg/L	6/22/2015	63	<5
Iron Dissolved	µg/L	6/29/2015	71	<5
Iron Dissolved	µg/L	7/6/2015	88	<5
Iron Dissolved	µg/L	7/13/2015	87	<5
Iron Dissolved	µg/L	7/20/2015	126	<5
Iron Dissolved	µg/L	7/27/2015	180	<5
Iron Dissolved	µg/L	8/4/2015	182	<5
Iron Dissolved	µg/L	8/10/2015	229	<5
Iron Dissolved	µg/L	8/17/2015	291	<5
Iron Dissolved	µg/L	8/24/2015	308	8
Iron Dissolved	µg/L	8/31/2015	336	<5
Iron Dissolved	µg/L	9/8/2015	115	<5
Iron Dissolved	µg/L	9/14/2015	115	<5
Iron Dissolved	µg/L	9/21/2015	116	<5
Iron Dissolved	µg/L	9/28/2015	94	<5
Iron Dissolved	µg/L	10/5/2015	84	<5
Iron Dissolved	µg/L	10/13/2015	114	<5
Iron Dissolved	µg/L	10/19/2015	110	<5
Iron Dissolved	µg/L	10/26/2015	88	<5
Iron Dissolved	µg/L	11/2/2015	91	<5

Analysis - Capilano	Units	Date Sampled	Source	Treated
Iron Dissolved	µg/L	11/9/2015	66	<5
Iron Dissolved	µg/L	11/16/2015	49	<5
Iron Dissolved	µg/L	11/23/2015	43	<5
Iron Dissolved	µg/L	11/30/2015	42	<5
Iron Dissolved	µg/L	12/7/2015	40	<5
Iron Dissolved	µg/L	12/14/2015	25	<5
Iron Dissolved	µg/L	12/21/2015	29	<5
Iron Total	µg/L	1/19/2015	324	
Iron Total	µg/L	1/26/2015	261	
Iron Total	µg/L	2/2/2015	223	
Iron Total	µg/L	2/10/2015	148	
Iron Total	µg/L	2/16/2015	122	
Iron Total	µg/L	2/23/2015	119	
Iron Total	µg/L	3/2/2015	92	
Iron Total	µg/L	3/9/2015	96	
Iron Total	µg/L	3/16/2015	116	
Iron Total	µg/L	3/23/2015	91	
Iron Total	µg/L	3/30/2015	80	
Iron Total	µg/L	4/7/2015	84	
Iron Total	µg/L	4/13/2015	93	
Iron Total	µg/L	4/16/2015		<5
Iron Total	µg/L	4/20/2015	86	<5
Iron Total	µg/L	4/22/2015		<5
Iron Total	µg/L	4/27/2015	77	<5
Iron Total	µg/L	5/4/2015	91	<5
Iron Total	µg/L	5/5/2015	108	<5
Iron Total	µg/L	5/11/2015	89	<5
Iron Total	µg/L	5/19/2015	75	<5
Iron Total	µg/L	5/25/2015	98	<5
Iron Total	µg/L	6/1/2015	84	<5
Iron Total	µg/L	6/8/2015	90	5
Iron Total	µg/L	6/15/2015	114	<5
Iron Total	µg/L	6/22/2015	127	<5
Iron Total	µg/L	6/29/2015	149	<5
Iron Total	µg/L	7/6/2015	177	6
Iron Total	µg/L	7/13/2015	208	5
Iron Total	µg/L	7/20/2015	282	6
Iron Total	µg/L	7/27/2015	358	<5
Iron Total	µg/L	8/4/2015	353	<5
Iron Total	µg/L	8/10/2015	402	<5
Iron Total	µg/L	8/17/2015	473	<5
Iron Total	µg/L	8/24/2015	515	<5
Iron Total	µg/L	8/31/2015	689	<5
Iron Total	µg/L	9/8/2015	296	<5
Iron Total	µg/L	9/14/2015	284	24
Iron Total	µg/L	9/21/2015	251	<5

Analysis - Capilano	Units	Date Sampled	Source	Treated
Iron Total	µg/L	9/28/2015	210	<5
Iron Total	µg/L	10/5/2015	189	6
Iron Total	µg/L	10/13/2015	241	<5
Iron Total	µg/L	10/19/2015	206	<5
Iron Total	µg/L	10/20/2015	205	<5
Iron Total	µg/L	10/26/2015	177	<5
Iron Total	µg/L	11/2/2015	205	<5
Iron Total	µg/L	11/9/2015	227	LA
Iron Total	µg/L	11/16/2015	182	<5
Iron Total	µg/L	11/23/2015	149	<5
Iron Total	µg/L	11/30/2015	121	<5
Iron Total	µg/L	12/7/2015	127	<5
Iron Total	µg/L	12/14/2015	96	<5
Iron Total	µg/L	12/21/2015	85	<5
Lead Total	µg/L	4/16/2015		<0.5
Lead Total	µg/L	4/22/2015		<0.5
Lead Total	µg/L	4/27/2015		<0.5
Lead Total	µg/L	5/4/2015		<0.5
Lead Total	µg/L	5/5/2015	<0.5	<0.5
Lead Total	µg/L	5/11/2015		<0.5
Lead Total	µg/L	5/19/2015		<0.5
Lead Total	µg/L	6/1/2015	<0.5	<0.5
Lead Total	µg/L	10/20/2015	<0.5	<0.5
Lead Total	µg/L	12/7/2015	<0.5	<0.5
Magnesium Total	µg/L	2/2/2015	193	
Magnesium Total	µg/L	3/2/2015	150	
Magnesium Total	µg/L	4/7/2015	148	
Magnesium Total	µg/L	4/16/2015		150
Magnesium Total	µg/L	4/22/2015		151
Magnesium Total	µg/L	4/27/2015		153
Magnesium Total	µg/L	5/4/2015	157	161
Magnesium Total	µg/L	5/5/2015	162	171
Magnesium Total	µg/L	5/11/2015		161
Magnesium Total	µg/L	5/19/2015		163
Magnesium Total	µg/L	6/1/2015	160	171
Magnesium Total	µg/L	7/6/2015	176	195
Magnesium Total	µg/L	8/10/2015	200	202
Magnesium Total	µg/L	9/8/2015	225	190
Magnesium Total	µg/L	10/13/2015	205	200
Magnesium Total	µg/L	10/20/2015	201	209
Magnesium Total	µg/L	11/9/2015	218	LA
Magnesium Total	µg/L	12/7/2015	179	155
Manganese Dissolved	µg/L	2/2/2015	3.5	
Manganese Dissolved	µg/L	3/2/2015	4.6	
Manganese Dissolved	µg/L	4/7/2015	4.3	
Manganese Dissolved	µg/L	5/4/2015	7.1	3.4

Analysis - Capilano	Units	Date Sampled	Source	Treated
Manganese Dissolved	µg/L	6/1/2015	5.5	2.5
Manganese Dissolved	µg/L	7/6/2015	14	4.1
Manganese Dissolved	µg/L	8/10/2015	28.6	1.2
Manganese Dissolved	µg/L	9/8/2015	13.4	4.6
Manganese Dissolved	µg/L	10/13/2015	12.3	3.8
Manganese Dissolved	µg/L	11/9/2015	6.4	2.8
Manganese Dissolved	µg/L	12/7/2015	3.3	3.5
Manganese Total	µg/L	2/2/2015	5.5	
Manganese Total	µg/L	3/2/2015	6.1	
Manganese Total	µg/L	4/7/2015	5.6	
Manganese Total	µg/L	4/16/2015		4.2
Manganese Total	µg/L	4/22/2015		4.3
Manganese Total	µg/L	4/27/2015		4
Manganese Total	µg/L	5/4/2015	7.9	3.6
Manganese Total	µg/L	5/5/2015	9.1	4.2
Manganese Total	µg/L	5/11/2015		3.8
Manganese Total	µg/L	5/19/2015		2.9
Manganese Total	µg/L	6/1/2015	6.5	2.6
Manganese Total	µg/L	7/6/2015	15.3	6.2
Manganese Total	µg/L	8/10/2015	31	11
Manganese Total	µg/L	9/8/2015	18	6.8
Manganese Total	µg/L	10/13/2015	16.3	6.8
Manganese Total	µg/L	10/20/2015	13.9	8.6
Manganese Total	µg/L	11/9/2015	9.9	LA
Manganese Total	µg/L	12/7/2015	5.3	3.7
Mercury Total	µg/L	4/16/2015		<0.05
Mercury Total	µg/L	4/22/2015		<0.05
Mercury Total	µg/L	4/27/2015		<0.05
Mercury Total	µg/L	5/4/2015		<0.05
Mercury Total	µg/L	5/5/2015	<0.05	<0.05
Mercury Total	µg/L	5/11/2015		<0.05
Mercury Total	µg/L	5/19/2015		<0.05
Mercury Total	µg/L	6/1/2015	<0.05	<0.05
Mercury Total	µg/L	10/20/2015	<0.05	<0.05
Mercury Total	µg/L	12/7/2015	<0.05	<0.05
Molybdenum Total	µg/L	4/16/2015		<0.5
Molybdenum Total	µg/L	4/22/2015		<0.5
Molybdenum Total	µg/L	4/27/2015		<0.5
Molybdenum Total	µg/L	5/4/2015		<0.5
Molybdenum Total	µg/L	5/5/2015	<0.5	<0.5
Molybdenum Total	µg/L	5/11/2015		<0.5
Molybdenum Total	µg/L	5/19/2015		<0.5
Molybdenum Total	µg/L	10/20/2015	<0.5	<0.5
Monobromoacetic Acid	ppb	2/17/2015	<1	
Monobromoacetic Acid	ppb	5/20/2015	<1	<1
Monobromoacetic Acid	ppb	8/18/2015	<1	<1

Analysis - Capilano	Units	Date Sampled	Source	Treated
Monobromoacetic Acid	ppb	11/25/2015	<1	<1
Monochloroacetic Acid	ppb	2/17/2015	<2	
Monochloroacetic Acid	ppb	5/20/2015	<2	4
Monochloroacetic Acid	ppb	8/18/2015	<2	9
Monochloroacetic Acid	ppb	11/25/2015	<2	7
Nickel Total	µg/L	4/16/2015		<0.5
Nickel Total	µg/L	4/22/2015		<0.5
Nickel Total	µg/L	4/27/2015		<0.5
Nickel Total	µg/L	5/4/2015		<0.5
Nickel Total	µg/L	5/5/2015	<0.5	<0.5
Nickel Total	µg/L	5/11/2015		<0.5
Nickel Total	µg/L	5/19/2015		<0.5
Nickel Total	µg/L	6/1/2015	<0.5	<0.5
Nickel Total	µg/L	10/20/2015	<0.5	<0.5
Nickel Total	µg/L	12/7/2015	<0.5	<0.5
Nitrogen - Ammonia as N	mg/L	1/19/2015	<0.02	
Nitrogen - Ammonia as N	mg/L	1/26/2015	<0.02	
Nitrogen - Ammonia as N	mg/L	2/2/2015	<0.02	
Nitrogen - Ammonia as N	mg/L	2/10/2015	<0.02	
Nitrogen - Ammonia as N	mg/L	2/16/2015	<0.02	
Nitrogen - Ammonia as N	mg/L	2/23/2015	<0.02	
Nitrogen - Ammonia as N	mg/L	3/2/2015	<0.02	
Nitrogen - Ammonia as N	mg/L	3/9/2015	<0.02	
Nitrogen - Ammonia as N	mg/L	3/16/2015	<0.02	
Nitrogen - Ammonia as N	mg/L	3/23/2015	<0.02	
Nitrogen - Ammonia as N	mg/L	3/30/2015	<0.02	
Nitrogen - Ammonia as N	mg/L	4/7/2015	<0.02	
Nitrogen - Ammonia as N	mg/L	4/13/2015	<0.02	
Nitrogen - Ammonia as N	mg/L	4/20/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	4/27/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	5/4/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	5/11/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	5/19/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	5/25/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	6/1/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	6/8/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	6/15/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	6/22/2015	0.02	<0.02
Nitrogen - Ammonia as N	mg/L	6/29/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	7/6/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	7/13/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	7/20/2015	0.03	<0.02
Nitrogen - Ammonia as N	mg/L	7/27/2015	0.03	<0.02
Nitrogen - Ammonia as N	mg/L	8/4/2015	0.04	<0.02
Nitrogen - Ammonia as N	mg/L	8/10/2015	0.03	<0.02
Nitrogen - Ammonia as N	mg/L	8/17/2015	0.04	<0.02

Analysis - Capilano	Units	Date Sampled	Source	Treated
Nitrogen - Ammonia as N	mg/L	8/24/2015	0.04	<0.02
Nitrogen - Ammonia as N	mg/L	8/31/2015	0.05	<0.02
Nitrogen - Ammonia as N	mg/L	9/8/2015	0.02	<0.02
Nitrogen - Ammonia as N	mg/L	9/14/2015	0.02	<0.02
Nitrogen - Ammonia as N	mg/L	9/21/2015	0.02	<0.02
Nitrogen - Ammonia as N	mg/L	9/28/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	10/5/2015	0.02	<0.02
Nitrogen - Ammonia as N	mg/L	10/13/2015	0.03	<0.02
Nitrogen - Ammonia as N	mg/L	10/19/2015	0.02	<0.02
Nitrogen - Ammonia as N	mg/L	10/26/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	11/2/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	11/9/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	11/16/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	11/23/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	11/30/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	12/7/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	12/14/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	12/21/2015	<0.02	<0.02
Nitrogen - Nitrate as N	mg/L	2/2/2015	0.13	
Nitrogen - Nitrate as N	mg/L	3/2/2015	0.07	
Nitrogen - Nitrate as N	mg/L	4/7/2015	0.06	
Nitrogen - Nitrate as N	mg/L	5/4/2015	0.07	0.07
Nitrogen - Nitrate as N	mg/L	6/1/2015	0.06	0.06
Nitrogen - Nitrate as N	mg/L	7/6/2015	0.06	0.05
Nitrogen - Nitrate as N	mg/L	8/10/2015	0.03	0.04
Nitrogen - Nitrate as N	mg/L	9/8/2015	0.16	0.15
Nitrogen - Nitrate as N	mg/L	10/13/2015	0.14	0.13
Nitrogen - Nitrate as N	mg/L	11/9/2015	0.12	0.11
Nitrogen - Nitrate as N	mg/L	12/7/2015	0.09	0.1
Nitrogen - Nitrite as N	mg/L	2/2/2015	<0.01	
Nitrogen - Nitrite as N	mg/L	3/2/2015	<0.01	
Nitrogen - Nitrite as N	mg/L	4/7/2015	<0.01	
Nitrogen - Nitrite as N	mg/L	5/4/2015	<0.01	<0.01
Nitrogen - Nitrite as N	mg/L	6/1/2015	<0.01	<0.01
Nitrogen - Nitrite as N	mg/L	7/6/2015	<0.01	<0.01
Nitrogen - Nitrite as N	mg/L	8/10/2015	<0.01	<0.01
Nitrogen - Nitrite as N	mg/L	9/8/2015	<0.01	<0.01
Nitrogen - Nitrite as N	mg/L	10/13/2015	<0.01	<0.01
Nitrogen - Nitrite as N	mg/L	11/9/2015	<0.01	<0.01
Nitrogen - Nitrite as N	mg/L	12/7/2015	<0.01	<0.01
pH	pH units	1/19/2015	6.3	
pH	pH units	1/26/2015	6.2	
pH	pH units	2/2/2015	6.3	
pH	pH units	2/10/2015	6.4	
pH	pH units	2/16/2015	6.5	
pH	pH units	2/17/2015	6.6	

Analysis - Capilano	Units	Date Sampled	Source	Treated
pH	pH units	2/18/2015	6.5	
pH	pH units	2/19/2015	6.5	
pH	pH units	2/20/2015	6.6	
pH	pH units	2/21/2015	6.7	
pH	pH units	2/23/2015	6.5	
pH	pH units	3/2/2015	6.4	
pH	pH units	3/9/2015	6.5	
pH	pH units	3/16/2015	6.5	
pH	pH units	3/23/2015	6.5	
pH	pH units	3/30/2015	6.5	
pH	pH units	4/7/2015	6.4	
pH	pH units	4/13/2015	6.5	
pH	pH units	4/20/2015	6.5	7.2
pH	pH units	4/27/2015	6.5	7
pH	pH units	5/4/2015	6.5	7.2
pH	pH units	5/11/2015	6.5	7.2
pH	pH units	5/19/2015	6.5	7.2
pH	pH units	5/20/2015	6.4	7.2
pH	pH units	5/25/2015	6.5	7.3
pH	pH units	6/1/2015	6.3	7.3
pH	pH units	6/8/2015	6.5	7.3
pH	pH units	6/15/2015	6.5	7.3
pH	pH units	6/22/2015	6.4	7.3
pH	pH units	6/29/2015	6.5	7.4
pH	pH units	7/6/2015	6.5	7.4
pH	pH units	7/13/2015	6.4	7.4
pH	pH units	7/20/2015	6.5	7.4
pH	pH units	7/27/2015	6.4	7.4
pH	pH units	8/4/2015	6.4	7.4
pH	pH units	8/10/2015	6.5	7.4
pH	pH units	8/17/2015	6.3	7.3
pH	pH units	8/18/2015	6.3	7.3
pH	pH units	8/24/2015	6.4	7.4
pH	pH units	8/31/2015	6.4	7.4
pH	pH units	9/8/2015	6.5	7.2
pH	pH units	9/14/2015	6.5	7.2
pH	pH units	9/21/2015	6.5	7.2
pH	pH units	9/28/2015	6.5	7.2
pH	pH units	10/5/2015	6.6	7.2
pH	pH units	10/13/2015	6.5	7.3
pH	pH units	10/19/2015	6.5	7.2
pH	pH units	10/26/2015	6.5	7.2
pH	pH units	11/2/2015	6.5	7.2
pH	pH units	11/9/2015	6.5	7.2
pH	pH units	11/16/2015	6.5	7.1
pH	pH units	11/23/2015	6.6	7.2

Analysis - Capilano	Units	Date Sampled	Source	Treated
pH	pH units	11/25/2015	6.4	7.1
pH	pH units	11/30/2015	6.5	7.1
pH	pH units	12/7/2015	6.4	7.2
pH	pH units	12/14/2015	6.5	7.1
pH	pH units	12/21/2015	6.5	7.1
Phenol	mg/L	6/1/2015	<0.005	<0.005
Phenol	mg/L	12/7/2015	<0.005	<0.005
Phosphorus Dissolved Reactive	mg/L	2/2/2015	0.006	
Phosphorus Dissolved Reactive	mg/L	3/2/2015	<0.005	
Phosphorus Dissolved Reactive	mg/L	4/7/2015	0.008	
Phosphorus Dissolved Reactive	mg/L	5/4/2015	<0.005	<0.005
Phosphorus Dissolved Reactive	mg/L	6/1/2015	<0.005	<0.005
Phosphorus Dissolved Reactive	mg/L	7/6/2015	<0.005	<0.005
Phosphorus Dissolved Reactive	mg/L	8/10/2015	<0.005	<0.005
Phosphorus Dissolved Reactive	mg/L	9/8/2015	0.007	<0.005
Phosphorus Dissolved Reactive	mg/L	10/13/2015	<0.005	<0.005
Phosphorus Dissolved Reactive	mg/L	11/9/2015	0.008	<0.005
Phosphorus Dissolved Reactive	mg/L	12/7/2015	<0.005	<0.005
Phosphorus Total	µg/L	4/16/2015		<0.005
Phosphorus Total	µg/L	4/22/2015		<0.005
Phosphorus Total	µg/L	4/27/2015		<0.005
Phosphorus Total	µg/L	5/4/2015		<0.005
Phosphorus Total	µg/L	5/11/2015		<0.005
Phosphorus Total	µg/L	5/19/2015		<0.005
Phosphorus Total	mg/L	2/2/2015	0.006	
Phosphorus Total	mg/L	3/2/2015	<0.005	
Phosphorus Total	mg/L	4/7/2015	<0.005	
Phosphorus Total	mg/L	5/4/2015	<0.005	<0.005
Phosphorus Total	mg/L	6/1/2015	<0.005	<0.005
Phosphorus Total	mg/L	7/6/2015	<0.005	<0.005
Phosphorus Total	mg/L	8/10/2015	<0.005	<0.005
Phosphorus Total	mg/L	9/8/2015	<0.005	<0.005
Phosphorus Total	mg/L	10/13/2015	0.005	<0.005
Phosphorus Total	mg/L	11/9/2015	0.005	<0.005
Phosphorus Total	mg/L	12/7/2015	<0.005	<0.005
Potassium Total	µg/L	4/16/2015		160
Potassium Total	µg/L	4/22/2015		153
Potassium Total	µg/L	4/27/2015		153
Potassium Total	µg/L	5/4/2015		157
Potassium Total	µg/L	5/5/2015	161	171
Potassium Total	µg/L	5/11/2015		164
Potassium Total	µg/L	5/19/2015		166
Potassium Total	µg/L	6/1/2015	170	175
Potassium Total	µg/L	10/20/2015	232	242
Potassium Total	µg/L	12/7/2015	168	167
Residue Total	mg/L	2/2/2015	19	

Analysis - Capilano	Units	Date Sampled	Source	Treated
Residue Total	mg/L	4/7/2015	16	
Residue Total	mg/L	6/1/2015	17	28
Residue Total	mg/L	8/10/2015	23	34
Residue Total	mg/L	10/13/2015	21	29
Residue Total	mg/L	12/7/2015	17	25
Residue Total Dissolved	mg/L	2/2/2015	16	
Residue Total Dissolved	mg/L	4/7/2015	18	
Residue Total Dissolved	mg/L	6/1/2015	16	21
Residue Total Dissolved	mg/L	8/10/2015	19	27
Residue Total Dissolved	mg/L	10/13/2015	17	25
Residue Total Dissolved	mg/L	12/7/2015	14	18
Residue Total Fixed	mg/L	2/2/2015	9	
Residue Total Fixed	mg/L	4/7/2015	8	
Residue Total Fixed	mg/L	6/1/2015	10	22
Residue Total Fixed	mg/L	8/10/2015	16	27
Residue Total Fixed	mg/L	10/13/2015	12	20
Residue Total Fixed	mg/L	12/7/2015	10	19
Residue Total Volatile	mg/L	2/2/2015	9	
Residue Total Volatile	mg/L	4/7/2015	8	
Residue Total Volatile	mg/L	6/1/2015	7	7
Residue Total Volatile	mg/L	8/10/2015	7	7
Residue Total Volatile	mg/L	10/13/2015	9	9
Residue Total Volatile	mg/L	12/7/2015	7	6
Selenium Total	µg/L	4/16/2015		<0.5
Selenium Total	µg/L	4/22/2015		<0.5
Selenium Total	µg/L	4/27/2015		<0.5
Selenium Total	µg/L	5/4/2015		<0.5
Selenium Total	µg/L	5/5/2015	<0.5	<0.5
Selenium Total	µg/L	5/11/2015		<0.5
Selenium Total	µg/L	5/19/2015		<0.5
Selenium Total	µg/L	6/1/2015	<0.5	<0.5
Selenium Total	µg/L	10/20/2015	<0.5	<0.5
Selenium Total	µg/L	12/7/2015	<0.5	<0.5
Silica as SiO2	mg/L	2/2/2015	3.2	
Silica as SiO2	mg/L	4/7/2015	2.7	
Silica as SiO2	mg/L	6/1/2015	3.1	3.2
Silica as SiO2	mg/L	8/10/2015	3.5	3.4
Silica as SiO2	mg/L	10/13/2015	3.6	3.5
Silica as SiO2	mg/L	12/7/2015	3.1	3.1
Silver Total	µg/L	4/16/2015		<0.5
Silver Total	µg/L	4/22/2015		<0.5
Silver Total	µg/L	4/27/2015		<0.5
Silver Total	µg/L	5/4/2015		<0.5
Silver Total	µg/L	5/5/2015	<0.5	<0.5
Silver Total	µg/L	5/11/2015		<0.5
Silver Total	µg/L	5/19/2015		<0.5

Analysis - Capilano	Units	Date Sampled	Source	Treated
Silver Total	µg/L	6/1/2015	<0.5	<0.5
Silver Total	µg/L	10/20/2015	<0.5	<0.5
Silver Total	µg/L	12/7/2015	<0.5	<0.5
Sodium Total	µg/L	2/2/2015	605	
Sodium Total	µg/L	4/7/2015	505	
Sodium Total	µg/L	4/16/2015		1440
Sodium Total	µg/L	4/22/2015		1430
Sodium Total	µg/L	4/27/2015		1430
Sodium Total	µg/L	5/4/2015		1440
Sodium Total	µg/L	5/5/2015	561	1540
Sodium Total	µg/L	5/11/2015		1460
Sodium Total	µg/L	5/19/2015		1450
Sodium Total	µg/L	5/20/2015		1500
Sodium Total	µg/L	6/1/2015	591	1520
Sodium Total	µg/L	8/10/2015	728	1730
Sodium Total	µg/L	8/18/2015		1810
Sodium Total	µg/L	10/13/2015	721	1760
Sodium Total	µg/L	10/20/2015	716	1810
Sodium Total	µg/L	11/25/2015		1530
Sodium Total	µg/L	12/7/2015	563	1400
Sulphate	mg/L	2/2/2015	0.8	
Sulphate	mg/L	3/2/2015	0.7	
Sulphate	mg/L	4/7/2015	0.7	
Sulphate	mg/L	5/4/2015	0.8	1.1
Sulphate	mg/L	6/1/2015	0.9	1.1
Sulphate	mg/L	7/6/2015	0.9	1.1
Sulphate	mg/L	8/10/2015	0.9	1.3
Sulphate	mg/L	9/8/2015	0.9	1.1
Sulphate	mg/L	10/13/2015	0.9	1.3
Sulphate	mg/L	11/9/2015	0.8	1
Sulphate	mg/L	12/7/2015	0.8	1.1
Temperature	°C	1/19/2015	10	
Temperature	°C	1/26/2015	10	
Temperature	°C	2/2/2015	10	
Temperature	°C	2/10/2015	8.2	
Temperature	°C	2/16/2015	7.9	
Temperature	°C	2/23/2015	7	
Temperature	°C	3/2/2015	7.4	
Temperature	°C	3/9/2015	6.9	
Temperature	°C	3/16/2015	7.9	
Temperature	°C	3/23/2015	7.6	
Temperature	°C	3/30/2015	8.1	
Temperature	°C	4/7/2015	7.9	
Temperature	°C	4/13/2015	6.9	
Temperature	°C	4/20/2015	7.6	8.2
Temperature	°C	4/27/2015	8.3	9.2

Analysis - Capilano	Units	Date Sampled	Source	Treated
Temperature	°C	5/4/2015	8	8.7
Temperature	°C	5/11/2015	7.3	8.1
Temperature	°C	5/19/2015	16	9.5
Temperature	°C	5/25/2015	8.5	9.6
Temperature	°C	6/1/2015	8.9	9.1
Temperature	°C	6/8/2015	9.8	9.9
Temperature	°C	6/15/2015	9.3	11
Temperature	°C	6/22/2015	11	11
Temperature	°C	6/29/2015	14	14
Temperature	°C	7/6/2015	12	15
Temperature	°C	7/13/2015	13	14
Temperature	°C	7/20/2015	15	16
Temperature	°C	7/27/2015	18	19
Temperature	°C	8/4/2015	15	18
Temperature	°C	8/10/2015	16	17
Temperature	°C	8/17/2015	18	19
Temperature	°C	8/24/2015	19	20
Temperature	°C	8/31/2015	16	18
Temperature	°C	9/8/2015	18	18
Temperature	°C	9/14/2015	14	14
Temperature	°C	9/21/2015	14	14
Temperature	°C	9/28/2015	13	14
Temperature	°C	10/5/2015	13	14
Temperature	°C	10/13/2015	13	13
Temperature	°C	10/19/2015	13	13
Temperature	°C	10/26/2015	12	13
Temperature	°C	11/2/2015	12	12
Temperature	°C	11/3/2015	12	12
Temperature	°C	11/4/2015	11	11
Temperature	°C	11/5/2015	12	11
Temperature	°C	11/6/2015	11	10
Temperature	°C	11/7/2015	LA	
Temperature	°C	11/8/2015	LA	
Temperature	°C	11/9/2015	10	10
Temperature	°C	11/10/2015	10	9.9
Temperature	°C	11/11/2015	LA	
Temperature	°C	11/12/2015	LA	
Temperature	°C	11/13/2015	9.8	9.8
Temperature	°C	11/14/2015	8.6	8.9
Temperature	°C	11/15/2015	8.5	8.6
Temperature	°C	11/16/2015	9.1	8.9
Temperature	°C	11/17/2015	9.1	8.5
Temperature	°C	11/18/2015	8.2	8.4
Temperature	°C	11/19/2015	8	7.9
Temperature	°C	11/20/2015	8	7.9
Temperature	°C	11/21/2015	7.5	7.5

Analysis - Capilano	Units	Date Sampled	Source	Treated
Temperature	°C	11/22/2015	7.3	7.2
Temperature	°C	11/23/2015	7.7	7.5
Temperature	°C	11/24/2015	7.7	7.9
Temperature	°C	11/25/2015	7.9	7.3
Temperature	°C	11/26/2015	7.4	6.8
Temperature	°C	11/27/2015	7.3	6.8
Temperature	°C	11/28/2015	7.1	6.5
Temperature	°C	11/29/2015	7	6.3
Temperature	°C	11/30/2015	6.9	6.9
Temperature	°C	12/1/2015	7.3	6.4
Temperature	°C	12/2/2015	6.9	5.9
Temperature	°C	12/3/2015	7	6
Temperature	°C	12/4/2015	6.8	6.3
Temperature	°C	12/5/2015	6.6	5.9
Temperature	°C	12/6/2015	6.7	5.9
Temperature	°C	12/7/2015	7.2	6.3
Temperature	°C	12/8/2015	7.4	LA
Temperature	°C	12/9/2015	7.1	
Temperature	°C	12/10/2015	7.1	7.1
Temperature	°C	12/11/2015	6.7	7
Temperature	°C	12/12/2015	6.7	6.8
Temperature	°C	12/13/2015	6.7	6.9
Temperature	°C	12/14/2015	6.9	6.7
Temperature	°C	12/15/2015	6.9	7.1
Temperature	°C	12/16/2015	7	7.2
Temperature	°C	12/17/2015	6.9	6.7
Temperature	°C	12/18/2015	6.8	6.8
Temperature	°C	12/19/2015	6.4	6.2
Temperature	°C	12/20/2015	6.3	LA
Temperature	°C	12/21/2015	7.3	7.2
Temperature	°C	12/22/2015	6.5	6.3
Temperature	°C	12/23/2015	6.6	6.5
Temperature	°C	12/24/2015	7.3	7.4
Temperature	°C	12/26/2015	6.3	6.2
Temperature	°C	12/27/2015	6.3	6.1
Temperature	°C	12/28/2015	5.9	5.7
Temperature	°C	12/29/2015	6	5.9
Temperature	°C	12/30/2015	6	5.3
Temperature	°C	12/31/2015	5.8	5.4
THM-Total Trihalomethanes	ppb	2/17/2015	<2.0	
THM-Total Trihalomethanes	ppb	5/20/2015	<2.0	16.2
THM-Total Trihalomethanes	ppb	8/18/2015	<2.0	18.7
THM-Total Trihalomethanes	ppb	11/25/2015	<2	18.5
Toluene	ppb	4/16/2015		<0.5
Toluene	ppb	4/22/2015		<0.5
Toluene	ppb	4/27/2015		<0.5

Analysis - Capilano	Units	Date Sampled	Source	Treated
Toluene	ppb	5/4/2015		<0.5
Toluene	ppb	5/11/2015		<0.5
Toluene	ppb	5/19/2015		<0.5
Total Suspended Solids	mg/L	2/16/2015	2	
Total Suspended Solids	mg/L	2/17/2015	3	
Total Suspended Solids	mg/L	2/18/2015	3	
Total Suspended Solids	mg/L	2/19/2015	4	
Total Suspended Solids	mg/L	2/20/2015	3	
Total Suspended Solids	mg/L	2/21/2015	2	
Trichloroacetic Acid	ppb	2/17/2015	<0.5	
Trichloroacetic Acid	ppb	5/20/2015	<0.5	5.4
Trichloroacetic Acid	ppb	8/18/2015	<0.5	4.9
Trichloroacetic Acid	ppb	11/25/2015	<0.5	6.5
Turbidity	NTU	1/14/2015	6.2	
Turbidity	NTU	1/15/2015	5.4	
Turbidity	NTU	1/16/2015	5.1	
Turbidity	NTU	1/19/2015	4.5	
Turbidity	NTU	1/20/2015	4.4	
Turbidity	NTU	1/21/2015	4.3	
Turbidity	NTU	1/23/2015	4	
Turbidity	NTU	1/24/2015	4	
Turbidity	NTU	1/25/2015	3.9	
Turbidity	NTU	1/26/2015	3.7	
Turbidity	NTU	1/27/2015	3.6	
Turbidity	NTU	1/28/2015	3.6	
Turbidity	NTU	1/29/2015	3.4	
Turbidity	NTU	1/30/2015	3.3	
Turbidity	NTU	1/31/2015	3.1	
Turbidity	NTU	2/1/2015	3.1	
Turbidity	NTU	2/2/2015	3	
Turbidity	NTU	2/3/2015	2.9	
Turbidity	NTU	2/4/2015	1.5	
Turbidity	NTU	2/5/2015	1.3	
Turbidity	NTU	2/6/2015	1.3	
Turbidity	NTU	2/7/2015	1.2	
Turbidity	NTU	2/8/2015	1.6	
Turbidity	NTU	2/9/2015	2	
Turbidity	NTU	2/10/2015	2.1	
Turbidity	NTU	2/11/2015	2.8	
Turbidity	NTU	2/12/2015	2.8	
Turbidity	NTU	2/13/2015	2.9	
Turbidity	NTU	2/14/2015	1.9	
Turbidity	NTU	2/15/2015	2.2	
Turbidity	NTU	2/16/2015	2.1	
Turbidity	NTU	2/17/2015	2.2	
Turbidity	NTU	2/18/2015	2	

Analysis - Capilano	Units	Date Sampled	Source	Treated
Turbidity	NTU	2/19/2015	1.6	
Turbidity	NTU	2/20/2015	2.1	
Turbidity	NTU	2/21/2015	2	
Turbidity	NTU	2/22/2015	1.6	
Turbidity	NTU	2/23/2015	1.6	
Turbidity	NTU	2/24/2015	1.4	
Turbidity	NTU	2/25/2015	1.3	
Turbidity	NTU	2/26/2015	1.5	
Turbidity	NTU	2/27/2015	1.6	
Turbidity	NTU	2/28/2015	1.4	
Turbidity	NTU	3/1/2015	1.5	
Turbidity	NTU	3/2/2015	1.5	
Turbidity	NTU	3/3/2015	1.5	
Turbidity	NTU	3/4/2015	1.4	
Turbidity	NTU	3/5/2015	1.4	
Turbidity	NTU	3/6/2015	1.3	
Turbidity	NTU	3/7/2015	1.1	
Turbidity	NTU	3/8/2015	1.2	
Turbidity	NTU	3/9/2015	1.2	
Turbidity	NTU	3/10/2015	1.2	
Turbidity	NTU	3/11/2015	1.3	
Turbidity	NTU	3/12/2015	1.2	
Turbidity	NTU	3/13/2015	1.2	
Turbidity	NTU	3/14/2015	1.1	
Turbidity	NTU	3/15/2015	1.1	
Turbidity	NTU	3/16/2015	1.2	
Turbidity	NTU	3/17/2015	1.4	
Turbidity	NTU	3/18/2015	1.2	
Turbidity	NTU	3/19/2015	1.1	
Turbidity	NTU	3/20/2015	1.1	
Turbidity	NTU	3/21/2015	0.97	
Turbidity	NTU	3/22/2015	0.88	
Turbidity	NTU	3/23/2015	0.95	
Turbidity	NTU	3/24/2015	1.5	
Turbidity	NTU	3/25/2015	1.8	
Turbidity	NTU	3/26/2015	1.4	
Turbidity	NTU	3/27/2015	1.3	
Turbidity	NTU	3/28/2015	1.2	
Turbidity	NTU	3/29/2015	1	
Turbidity	NTU	3/30/2015	0.92	
Turbidity	NTU	3/31/2015	1.4	
Turbidity	NTU	4/1/2015	1.5	
Turbidity	NTU	4/2/2015	1.5	
Turbidity	NTU	4/3/2015	1.3	
Turbidity	NTU	4/4/2015	1.1	
Turbidity	NTU	4/5/2015	1.2	

Analysis - Capilano	Units	Date Sampled	Source	Treated
Turbidity	NTU	4/6/2015	1.1	
Turbidity	NTU	4/7/2015	1	
Turbidity	NTU	4/8/2015	0.98	
Turbidity	NTU	4/9/2015	1	
Turbidity	NTU	4/10/2015	1.1	
Turbidity	NTU	4/11/2015	0.9	
Turbidity	NTU	4/12/2015	0.92	
Turbidity	NTU	4/13/2015	1.1	
Turbidity	NTU	4/14/2015	1	
Turbidity	NTU	4/15/2015	1	
Turbidity	NTU	4/16/2015	0.96	0.26
Turbidity	NTU	4/17/2015	1	0.13
Turbidity	NTU	4/18/2015	0.91	0.08
Turbidity	NTU	4/19/2015	0.9	0.08
Turbidity	NTU	4/20/2015	1	0.1
Turbidity	NTU	4/21/2015	0.84	0.12
Turbidity	NTU	4/22/2015	0.9	0.26
Turbidity	NTU	4/23/2015	0.82	0.13
Turbidity	NTU	4/24/2015	0.83	0.13
Turbidity	NTU	4/25/2015	0.76	0.09
Turbidity	NTU	4/26/2015	0.79	0.08
Turbidity	NTU	4/27/2015	0.72	0.13
Turbidity	NTU	4/28/2015	0.81	0.12
Turbidity	NTU	4/29/2015	0.74	0.14
Turbidity	NTU	4/30/2015	0.79	0.09
Turbidity	NTU	5/1/2015	0.76	0.11
Turbidity	NTU	5/2/2015	0.7	0.1
Turbidity	NTU	5/3/2015	0.63	0.08
Turbidity	NTU	5/4/2015	0.69	0.1
Turbidity	NTU	5/5/2015	0.68	0.12
Turbidity	NTU	5/6/2015	0.76	0.15
Turbidity	NTU	5/7/2015	0.69	0.16
Turbidity	NTU	5/8/2015	0.62	0.1
Turbidity	NTU	5/9/2015	0.61	0.1
Turbidity	NTU	5/10/2015	0.58	0.09
Turbidity	NTU	5/11/2015	0.61	0.12
Turbidity	NTU	5/12/2015	0.61	0.12
Turbidity	NTU	5/13/2015	0.63	0.1
Turbidity	NTU	5/14/2015	0.63	0.1
Turbidity	NTU	5/15/2015	0.65	0.09
Turbidity	NTU	5/16/2015	0.57	0.09
Turbidity	NTU	5/17/2015	0.55	0.09
Turbidity	NTU	5/18/2015	0.58	0.12
Turbidity	NTU	5/19/2015	0.63	0.14
Turbidity	NTU	5/20/2015	0.58	0.11
Turbidity	NTU	5/21/2015	0.54	0.09

Analysis - Capilano	Units	Date Sampled	Source	Treated
Turbidity	NTU	5/22/2015	0.55	0.1
Turbidity	NTU	5/23/2015	0.54	0.1
Turbidity	NTU	5/24/2015	0.57	0.09
Turbidity	NTU	5/25/2015	0.57	0.1
Turbidity	NTU	5/26/2015	0.52	0.12
Turbidity	NTU	5/27/2015	0.64	0.13
Turbidity	NTU	5/28/2015	0.47	0.13
Turbidity	NTU	5/29/2015	0.52	0.1
Turbidity	NTU	5/30/2015	0.48	0.09
Turbidity	NTU	5/31/2015	0.42	0.09
Turbidity	NTU	6/1/2015	0.44	0.1
Turbidity	NTU	6/2/2015	0.45	0.13
Turbidity	NTU	6/3/2015	0.52	0.13
Turbidity	NTU	6/4/2015	0.52	0.11
Turbidity	NTU	6/5/2015	0.46	0.16
Turbidity	NTU	6/6/2015	0.38	0.09
Turbidity	NTU	6/7/2015	0.43	0.11
Turbidity	NTU	6/8/2015	0.4	0.13
Turbidity	NTU	6/9/2015	0.43	0.17
Turbidity	NTU	6/10/2015	0.38	0.16
Turbidity	NTU	6/11/2015	0.42	0.13
Turbidity	NTU	6/12/2015	0.44	0.15
Turbidity	NTU	6/13/2015	0.45	0.1
Turbidity	NTU	6/14/2015	0.42	0.09
Turbidity	NTU	6/15/2015	0.4	0.12
Turbidity	NTU	6/16/2015	0.38	0.11
Turbidity	NTU	6/17/2015	0.4	0.11
Turbidity	NTU	6/18/2015	0.46	0.13
Turbidity	NTU	6/19/2015		0.14
Turbidity	NTU	6/20/2015	0.52	0.12
Turbidity	NTU	6/21/2015	0.44	0.1
Turbidity	NTU	6/22/2015	0.45	0.1
Turbidity	NTU	6/23/2015	0.59	0.18
Turbidity	NTU	6/24/2015	0.54	0.18
Turbidity	NTU	6/25/2015	0.42	0.1
Turbidity	NTU	6/26/2015	0.44	0.13
Turbidity	NTU	6/27/2015	0.42	0.1
Turbidity	NTU	6/28/2015	0.42	0.1
Turbidity	NTU	6/29/2015	0.47	0.13
Turbidity	NTU	6/30/2015	0.47	0.15
Turbidity	NTU	7/1/2015	0.52	0.11
Turbidity	NTU	7/2/2015	0.44	0.12
Turbidity	NTU	7/3/2015	0.53	0.13
Turbidity	NTU	7/4/2015	0.49	0.12
Turbidity	NTU	7/5/2015	0.49	0.1
Turbidity	NTU	7/6/2015	0.57	0.1

Analysis - Capilano	Units	Date Sampled	Source	Treated
Turbidity	NTU	7/7/2015	0.56	0.12
Turbidity	NTU	7/8/2015	0.49	0.13
Turbidity	NTU	7/9/2015	0.53	0.14
Turbidity	NTU	7/10/2015	0.48	0.1
Turbidity	NTU	7/11/2015	0.52	0.11
Turbidity	NTU	7/12/2015	0.54	0.1
Turbidity	NTU	7/13/2015	0.53	0.14
Turbidity	NTU	7/14/2015	0.51	0.14
Turbidity	NTU	7/15/2015	0.56	0.14
Turbidity	NTU	7/16/2015	0.64	0.13
Turbidity	NTU	7/17/2015	0.65	0.13
Turbidity	NTU	7/18/2015	0.64	0.12
Turbidity	NTU	7/19/2015	0.62	0.11
Turbidity	NTU	7/20/2015	0.63	0.17
Turbidity	NTU	7/21/2015	0.7	0.14
Turbidity	NTU	7/22/2015	0.74	0.13
Turbidity	NTU	7/23/2015	0.67	0.11
Turbidity	NTU	7/24/2015	0.67	0.15
Turbidity	NTU	7/25/2015	0.78	0.14
Turbidity	NTU	7/26/2015	0.72	0.13
Turbidity	NTU	7/27/2015	0.82	0.21
Turbidity	NTU	7/28/2015	0.83	0.13
Turbidity	NTU	7/29/2015	0.8	0.19
Turbidity	NTU	7/30/2015	0.75	0.14
Turbidity	NTU	7/31/2015	0.81	0.15
Turbidity	NTU	8/1/2015	0.87	0.16
Turbidity	NTU	8/2/2015	0.79	0.16
Turbidity	NTU	8/3/2015	0.79	0.17
Turbidity	NTU	8/4/2015	0.81	0.1
Turbidity	NTU	8/5/2015	0.82	0.13
Turbidity	NTU	8/6/2015	0.84	0.13
Turbidity	NTU	8/7/2015	0.84	0.13
Turbidity	NTU	8/8/2015	0.9	0.17
Turbidity	NTU	8/9/2015	0.83	0.17
Turbidity	NTU	8/10/2015	0.79	0.16
Turbidity	NTU	8/11/2015	0.86	0.15
Turbidity	NTU	8/12/2015	0.86	0.17
Turbidity	NTU	8/13/2015	0.85	0.16
Turbidity	NTU	8/14/2015	0.84	0.16
Turbidity	NTU	8/15/2015	0.72	0.16
Turbidity	NTU	8/16/2015	0.73	0.13
Turbidity	NTU	8/17/2015	0.88	0.11
Turbidity	NTU	8/18/2015	0.85	0.1
Turbidity	NTU	8/19/2015	0.83	0.36
Turbidity	NTU	8/20/2015	0.86	0.16
Turbidity	NTU	8/21/2015	0.82	0.18

Analysis - Capilano	Units	Date Sampled	Source	Treated
Turbidity	NTU	8/22/2015	0.77	0.15
Turbidity	NTU	8/23/2015	0.85	0.13
Turbidity	NTU	8/24/2015	0.84	0.08
Turbidity	NTU	8/25/2015	0.91	0.12
Turbidity	NTU	8/26/2015	0.89	0.09
Turbidity	NTU	8/27/2015	0.95	0.1
Turbidity	NTU	8/28/2015	0.9	0.1
Turbidity	NTU	8/29/2015	0.93	0.16
Turbidity	NTU	8/30/2015	0.89	0.14
Turbidity	NTU	8/31/2015	1.1	0.08
Turbidity	NTU	9/1/2015	4.3	0.17
Turbidity	NTU	9/2/2015	4.5	0.13
Turbidity	NTU	9/3/2015	3.9	0.11
Turbidity	NTU	9/4/2015	3.4	0.1
Turbidity	NTU	9/5/2015	2.8	0.1
Turbidity	NTU	9/6/2015	2.5	0.11
Turbidity	NTU	9/7/2015	2.7	0.12
Turbidity	NTU	9/8/2015	2.1	0.13
Turbidity	NTU	9/9/2015	2.2	0.12
Turbidity	NTU	9/10/2015	2.2	0.1
Turbidity	NTU	9/11/2015	2	0.11
Turbidity	NTU	9/12/2015	1.9	0.11
Turbidity	NTU	9/13/2015	1.6	0.09
Turbidity	NTU	9/14/2015	1.8	0.82
Turbidity	NTU	9/15/2015	1.5	0.11
Turbidity	NTU	9/16/2015	1.5	0.12
Turbidity	NTU	9/17/2015	1.5	0.15
Turbidity	NTU	9/18/2015	1.4	0.09
Turbidity	NTU	9/19/2015	1.4	0.08
Turbidity	NTU	9/20/2015	1.4	0.1
Turbidity	NTU	9/21/2015	1.2	0.12
Turbidity	NTU	9/22/2015	1.6	0.13
Turbidity	NTU	9/23/2015	1.4	0.09
Turbidity	NTU	9/24/2015	1.3	0.12
Turbidity	NTU	9/25/2015	1.3	0.13
Turbidity	NTU	9/26/2015	1.1	0.12
Turbidity	NTU	9/27/2015	1.2	0.12
Turbidity	NTU	9/28/2015	0.97	0.12
Turbidity	NTU	9/29/2015	1.1	0.12
Turbidity	NTU	9/30/2015	1	0.1
Turbidity	NTU	10/1/2015	0.98	0.12
Turbidity	NTU	10/2/2015	0.94	0.11
Turbidity	NTU	10/3/2015	0.87	0.1
Turbidity	NTU	10/4/2015	0.77	0.08
Turbidity	NTU	10/5/2015	0.74	0.09
Turbidity	NTU	10/6/2015	0.83	

Analysis - Capilano	Units	Date Sampled	Source	Treated
Turbidity	NTU	10/7/2015	0.74	0.1
Turbidity	NTU	10/8/2015	0.77	0.13
Turbidity	NTU	10/9/2015	0.7	0.12
Turbidity	NTU	10/10/2015	0.75	0.09
Turbidity	NTU	10/11/2015	0.69	0.08
Turbidity	NTU	10/12/2015	0.69	0.09
Turbidity	NTU	10/13/2015	0.74	0.1
Turbidity	NTU	10/14/2015	0.73	0.1
Turbidity	NTU	10/15/2015	0.66	0.12
Turbidity	NTU	10/16/2015	0.73	0.11
Turbidity	NTU	10/17/2015	0.7	0.08
Turbidity	NTU	10/18/2015	0.66	0.09
Turbidity	NTU	10/19/2015	0.68	0.1
Turbidity	NTU	10/20/2015	0.67	0.12
Turbidity	NTU	10/21/2015	0.65	0.11
Turbidity	NTU	10/22/2015	0.66	0.09
Turbidity	NTU	10/23/2015	0.52	0.12
Turbidity	NTU	10/24/2015	0.47	0.1
Turbidity	NTU	10/25/2015	0.51	0.08
Turbidity	NTU	10/26/2015	0.55	0.11
Turbidity	NTU	10/27/2015	0.51	0.12
Turbidity	NTU	10/28/2015	0.54	0.12
Turbidity	NTU	10/29/2015	0.5	0.1
Turbidity	NTU	10/30/2015	0.54	0.12
Turbidity	NTU	10/31/2015	0.55	0.09
Turbidity	NTU	11/1/2015	0.59	0.09
Turbidity	NTU	11/2/2015	0.64	0.15
Turbidity	NTU	11/3/2015	0.69	0.14
Turbidity	NTU	11/4/2015	0.67	0.13
Turbidity	NTU	11/5/2015	0.71	0.1
Turbidity	NTU	11/6/2015	0.7	0.12
Turbidity	NTU	11/7/2015	0.68	0.09
Turbidity	NTU	11/8/2015	3.8	0.09
Turbidity	NTU	11/9/2015	3.2	0.09
Turbidity	NTU	11/10/2015	2.6	0.14
Turbidity	NTU	11/11/2015	2.3	0.11
Turbidity	NTU	11/12/2015	2.4	0.12
Turbidity	NTU	11/13/2015	2	0.13
Turbidity	NTU	11/14/2015	2.8	0.13
Turbidity	NTU	11/15/2015	2.7	0.09
Turbidity	NTU	11/16/2015	2.2	0.09
Turbidity	NTU	11/17/2015	2	0.11
Turbidity	NTU	11/18/2015	1.9	0.13
Turbidity	NTU	11/19/2015	2.2	0.11
Turbidity	NTU	11/20/2015	1.9	0.12
Turbidity	NTU	11/21/2015	1.9	0.12

Analysis - Capilano	Units	Date Sampled	Source	Treated
Turbidity	NTU	11/22/2015	1.8	0.1
Turbidity	NTU	11/23/2015	1.8	0.1
Turbidity	NTU	11/24/2015	1.7	0.1
Turbidity	NTU	11/25/2015	1.6	0.13
Turbidity	NTU	11/26/2015	1.5	0.1
Turbidity	NTU	11/27/2015	1.5	0.13
Turbidity	NTU	11/28/2015	1.4	0.1
Turbidity	NTU	11/29/2015	1.2	0.08
Turbidity	NTU	11/30/2015	1.3	0.1
Turbidity	NTU	12/1/2015	1.3	0.11
Turbidity	NTU	12/2/2015	1.3	0.13
Turbidity	NTU	12/3/2015	1.2	0.09
Turbidity	NTU	12/4/2015	1.2	0.12
Turbidity	NTU	12/5/2015	1.6	0.09
Turbidity	NTU	12/6/2015	1.6	0.08
Turbidity	NTU	12/7/2015	1.8	0.13
Turbidity	NTU	12/8/2015	1.8	0.13
Turbidity	NTU	12/9/2015	1.6	
Turbidity	NTU	12/10/2015	2	0.11
Turbidity	NTU	12/11/2015	1.9	0.1
Turbidity	NTU	12/12/2015	2	0.09
Turbidity	NTU	12/13/2015	1.8	0.08
Turbidity	NTU	12/14/2015	1.6	0.12
Turbidity	NTU	12/15/2015	2.1	0.12
Turbidity	NTU	12/16/2015	1.6	0.14
Turbidity	NTU	12/17/2015	1.6	0.12
Turbidity	NTU	12/18/2015	1.4	0.11
Turbidity	NTU	12/19/2015	1.3	0.12
Turbidity	NTU	12/20/2015	1.3	0.08
Turbidity	NTU	12/21/2015	1.1	0.09
Turbidity	NTU	12/22/2015	1.4	0.11
Turbidity	NTU	12/23/2015	1.2	0.1
Turbidity	NTU	12/24/2015	1.1	0.1
Turbidity	NTU	12/26/2015	1.1	0.07
Turbidity	NTU	12/27/2015	0.95	0.1
Turbidity	NTU	12/28/2015	1	0.08
Turbidity	NTU	12/29/2015	1	0.11
Turbidity	NTU	12/30/2015	0.96	0.09
Turbidity	NTU	12/31/2015	1	0.08
UV 254 - Transmittance	%	2/16/2015	77.3	
UV 254 - Transmittance	%	2/17/2015	77.4	
UV 254 - Transmittance	%	2/18/2015	77.2	
UV 254 - Transmittance	%	2/19/2015	77.3	
UV 254 - Transmittance	%	2/20/2015	77.7	
UV 254 - Transmittance	%	2/21/2015	78	
UV Absorbance 254 nm	Abs/cm	1/19/2015	0.104	

Analysis - Capilano	Units	Date Sampled	Source	Treated
UV Absorbance 254 nm	Abs/cm	1/26/2015	0.104	
UV Absorbance 254 nm	Abs/cm	2/2/2015	0.1	
UV Absorbance 254 nm	Abs/cm	2/10/2015	0.106	
UV Absorbance 254 nm	Abs/cm	2/16/2015	0.101	
UV Absorbance 254 nm	Abs/cm	2/23/2015	0.094	
UV Absorbance 254 nm	Abs/cm	3/2/2015	0.093	
UV Absorbance 254 nm	Abs/cm	3/9/2015	0.09	
UV Absorbance 254 nm	Abs/cm	3/16/2015	0.092	
UV Absorbance 254 nm	Abs/cm	3/23/2015	0.095	
UV Absorbance 254 nm	Abs/cm	3/30/2015	0.102	
UV Absorbance 254 nm	Abs/cm	4/7/2015	0.104	
UV Absorbance 254 nm	Abs/cm	4/13/2015	0.092	
UV Absorbance 254 nm	Abs/cm	4/20/2015	0.096	0.011
UV Absorbance 254 nm	Abs/cm	4/27/2015	0.09	0.01
UV Absorbance 254 nm	Abs/cm	5/4/2015	0.088	0.012
UV Absorbance 254 nm	Abs/cm	5/11/2015	0.087	0.01
UV Absorbance 254 nm	Abs/cm	5/19/2015	0.081	0.009
UV Absorbance 254 nm	Abs/cm	5/25/2015	0.085	0.012
UV Absorbance 254 nm	Abs/cm	6/1/2015	0.08	0.01
UV Absorbance 254 nm	Abs/cm	6/8/2015	0.076	0.011
UV Absorbance 254 nm	Abs/cm	6/15/2015	0.076	0.012
UV Absorbance 254 nm	Abs/cm	6/22/2015	0.073	0.01
UV Absorbance 254 nm	Abs/cm	6/29/2015	0.069	0.012
UV Absorbance 254 nm	Abs/cm	7/6/2015	0.066	0.011
UV Absorbance 254 nm	Abs/cm	7/13/2015	0.066	0.01
UV Absorbance 254 nm	Abs/cm	7/20/2015	0.064	0.012
UV Absorbance 254 nm	Abs/cm	7/27/2015	0.064	0.011
UV Absorbance 254 nm	Abs/cm	8/4/2015	0.061	0.01
UV Absorbance 254 nm	Abs/cm	8/10/2015	0.062	0.01
UV Absorbance 254 nm	Abs/cm	8/17/2015	0.068	0.01
UV Absorbance 254 nm	Abs/cm	8/24/2015	0.067	0.01
UV Absorbance 254 nm	Abs/cm	8/31/2015	0.073	0.01
UV Absorbance 254 nm	Abs/cm	9/8/2015	0.088	0.014
UV Absorbance 254 nm	Abs/cm	9/14/2015	0.082	0.014
UV Absorbance 254 nm	Abs/cm	9/21/2015	0.092	0.014
UV Absorbance 254 nm	Abs/cm	9/28/2015	0.092	0.014
UV Absorbance 254 nm	Abs/cm	10/5/2015	0.088	0.016
UV Absorbance 254 nm	Abs/cm	10/13/2015	0.09	0.014
UV Absorbance 254 nm	Abs/cm	10/19/2015	0.096	0.015
UV Absorbance 254 nm	Abs/cm	10/26/2015	0.087	0.017
UV Absorbance 254 nm	Abs/cm	11/2/2015	0.09	0.015
UV Absorbance 254 nm	Abs/cm	11/9/2015	0.113	0.014
UV Absorbance 254 nm	Abs/cm	11/16/2015	0.109	0.015
UV Absorbance 254 nm	Abs/cm	11/23/2015	0.104	0.013
UV Absorbance 254 nm	Abs/cm	11/30/2015	0.099	0.013
UV Absorbance 254 nm	Abs/cm	12/7/2015	0.108	0.011

Analysis - Capilano	Units	Date Sampled	Source	Treated
UV Absorbance 254 nm	Abs/cm	12/14/2015	0.101	0.013
UV Absorbance 254 nm	Abs/cm	12/21/2015	0.09	0.012
xylene meta para	ppb	4/16/2015		<1
xylene meta para	ppb	4/22/2015		<1
xylene meta para	ppb	4/27/2015		<1
xylene meta para	ppb	5/4/2015		<1
xylene meta para	ppb	5/11/2015		<1
xylene meta para	ppb	5/19/2015		<1
xylene ortho	ppb	4/16/2015		<0.5
xylene ortho	ppb	4/22/2015		<0.5
xylene ortho	ppb	4/27/2015		<0.5
xylene ortho	ppb	5/4/2015		<0.5
xylene ortho	ppb	5/11/2015		<0.5
xylene ortho	ppb	5/19/2015		<0.5
Xylene Total	ppb	4/16/2015		<1
Xylene Total	ppb	4/22/2015		<1
Xylene Total	ppb	4/27/2015		<1
Xylene Total	ppb	5/4/2015		<1
Xylene Total	ppb	5/11/2015		<1
Xylene Total	ppb	5/19/2015		<1
Zinc Total	µg/L	4/16/2015		<3
Zinc Total	µg/L	4/22/2015		<3
Zinc Total	µg/L	4/27/2015		<3
Zinc Total	µg/L	5/4/2015		<3
Zinc Total	µg/L	5/5/2015	<3	<3
Zinc Total	µg/L	5/11/2015		<3
Zinc Total	µg/L	5/19/2015		<3
Zinc Total	µg/L	6/1/2015	<3	<3
Zinc Total	µg/L	10/20/2015	<3	<3
Zinc Total	µg/L	12/7/2015	<3	<3

Seymour

Analysis - Seymour	Units	Date Sampled	Source	Treated
Alkalinity as CaCO3	mg/L	1/5/2015	3	6.8
Alkalinity as CaCO3	mg/L	2/2/2015	3.2	7.4
Alkalinity as CaCO3	mg/L	3/2/2015	2.8	6.1
Alkalinity as CaCO3	mg/L	4/7/2015	2.9	7.8
Alkalinity as CaCO3	mg/L	5/4/2015	3.8	7
Alkalinity as CaCO3	mg/L	6/1/2015	4.2	7.6
Alkalinity as CaCO3	mg/L	7/6/2015	4.6	9.9
Alkalinity as CaCO3	mg/L	8/10/2015	4.9	10.8
Alkalinity as CaCO3	mg/L	9/8/2015	3.8	8.1
Alkalinity as CaCO3	mg/L	10/13/2015	4.6	9
Alkalinity as CaCO3	mg/L	11/9/2015	3.5	6.7
Alkalinity as CaCO3	mg/L	12/7/2015	2.9	6.4
Aluminium Dissolved	µg/L	2/2/2015	82	30
Aluminium Dissolved	µg/L	4/7/2015	79	27
Aluminium Dissolved	µg/L	6/1/2015	48	24
Aluminium Dissolved	µg/L	8/10/2015	37	15
Aluminium Dissolved	µg/L	10/13/2015	72	21
Aluminium Dissolved	µg/L	12/7/2015	110	40
Aluminum Total	µg/L	1/5/2015	165	38
Aluminum Total	µg/L	1/12/2015	143	33
Aluminum Total	µg/L	1/19/2015	126	29
Aluminum Total	µg/L	1/26/2015	123	36
Aluminum Total	µg/L	2/2/2015	138	32
Aluminum Total	µg/L	2/10/2015	430	92
Aluminum Total	µg/L	2/16/2015	425	54
Aluminum Total	µg/L	2/17/2015	180	43
Aluminum Total	µg/L	2/23/2015	238	37
Aluminum Total	µg/L	3/2/2015	137	28
Aluminum Total	µg/L	3/9/2015	122	25
Aluminum Total	µg/L	3/16/2015	108	23
Aluminum Total	µg/L	3/23/2015	116	28
Aluminum Total	µg/L	3/30/2015	123	31
Aluminum Total	µg/L	4/7/2015	114	32
Aluminum Total	µg/L	4/13/2015	115	30
Aluminum Total	µg/L	4/20/2015	93	31
Aluminum Total	µg/L	4/27/2015	84	30
Aluminum Total	µg/L	5/4/2015	77	29
Aluminum Total	µg/L	5/5/2015	80	29
Aluminum Total	µg/L	5/11/2015	70	27
Aluminum Total	µg/L	5/19/2015	67	23
Aluminum Total	µg/L	5/25/2015	74	28
Aluminum Total	µg/L	6/1/2015	72	26
Aluminum Total	µg/L	6/8/2015	61	27
Aluminum Total	µg/L	6/15/2015	56	43
Aluminum Total	µg/L	6/22/2015	51	25

Analysis - Seymour	Units	Date Sampled	Source	Treated
Aluminum Total	µg/L	6/29/2015	66	23
Aluminum Total	µg/L	7/6/2015	57	26
Aluminum Total	µg/L	7/13/2015	60	22
Aluminum Total	µg/L	7/20/2015	59	24
Aluminum Total	µg/L	7/27/2015	64	18
Aluminum Total	µg/L	8/4/2015	61	17
Aluminum Total	µg/L	8/10/2015	58	17
Aluminum Total	µg/L	8/17/2015	53	16
Aluminum Total	µg/L	8/24/2015	52	16
Aluminum Total	µg/L	8/31/2015	56	16
Aluminum Total	µg/L	9/8/2015	714	31
Aluminum Total	µg/L	9/14/2015	375	28
Aluminum Total	µg/L	9/21/2015	164	25
Aluminum Total	µg/L	9/28/2015	483	26
Aluminum Total	µg/L	10/5/2015	357	26
Aluminum Total	µg/L	10/13/2015	239	28
Aluminum Total	µg/L	10/19/2015	229	27
Aluminum Total	µg/L	10/20/2015	205	29
Aluminum Total	µg/L	10/26/2015	190	20
Aluminum Total	µg/L	11/2/2015	153	23
Aluminum Total	µg/L	11/9/2015	140	41
Aluminum Total	µg/L	11/16/2015	137	41
Aluminum Total	µg/L	11/23/2015	150	38
Aluminum Total	µg/L	11/30/2015	140	38
Aluminum Total	µg/L	12/7/2015	427	42
Aluminum Total	µg/L	12/14/2015	335	58
Aluminum Total	µg/L	12/21/2015	258	46
Antimony Total	µg/L	2/17/2015	<0.5	<0.5
Antimony Total	µg/L	5/5/2015	<0.5	<0.5
Antimony Total	µg/L	6/1/2015	<0.5	<0.5
Antimony Total	µg/L	10/20/2015	<0.5	<0.5
Antimony Total	µg/L	12/7/2015	<0.5	<0.5
Arsenic Total	µg/L	2/17/2015	<0.5	<0.5
Arsenic Total	µg/L	5/5/2015	<0.5	<0.5
Arsenic Total	µg/L	6/1/2015	<0.5	<0.5
Arsenic Total	µg/L	10/20/2015	<0.5	<0.5
Arsenic Total	µg/L	12/7/2015	<0.5	<0.5
Barium Total	µg/L	2/17/2015	3.3	2.7
Barium Total	µg/L	5/5/2015	3.6	2.9
Barium Total	µg/L	6/1/2015	3.9	2.9
Barium Total	µg/L	10/20/2015	5.1	3.7
Barium Total	µg/L	12/7/2015	5.5	3.2
Boron Total	µg/L	2/17/2015	<10	<10
Boron Total	µg/L	5/5/2015	<10	<10
Boron Total	µg/L	6/1/2015	<10	<10

Analysis - Seymour	Units	Date Sampled	Source	Treated
Boron Total	µg/L	10/20/2015	<10	<10
Boron Total	µg/L	12/7/2015	<10	<10
Bromate	mg/L	2/17/2015	<0.01	<0.01
Bromate	mg/L	5/20/2015	<0.01	<0.01
Bromate	mg/L	8/18/2015	<0.01	<0.01
Bromate	mg/L	11/25/2015	<0.01	<0.01
Bromide	mg/L	2/17/2015	<0.01	<0.01
Bromide	mg/L	5/20/2015	<0.01	<0.01
Bromide	mg/L	8/18/2015	<0.01	<0.01
Bromide	mg/L	11/25/2015	<0.01	<0.01
Bromodichloromethane	ppb	2/17/2015	<1	<1
Bromodichloromethane	ppb	5/20/2015	<1	<1
Bromodichloromethane	ppb	8/18/2015	<1	1
Bromodichloromethane	ppb	11/25/2015	<1	<1
Bromoform	ppb	2/17/2015	<1	<1
Bromoform	ppb	5/20/2015	<1	<1
Bromoform	ppb	8/18/2015	<1	<1
Bromoform	ppb	11/25/2015	<1	<1
Cadmium Total	µg/L	2/17/2015	<0.2	<0.2
Cadmium Total	µg/L	5/5/2015	<0.2	<0.2
Cadmium Total	µg/L	6/1/2015	<0.2	<0.2
Cadmium Total	µg/L	10/20/2015	<0.2	<0.2
Cadmium Total	µg/L	12/7/2015	<0.2	<0.2
Calcium Total	µg/L	1/5/2015	1480	3220
Calcium Total	µg/L	2/2/2015	1480	3210
Calcium Total	µg/L	2/17/2015	1130	2860
Calcium Total	µg/L	3/2/2015	1330	2930
Calcium Total	µg/L	4/7/2015	1390	3560
Calcium Total	µg/L	5/4/2015	1750	3300
Calcium Total	µg/L	5/5/2015	1840	3430
Calcium Total	µg/L	6/1/2015	1980	3310
Calcium Total	µg/L	7/6/2015	2050	4120
Calcium Total	µg/L	8/10/2015	2120	4400
Calcium Total	µg/L	9/8/2015	1990	3940
Calcium Total	µg/L	10/13/2015	2180	4120
Calcium Total	µg/L	10/20/2015	2170	4210
Calcium Total	µg/L	11/9/2015	1810	3430
Calcium Total	µg/L	12/7/2015	1490	3290
Carbon Organic - Dissolved	mg/L	1/5/2015	1.9	0.7
Carbon Organic - Dissolved	mg/L	1/12/2015	1.7	0.6
Carbon Organic - Dissolved	mg/L	1/19/2015	1.6	0.6
Carbon Organic - Dissolved	mg/L	1/26/2015	1.9	0.6
Carbon Organic - Dissolved	mg/L	2/2/2015	1.9	0.7
Carbon Organic - Dissolved	mg/L	2/10/2015	2.7	0.8
Carbon Organic - Dissolved	mg/L	2/16/2015	2.2	0.7

Analysis - Seymour	Units	Date Sampled	Source	Treated
Carbon Organic - Dissolved	mg/L	2/23/2015	2	0.7
Carbon Organic - Dissolved	mg/L	3/2/2015	1.8	0.6
Carbon Organic - Dissolved	mg/L	3/9/2015	1.6	0.6
Carbon Organic - Dissolved	mg/L	3/16/2015	1.4	0.7
Carbon Organic - Dissolved	mg/L	3/23/2015	1.7	0.6
Carbon Organic - Dissolved	mg/L	3/30/2015	1.9	0.7
Carbon Organic - Dissolved	mg/L	4/7/2015	1.8	0.5
Carbon Organic - Dissolved	mg/L	4/13/2015	1.9	0.7
Carbon Organic - Dissolved	mg/L	4/20/2015	1.7	0.6
Carbon Organic - Dissolved	mg/L	4/27/2015	1.6	0.6
Carbon Organic - Dissolved	mg/L	5/4/2015	1.5	0.6
Carbon Organic - Dissolved	mg/L	5/11/2015	1.4	0.6
Carbon Organic - Dissolved	mg/L	5/19/2015	1.4	0.6
Carbon Organic - Dissolved	mg/L	5/25/2015	1.3	0.6
Carbon Organic - Dissolved	mg/L	6/1/2015	1.3	0.6
Carbon Organic - Dissolved	mg/L	6/8/2015	1.3	0.6
Carbon Organic - Dissolved	mg/L	6/15/2015	1.2	0.7
Carbon Organic - Dissolved	mg/L	6/22/2015	1.2	0.7
Carbon Organic - Dissolved	mg/L	6/29/2015	1.3	0.7
Carbon Organic - Dissolved	mg/L	7/6/2015	1.2	0.7
Carbon Organic - Dissolved	mg/L	7/13/2015	1.3	0.7
Carbon Organic - Dissolved	mg/L	7/20/2015	1.3	0.7
Carbon Organic - Dissolved	mg/L	7/27/2015	1.3	0.7
Carbon Organic - Dissolved	mg/L	8/4/2015	1.3	0.7
Carbon Organic - Dissolved	mg/L	8/10/2015	1.2	0.7
Carbon Organic - Dissolved	mg/L	8/17/2015	1.2	0.7
Carbon Organic - Dissolved	mg/L	8/24/2015	1.1	0.7
Carbon Organic - Dissolved	mg/L	8/31/2015	1.1	0.6
Carbon Organic - Dissolved	mg/L	9/8/2015	2.4	0.9
Carbon Organic - Dissolved	mg/L	9/14/2015	2.1	0.9
Carbon Organic - Dissolved	mg/L	9/21/2015	1.9	0.9
Carbon Organic - Dissolved	mg/L	9/28/2015	2.1	0.9
Carbon Organic - Dissolved	mg/L	10/5/2015	2.1	0.9
Carbon Organic - Dissolved	mg/L	10/13/2015	1.9	0.9
Carbon Organic - Dissolved	mg/L	10/19/2015	2.3	0.9
Carbon Organic - Dissolved	mg/L	10/26/2015	2	0.9
Carbon Organic - Dissolved	mg/L	11/2/2015	2	0.9
Carbon Organic - Dissolved	mg/L	11/9/2015	2.2	0.9
Carbon Organic - Dissolved	mg/L	11/16/2015	2.3	0.9
Carbon Organic - Dissolved	mg/L	11/23/2015	2.2	0.8
Carbon Organic - Dissolved	mg/L	11/30/2015	2.1	0.8
Carbon Organic - Dissolved	mg/L	12/7/2015	2.5	0.8
Carbon Organic - Dissolved	mg/L	12/14/2015	2.3	0.7
Carbon Organic - Dissolved	mg/L	12/21/2015	2	0.7
Carbon Organic - Total	mg/L	1/5/2015	1.9	0.6

Analysis - Seymour	Units	Date Sampled	Source	Treated
Carbon Organic - Total	mg/L	1/12/2015	1.8	0.6
Carbon Organic - Total	mg/L	1/19/2015	1.6	0.6
Carbon Organic - Total	mg/L	1/26/2015	2	0.6
Carbon Organic - Total	mg/L	2/2/2015	1.9	0.6
Carbon Organic - Total	mg/L	2/10/2015	2.7	0.8
Carbon Organic - Total	mg/L	2/16/2015	2.2	0.7
Carbon Organic - Total	mg/L	2/23/2015	2	0.7
Carbon Organic - Total	mg/L	3/2/2015	1.8	0.6
Carbon Organic - Total	mg/L	3/9/2015	1.6	0.6
Carbon Organic - Total	mg/L	3/16/2015	1.5	0.6
Carbon Organic - Total	mg/L	3/23/2015	1.8	0.6
Carbon Organic - Total	mg/L	3/30/2015	2	0.7
Carbon Organic - Total	mg/L	4/7/2015	1.8	0.5
Carbon Organic - Total	mg/L	4/13/2015	1.9	0.7
Carbon Organic - Total	mg/L	4/20/2015	1.7	0.6
Carbon Organic - Total	mg/L	4/27/2015	1.6	0.6
Carbon Organic - Total	mg/L	5/4/2015	1.5	0.6
Carbon Organic - Total	mg/L	5/11/2015	1.5	0.6
Carbon Organic - Total	mg/L	5/19/2015	1.4	0.6
Carbon Organic - Total	mg/L	5/25/2015	1.4	0.6
Carbon Organic - Total	mg/L	6/1/2015	1.3	0.6
Carbon Organic - Total	mg/L	6/8/2015	1.3	0.6
Carbon Organic - Total	mg/L	6/15/2015	1.2	0.6
Carbon Organic - Total	mg/L	6/22/2015	1.2	0.7
Carbon Organic - Total	mg/L	6/29/2015	1.3	0.7
Carbon Organic - Total	mg/L	7/6/2015	1.3	0.7
Carbon Organic - Total	mg/L	7/13/2015	1.3	0.7
Carbon Organic - Total	mg/L	7/20/2015	1.4	0.7
Carbon Organic - Total	mg/L	7/27/2015	1.3	0.7
Carbon Organic - Total	mg/L	8/4/2015	1.3	0.7
Carbon Organic - Total	mg/L	8/10/2015	1.2	0.6
Carbon Organic - Total	mg/L	8/17/2015	1.2	0.6
Carbon Organic - Total	mg/L	8/24/2015	1.2	0.6
Carbon Organic - Total	mg/L	8/31/2015	1.2	0.6
Carbon Organic - Total	mg/L	9/8/2015	2.6	0.9
Carbon Organic - Total	mg/L	9/14/2015	2.1	0.9
Carbon Organic - Total	mg/L	9/21/2015	1.9	0.9
Carbon Organic - Total	mg/L	9/28/2015	2.3	0.9
Carbon Organic - Total	mg/L	10/5/2015	2.1	0.9
Carbon Organic - Total	mg/L	10/13/2015	1.9	0.9
Carbon Organic - Total	mg/L	10/19/2015	2.4	0.9
Carbon Organic - Total	mg/L	10/26/2015	2.1	0.9
Carbon Organic - Total	mg/L	11/2/2015	2	0.9
Carbon Organic - Total	mg/L	11/9/2015	2.3	0.9
Carbon Organic - Total	mg/L	11/16/2015	2.4	0.9

Analysis - Seymour	Units	Date Sampled	Source	Treated
Carbon Organic - Total	mg/L	11/23/2015	2.2	0.8
Carbon Organic - Total	mg/L	11/30/2015	2.1	0.8
Carbon Organic - Total	mg/L	12/7/2015	2.6	0.7
Carbon Organic - Total	mg/L	12/14/2015	2.4	0.7
Carbon Organic - Total	mg/L	12/21/2015	2.1	0.7
Chlorate	mg/L	2/17/2015	<0.01	0.03
Chlorate	mg/L	5/20/2015	<0.01	0.03
Chlorate	mg/L	8/18/2015	<0.01	0.07
Chlorate	mg/L	11/25/2015	<0.01	0.02
Chloride	mg/L	1/5/2015	<0.5	2.4
Chloride	mg/L	2/2/2015	<0.5	2.3
Chloride	mg/L	2/17/2015	<0.5	2.2
Chloride	mg/L	3/2/2015	<0.5	2.4
Chloride	mg/L	4/7/2015	<0.5	2.5
Chloride	mg/L	5/4/2015	<0.5	2.3
Chloride	mg/L	5/20/2015	<0.5	2.3
Chloride	mg/L	6/1/2015	<0.5	2.3
Chloride	mg/L	7/6/2015	<0.5	2.4
Chloride	mg/L	8/10/2015	<0.5	2.4
Chloride	mg/L	8/18/2015	<0.5	2.5
Chloride	mg/L	9/8/2015	<0.5	3.1
Chloride	mg/L	10/13/2015	0.5	2.9
Chloride	mg/L	11/9/2015	0.5	3.1
Chloride	mg/L	11/25/2015	<0.5	2.9
Chloride	mg/L	12/7/2015	<0.5	2.7
Chlorine Free	mg/L	1/1/2015		0.83
Chlorine Free	mg/L	1/2/2015		0.78
Chlorine Free	mg/L	1/3/2015		0.84
Chlorine Free	mg/L	1/4/2015		0.83
Chlorine Free	mg/L	1/5/2015		0.66
Chlorine Free	mg/L	1/6/2015		0.77
Chlorine Free	mg/L	1/7/2015		0.82
Chlorine Free	mg/L	1/8/2015		0.85
Chlorine Free	mg/L	1/9/2015		0.78
Chlorine Free	mg/L	1/10/2015		0.71
Chlorine Free	mg/L	1/11/2015		0.75
Chlorine Free	mg/L	1/12/2015		0.62
Chlorine Free	mg/L	1/13/2015		0.7
Chlorine Free	mg/L	1/14/2015		0.7
Chlorine Free	mg/L	1/15/2015		0.63
Chlorine Free	mg/L	1/16/2015		0.78
Chlorine Free	mg/L	1/17/2015		0.75
Chlorine Free	mg/L	1/18/2015		0.73
Chlorine Free	mg/L	1/19/2015		0.79
Chlorine Free	mg/L	1/20/2015		0.74

Analysis - Seymour	Units	Date Sampled	Source	Treated
Chlorine Free	mg/L	1/21/2015		0.63
Chlorine Free	mg/L	1/22/2015		0.73
Chlorine Free	mg/L	1/23/2015		0.58
Chlorine Free	mg/L	1/24/2015		0.63
Chlorine Free	mg/L	1/25/2015		0.78
Chlorine Free	mg/L	1/26/2015		0.71
Chlorine Free	mg/L	1/27/2015		0.62
Chlorine Free	mg/L	1/28/2015		0.61
Chlorine Free	mg/L	1/29/2015		0.75
Chlorine Free	mg/L	1/30/2015		0.56
Chlorine Free	mg/L	1/31/2015		0.74
Chlorine Free	mg/L	2/1/2015		0.79
Chlorine Free	mg/L	2/2/2015		0.66
Chlorine Free	mg/L	2/3/2015		0.64
Chlorine Free	mg/L	2/4/2015		0.69
Chlorine Free	mg/L	2/5/2015		0.71
Chlorine Free	mg/L	2/6/2015		0.68
Chlorine Free	mg/L	2/7/2015		0.77
Chlorine Free	mg/L	2/8/2015		0.75
Chlorine Free	mg/L	2/9/2015		0.74
Chlorine Free	mg/L	2/10/2015		0.68
Chlorine Free	mg/L	2/11/2015		0.7
Chlorine Free	mg/L	2/12/2015		0.78
Chlorine Free	mg/L	2/13/2015		0.75
Chlorine Free	mg/L	2/14/2015		0.76
Chlorine Free	mg/L	2/15/2015		0.76
Chlorine Free	mg/L	2/16/2015		0.75
Chlorine Free	mg/L	2/17/2015		0.64
Chlorine Free	mg/L	2/18/2015		0.74
Chlorine Free	mg/L	2/19/2015		0.83
Chlorine Free	mg/L	2/20/2015		0.73
Chlorine Free	mg/L	2/21/2015		0.85
Chlorine Free	mg/L	2/22/2015		0.84
Chlorine Free	mg/L	2/23/2015		0.57
Chlorine Free	mg/L	2/24/2015		0.86
Chlorine Free	mg/L	2/25/2015		0.74
Chlorine Free	mg/L	2/26/2015		0.8
Chlorine Free	mg/L	2/27/2015		0.81
Chlorine Free	mg/L	2/28/2015		0.86
Chlorine Free	mg/L	3/1/2015		0.88
Chlorine Free	mg/L	3/2/2015		0.75
Chlorine Free	mg/L	3/3/2015		0.84
Chlorine Free	mg/L	3/4/2015		0.77
Chlorine Free	mg/L	3/5/2015		0.75
Chlorine Free	mg/L	3/6/2015		0.68

Analysis - Seymour	Units	Date Sampled	Source	Treated
Chlorine Free	mg/L	3/7/2015		0.9
Chlorine Free	mg/L	3/8/2015		0.84
Chlorine Free	mg/L	3/9/2015		0.73
Chlorine Free	mg/L	3/10/2015		0.78
Chlorine Free	mg/L	3/11/2015		0.75
Chlorine Free	mg/L	3/12/2015		0.58
Chlorine Free	mg/L	3/13/2015		0.82
Chlorine Free	mg/L	3/14/2015		0.86
Chlorine Free	mg/L	3/15/2015		0.85
Chlorine Free	mg/L	3/16/2015		0.95
Chlorine Free	mg/L	3/17/2015		0.54
Chlorine Free	mg/L	3/18/2015		0.72
Chlorine Free	mg/L	3/19/2015		0.6
Chlorine Free	mg/L	3/20/2015		0.69
Chlorine Free	mg/L	3/21/2015		0.84
Chlorine Free	mg/L	3/22/2015		0.88
Chlorine Free	mg/L	3/23/2015		0.69
Chlorine Free	mg/L	3/24/2015		0.75
Chlorine Free	mg/L	3/25/2015		0.66
Chlorine Free	mg/L	3/26/2015		0.82
Chlorine Free	mg/L	3/27/2015		0.74
Chlorine Free	mg/L	3/28/2015		0.84
Chlorine Free	mg/L	3/29/2015		0.79
Chlorine Free	mg/L	3/30/2015		0.71
Chlorine Free	mg/L	3/31/2015		0.78
Chlorine Free	mg/L	4/1/2015		0.82
Chlorine Free	mg/L	4/2/2015		0.84
Chlorine Free	mg/L	4/3/2015		0.83
Chlorine Free	mg/L	4/4/2015		0.88
Chlorine Free	mg/L	4/5/2015		0.84
Chlorine Free	mg/L	4/6/2015		0.83
Chlorine Free	mg/L	4/7/2015		0.79
Chlorine Free	mg/L	4/8/2015		0.79
Chlorine Free	mg/L	4/9/2015		0.61
Chlorine Free	mg/L	4/10/2015		0.69
Chlorine Free	mg/L	4/11/2015		0.85
Chlorine Free	mg/L	4/12/2015		0.79
Chlorine Free	mg/L	4/13/2015		0.76
Chlorine Free	mg/L	4/14/2015		0.65
Chlorine Free	mg/L	4/15/2015		0.84
Chlorine Free	mg/L	4/16/2015		0.61
Chlorine Free	mg/L	4/17/2015		0.8
Chlorine Free	mg/L	4/18/2015		0.82
Chlorine Free	mg/L	4/19/2015		0.86
Chlorine Free	mg/L	4/20/2015		0.72

Analysis - Seymour	Units	Date Sampled	Source	Treated
Chlorine Free	mg/L	4/21/2015		0.79
Chlorine Free	mg/L	4/22/2015		0.69
Chlorine Free	mg/L	4/23/2015		0.71
Chlorine Free	mg/L	4/24/2015		0.79
Chlorine Free	mg/L	4/25/2015		0.82
Chlorine Free	mg/L	4/26/2015		0.76
Chlorine Free	mg/L	4/27/2015		0.7
Chlorine Free	mg/L	4/28/2015		0.81
Chlorine Free	mg/L	4/29/2015		0.66
Chlorine Free	mg/L	4/30/2015		0.83
Chlorine Free	mg/L	5/1/2015		0.75
Chlorine Free	mg/L	5/2/2015		0.82
Chlorine Free	mg/L	5/3/2015		0.8
Chlorine Free	mg/L	5/4/2015		0.74
Chlorine Free	mg/L	5/5/2015		0.82
Chlorine Free	mg/L	5/6/2015		0.82
Chlorine Free	mg/L	5/7/2015		0.8
Chlorine Free	mg/L	5/8/2015		0.7
Chlorine Free	mg/L	5/9/2015		0.84
Chlorine Free	mg/L	5/10/2015		0.83
Chlorine Free	mg/L	5/11/2015		0.74
Chlorine Free	mg/L	5/12/2015		0.71
Chlorine Free	mg/L	5/13/2015		0.66
Chlorine Free	mg/L	5/14/2015		0.76
Chlorine Free	mg/L	5/15/2015		0.69
Chlorine Free	mg/L	5/16/2015		0.82
Chlorine Free	mg/L	5/17/2015		0.81
Chlorine Free	mg/L	5/18/2015		0.79
Chlorine Free	mg/L	5/19/2015		0.73
Chlorine Free	mg/L	5/20/2015		0.74
Chlorine Free	mg/L	5/21/2015		0.76
Chlorine Free	mg/L	5/22/2015		0.7
Chlorine Free	mg/L	5/23/2015		0.84
Chlorine Free	mg/L	5/24/2015		0.82
Chlorine Free	mg/L	5/25/2015		0.71
Chlorine Free	mg/L	5/26/2015		0.77
Chlorine Free	mg/L	5/27/2015		0.78
Chlorine Free	mg/L	5/28/2015		0.74
Chlorine Free	mg/L	5/29/2015		0.74
Chlorine Free	mg/L	5/30/2015		0.8
Chlorine Free	mg/L	5/31/2015		0.85
Chlorine Free	mg/L	6/1/2015		0.75
Chlorine Free	mg/L	6/2/2015		0.68
Chlorine Free	mg/L	6/3/2015		0.63
Chlorine Free	mg/L	6/4/2015		0.83

Analysis - Seymour	Units	Date Sampled	Source	Treated
Chlorine Free	mg/L	6/5/2015		0.68
Chlorine Free	mg/L	6/6/2015		0.8
Chlorine Free	mg/L	6/7/2015		0.8
Chlorine Free	mg/L	6/8/2015		0.71
Chlorine Free	mg/L	6/9/2015		0.81
Chlorine Free	mg/L	6/10/2015		0.71
Chlorine Free	mg/L	6/11/2015		0.75
Chlorine Free	mg/L	6/12/2015		0.81
Chlorine Free	mg/L	6/13/2015		0.81
Chlorine Free	mg/L	6/14/2015		0.83
Chlorine Free	mg/L	6/15/2015		0.7
Chlorine Free	mg/L	6/16/2015		0.66
Chlorine Free	mg/L	6/17/2015		0.82
Chlorine Free	mg/L	6/18/2015		0.73
Chlorine Free	mg/L	6/19/2015		0.75
Chlorine Free	mg/L	6/20/2015		0.83
Chlorine Free	mg/L	6/21/2015		0.84
Chlorine Free	mg/L	6/22/2015		0.72
Chlorine Free	mg/L	6/23/2015		0.75
Chlorine Free	mg/L	6/24/2015		0.68
Chlorine Free	mg/L	6/25/2015		0.77
Chlorine Free	mg/L	6/27/2015		0.86
Chlorine Free	mg/L	6/28/2015		0.88
Chlorine Free	mg/L	6/29/2015		0.76
Chlorine Free	mg/L	6/30/2015		0.76
Chlorine Free	mg/L	7/1/2015		0.84
Chlorine Free	mg/L	7/2/2015		0.91
Chlorine Free	mg/L	7/3/2015		0.82
Chlorine Free	mg/L	7/4/2015		0.86
Chlorine Free	mg/L	7/5/2015		0.84
Chlorine Free	mg/L	7/6/2015		0.8
Chlorine Free	mg/L	7/7/2015		0.47
Chlorine Free	mg/L	7/8/2015		0.79
Chlorine Free	mg/L	7/9/2015		0.59
Chlorine Free	mg/L	7/10/2015		0.76
Chlorine Free	mg/L	7/11/2015		0.81
Chlorine Free	mg/L	7/12/2015		0.84
Chlorine Free	mg/L	7/13/2015		0.74
Chlorine Free	mg/L	7/14/2015		0.63
Chlorine Free	mg/L	7/15/2015		0.81
Chlorine Free	mg/L	7/16/2015		0.77
Chlorine Free	mg/L	7/17/2015		0.79
Chlorine Free	mg/L	7/18/2015		0.8
Chlorine Free	mg/L	7/19/2015		0.82
Chlorine Free	mg/L	7/20/2015		0.79

Analysis - Seymour	Units	Date Sampled	Source	Treated
Chlorine Free	mg/L	7/21/2015		0.69
Chlorine Free	mg/L	7/22/2015		0.72
Chlorine Free	mg/L	7/23/2015		0.75
Chlorine Free	mg/L	7/24/2015		0.71
Chlorine Free	mg/L	7/25/2015		0.79
Chlorine Free	mg/L	7/26/2015		0.78
Chlorine Free	mg/L	7/27/2015		0.75
Chlorine Free	mg/L	7/28/2015		0.71
Chlorine Free	mg/L	7/29/2015		0.64
Chlorine Free	mg/L	7/30/2015		0.75
Chlorine Free	mg/L	7/31/2015		0.77
Chlorine Free	mg/L	8/1/2015		0.8
Chlorine Free	mg/L	8/2/2015		0.84
Chlorine Free	mg/L	8/3/2015		0.86
Chlorine Free	mg/L	8/4/2015		0.69
Chlorine Free	mg/L	8/5/2015		0.62
Chlorine Free	mg/L	8/6/2015		0.74
Chlorine Free	mg/L	8/7/2015		0.74
Chlorine Free	mg/L	8/8/2015		0.84
Chlorine Free	mg/L	8/9/2015		0.72
Chlorine Free	mg/L	8/10/2015		0.67
Chlorine Free	mg/L	8/11/2015		0.71
Chlorine Free	mg/L	8/12/2015		0.7
Chlorine Free	mg/L	8/13/2015		0.78
Chlorine Free	mg/L	8/14/2015		0.75
Chlorine Free	mg/L	8/15/2015		0.76
Chlorine Free	mg/L	8/16/2015		0.77
Chlorine Free	mg/L	8/17/2015		0.75
Chlorine Free	mg/L	8/18/2015		0.82
Chlorine Free	mg/L	8/19/2015		0.73
Chlorine Free	mg/L	8/20/2015		0.74
Chlorine Free	mg/L	8/21/2015		0.68
Chlorine Free	mg/L	8/22/2015		0.86
Chlorine Free	mg/L	8/23/2015		0.83
Chlorine Free	mg/L	8/24/2015		0.63
Chlorine Free	mg/L	8/25/2015		0.55
Chlorine Free	mg/L	8/26/2015		0.7
Chlorine Free	mg/L	8/27/2015		0.62
Chlorine Free	mg/L	8/28/2015		0.69
Chlorine Free	mg/L	8/29/2015		0.78
Chlorine Free	mg/L	8/30/2015		0.74
Chlorine Free	mg/L	8/31/2015		0.77
Chlorine Free	mg/L	9/1/2015		0.77
Chlorine Free	mg/L	9/2/2015		0.74
Chlorine Free	mg/L	9/3/2015		0.73

Analysis - Seymour	Units	Date Sampled	Source	Treated
Chlorine Free	mg/L	9/4/2015		0.77
Chlorine Free	mg/L	9/5/2015		0.78
Chlorine Free	mg/L	9/6/2015		0.81
Chlorine Free	mg/L	9/7/2015		0.81
Chlorine Free	mg/L	9/8/2015		0.76
Chlorine Free	mg/L	9/9/2015		0.69
Chlorine Free	mg/L	9/10/2015		0.86
Chlorine Free	mg/L	9/11/2015		0.78
Chlorine Free	mg/L	9/12/2015		0.81
Chlorine Free	mg/L	9/13/2015		0.81
Chlorine Free	mg/L	9/14/2015		0.88
Chlorine Free	mg/L	9/15/2015		0.78
Chlorine Free	mg/L	9/16/2015		0.67
Chlorine Free	mg/L	9/17/2015		0.63
Chlorine Free	mg/L	9/18/2015		0.79
Chlorine Free	mg/L	9/19/2015		0.79
Chlorine Free	mg/L	9/20/2015		0.77
Chlorine Free	mg/L	9/21/2015		0.74
Chlorine Free	mg/L	9/22/2015		0.75
Chlorine Free	mg/L	9/23/2015		0.64
Chlorine Free	mg/L	9/24/2015		0.8
Chlorine Free	mg/L	9/25/2015		0.65
Chlorine Free	mg/L	9/26/2015		0.78
Chlorine Free	mg/L	9/27/2015		0.8
Chlorine Free	mg/L	9/28/2015		0.75
Chlorine Free	mg/L	9/29/2015		0.72
Chlorine Free	mg/L	9/30/2015		0.79
Chlorine Free	mg/L	10/1/2015		0.78
Chlorine Free	mg/L	10/2/2015		0.72
Chlorine Free	mg/L	10/3/2015		0.89
Chlorine Free	mg/L	10/4/2015		0.81
Chlorine Free	mg/L	10/5/2015		0.77
Chlorine Free	mg/L	10/6/2015		0.78
Chlorine Free	mg/L	10/7/2015		0.78
Chlorine Free	mg/L	10/8/2015		0.77
Chlorine Free	mg/L	10/9/2015		0.71
Chlorine Free	mg/L	10/10/2015		0.77
Chlorine Free	mg/L	10/11/2015		0.73
Chlorine Free	mg/L	10/12/2015		0.78
Chlorine Free	mg/L	10/13/2015		0.74
Chlorine Free	mg/L	10/14/2015		0.72
Chlorine Free	mg/L	10/15/2015		0.71
Chlorine Free	mg/L	10/16/2015		0.69
Chlorine Free	mg/L	10/17/2015		0.8
Chlorine Free	mg/L	10/18/2015		0.75

Analysis - Seymour	Units	Date Sampled	Source	Treated
Chlorine Free	mg/L	10/19/2015		0.67
Chlorine Free	mg/L	10/20/2015		0.71
Chlorine Free	mg/L	10/21/2015		0.78
Chlorine Free	mg/L	10/22/2015		0.71
Chlorine Free	mg/L	10/23/2015		0.66
Chlorine Free	mg/L	10/24/2015		0.79
Chlorine Free	mg/L	10/25/2015		0.8
Chlorine Free	mg/L	10/26/2015		0.77
Chlorine Free	mg/L	10/27/2015		0.77
Chlorine Free	mg/L	10/28/2015		0.61
Chlorine Free	mg/L	10/29/2015		0.71
Chlorine Free	mg/L	10/30/2015		0.74
Chlorine Free	mg/L	10/31/2015		0.81
Chlorine Free	mg/L	11/1/2015		0.83
Chlorine Free	mg/L	11/2/2015		0.78
Chlorine Free	mg/L	11/3/2015		0.73
Chlorine Free	mg/L	11/4/2015		0.71
Chlorine Free	mg/L	11/5/2015		0.76
Chlorine Free	mg/L	11/6/2015		0.72
Chlorine Free	mg/L	11/7/2015		0.79
Chlorine Free	mg/L	11/8/2015		0.8
Chlorine Free	mg/L	11/9/2015		0.65
Chlorine Free	mg/L	11/10/2015		0.65
Chlorine Free	mg/L	11/11/2015		0.81
Chlorine Free	mg/L	11/12/2015		0.61
Chlorine Free	mg/L	11/13/2015		0.85
Chlorine Free	mg/L	11/14/2015		0.83
Chlorine Free	mg/L	11/15/2015		0.82
Chlorine Free	mg/L	11/16/2015		0.74
Chlorine Free	mg/L	11/17/2015		0.77
Chlorine Free	mg/L	11/18/2015		0.61
Chlorine Free	mg/L	11/19/2015		0.64
Chlorine Free	mg/L	11/20/2015		0.72
Chlorine Free	mg/L	11/21/2015		0.83
Chlorine Free	mg/L	11/22/2015		0.81
Chlorine Free	mg/L	11/23/2015		0.71
Chlorine Free	mg/L	11/24/2015		0.62
Chlorine Free	mg/L	11/25/2015		0.64
Chlorine Free	mg/L	11/26/2015		0.77
Chlorine Free	mg/L	11/27/2015		0.73
Chlorine Free	mg/L	11/28/2015		0.86
Chlorine Free	mg/L	11/29/2015		0.85
Chlorine Free	mg/L	11/30/2015		0.53
Chlorine Free	mg/L	12/1/2015		0.74
Chlorine Free	mg/L	12/2/2015		0.78

Analysis - Seymour	Units	Date Sampled	Source	Treated
Chlorine Free	mg/L	12/3/2015		0.77
Chlorine Free	mg/L	12/4/2015		0.71
Chlorine Free	mg/L	12/5/2015		0.82
Chlorine Free	mg/L	12/6/2015		0.81
Chlorine Free	mg/L	12/7/2015		0.81
Chlorine Free	mg/L	12/8/2015		0.8
Chlorine Free	mg/L	12/9/2015		0.83
Chlorine Free	mg/L	12/10/2015		0.8
Chlorine Free	mg/L	12/11/2015		0.74
Chlorine Free	mg/L	12/12/2015		0.86
Chlorine Free	mg/L	12/13/2015		0.85
Chlorine Free	mg/L	12/14/2015		0.68
Chlorine Free	mg/L	12/15/2015		0.74
Chlorine Free	mg/L	12/16/2015		0.74
Chlorine Free	mg/L	12/17/2015		0.72
Chlorine Free	mg/L	12/18/2015		0.71
Chlorine Free	mg/L	12/19/2015		0.88
Chlorine Free	mg/L	12/20/2015		0.82
Chlorine Free	mg/L	12/21/2015		0.69
Chlorine Free	mg/L	12/22/2015		0.72
Chlorine Free	mg/L	12/23/2015		0.58
Chlorine Free	mg/L	12/24/2015		0.79
Chlorine Free	mg/L	12/26/2015		0.71
Chlorine Free	mg/L	12/27/2015		0.73
Chlorine Free	mg/L	12/28/2015		0.81
Chlorine Free	mg/L	12/29/2015		0.77
Chlorine Free	mg/L	12/30/2015		0.81
Chlorine Free	mg/L	12/31/2015		0.78
Chlorine Total	mg/L	1/1/2015		0.99
Chlorine Total	mg/L	1/2/2015		0.84
Chlorine Total	mg/L	1/3/2015		0.89
Chlorine Total	mg/L	1/4/2015		0.86
Chlorine Total	mg/L	1/5/2015		0.66
Chlorine Total	mg/L	1/6/2015		0.81
Chlorine Total	mg/L	1/7/2015		0.85
Chlorine Total	mg/L	1/8/2015		0.89
Chlorine Total	mg/L	1/9/2015		0.82
Chlorine Total	mg/L	1/10/2015		0.77
Chlorine Total	mg/L	1/11/2015		0.8
Chlorine Total	mg/L	1/12/2015		0.76
Chlorine Total	mg/L	1/13/2015		0.8
Chlorine Total	mg/L	1/14/2015		0.74
Chlorine Total	mg/L	1/15/2015		0.67
Chlorine Total	mg/L	1/16/2015		0.78
Chlorine Total	mg/L	1/17/2015		0.8

Analysis - Seymour	Units	Date Sampled	Source	Treated
Chlorine Total	mg/L	1/18/2015		0.79
Chlorine Total	mg/L	1/19/2015		0.83
Chlorine Total	mg/L	1/20/2015		0.8
Chlorine Total	mg/L	1/21/2015		0.69
Chlorine Total	mg/L	1/22/2015		0.75
Chlorine Total	mg/L	1/23/2015		0.63
Chlorine Total	mg/L	1/24/2015		0.67
Chlorine Total	mg/L	1/25/2015		0.79
Chlorine Total	mg/L	1/26/2015		0.71
Chlorine Total	mg/L	1/27/2015		0.67
Chlorine Total	mg/L	1/28/2015		0.71
Chlorine Total	mg/L	1/29/2015		0.78
Chlorine Total	mg/L	1/30/2015		0.61
Chlorine Total	mg/L	1/31/2015		0.79
Chlorine Total	mg/L	2/1/2015		0.81
Chlorine Total	mg/L	2/2/2015		0.7
Chlorine Total	mg/L	2/3/2015		0.68
Chlorine Total	mg/L	2/4/2015		0.77
Chlorine Total	mg/L	2/5/2015		0.8
Chlorine Total	mg/L	2/6/2015		0.78
Chlorine Total	mg/L	2/7/2015		0.8
Chlorine Total	mg/L	2/8/2015		0.8
Chlorine Total	mg/L	2/9/2015		0.79
Chlorine Total	mg/L	2/10/2015		0.72
Chlorine Total	mg/L	2/11/2015		0.74
Chlorine Total	mg/L	2/12/2015		0.78
Chlorine Total	mg/L	2/13/2015		0.79
Chlorine Total	mg/L	2/14/2015		0.82
Chlorine Total	mg/L	2/15/2015		0.81
Chlorine Total	mg/L	2/16/2015		0.8
Chlorine Total	mg/L	2/17/2015		0.67
Chlorine Total	mg/L	2/18/2015		0.81
Chlorine Total	mg/L	2/19/2015		0.88
Chlorine Total	mg/L	2/20/2015		0.76
Chlorine Total	mg/L	2/21/2015		0.89
Chlorine Total	mg/L	2/22/2015		0.96
Chlorine Total	mg/L	2/23/2015		0.61
Chlorine Total	mg/L	2/24/2015		0.9
Chlorine Total	mg/L	2/25/2015		0.77
Chlorine Total	mg/L	2/26/2015		0.84
Chlorine Total	mg/L	2/27/2015		0.84
Chlorine Total	mg/L	2/28/2015		0.88
Chlorine Total	mg/L	3/1/2015		0.93
Chlorine Total	mg/L	3/2/2015		0.8
Chlorine Total	mg/L	3/3/2015		0.91

Analysis - Seymour	Units	Date Sampled	Source	Treated
Chlorine Total	mg/L	3/4/2015		0.81
Chlorine Total	mg/L	3/5/2015		0.79
Chlorine Total	mg/L	3/6/2015		0.73
Chlorine Total	mg/L	3/7/2015		0.92
Chlorine Total	mg/L	3/8/2015		0.9
Chlorine Total	mg/L	3/9/2015		0.79
Chlorine Total	mg/L	3/10/2015		0.82
Chlorine Total	mg/L	3/11/2015		0.79
Chlorine Total	mg/L	3/12/2015		0.61
Chlorine Total	mg/L	3/13/2015		0.9
Chlorine Total	mg/L	3/14/2015		0.92
Chlorine Total	mg/L	3/15/2015		0.91
Chlorine Total	mg/L	3/16/2015		0.98
Chlorine Total	mg/L	3/17/2015		0.57
Chlorine Total	mg/L	3/18/2015		0.75
Chlorine Total	mg/L	3/19/2015		0.65
Chlorine Total	mg/L	3/20/2015		0.74
Chlorine Total	mg/L	3/21/2015		0.91
Chlorine Total	mg/L	3/22/2015		0.91
Chlorine Total	mg/L	3/23/2015		0.73
Chlorine Total	mg/L	3/24/2015		0.81
Chlorine Total	mg/L	3/25/2015		0.7
Chlorine Total	mg/L	3/26/2015		0.88
Chlorine Total	mg/L	3/27/2015		0.76
Chlorine Total	mg/L	3/28/2015		0.86
Chlorine Total	mg/L	3/29/2015		0.86
Chlorine Total	mg/L	3/30/2015		0.71
Chlorine Total	mg/L	3/31/2015		0.82
Chlorine Total	mg/L	4/1/2015		0.83
Chlorine Total	mg/L	4/2/2015		0.87
Chlorine Total	mg/L	4/3/2015		0.87
Chlorine Total	mg/L	4/4/2015		0.92
Chlorine Total	mg/L	4/5/2015		0.9
Chlorine Total	mg/L	4/6/2015		0.87
Chlorine Total	mg/L	4/7/2015		0.79
Chlorine Total	mg/L	4/8/2015		0.86
Chlorine Total	mg/L	4/9/2015		0.73
Chlorine Total	mg/L	4/10/2015		0.73
Chlorine Total	mg/L	4/11/2015		0.89
Chlorine Total	mg/L	4/12/2015		0.86
Chlorine Total	mg/L	4/13/2015		0.88
Chlorine Total	mg/L	4/14/2015		0.68
Chlorine Total	mg/L	4/15/2015		0.89
Chlorine Total	mg/L	4/16/2015		0.64
Chlorine Total	mg/L	4/17/2015		0.9

Analysis - Seymour	Units	Date Sampled	Source	Treated
Chlorine Total	mg/L	4/18/2015		0.87
Chlorine Total	mg/L	4/19/2015		0.94
Chlorine Total	mg/L	4/20/2015		0.91
Chlorine Total	mg/L	4/21/2015		0.84
Chlorine Total	mg/L	4/22/2015		0.73
Chlorine Total	mg/L	4/23/2015		0.73
Chlorine Total	mg/L	4/24/2015		0.82
Chlorine Total	mg/L	4/25/2015		0.89
Chlorine Total	mg/L	4/26/2015		0.87
Chlorine Total	mg/L	4/27/2015		0.73
Chlorine Total	mg/L	4/28/2015		0.87
Chlorine Total	mg/L	4/29/2015		0.69
Chlorine Total	mg/L	4/30/2015		0.86
Chlorine Total	mg/L	5/1/2015		0.77
Chlorine Total	mg/L	5/2/2015		0.87
Chlorine Total	mg/L	5/3/2015		0.88
Chlorine Total	mg/L	5/4/2015		0.86
Chlorine Total	mg/L	5/5/2015		0.9
Chlorine Total	mg/L	5/6/2015		0.87
Chlorine Total	mg/L	5/7/2015		0.85
Chlorine Total	mg/L	5/8/2015		0.72
Chlorine Total	mg/L	5/9/2015		0.89
Chlorine Total	mg/L	5/10/2015		0.9
Chlorine Total	mg/L	5/11/2015		0.85
Chlorine Total	mg/L	5/12/2015		0.73
Chlorine Total	mg/L	5/13/2015		0.68
Chlorine Total	mg/L	5/14/2015		0.84
Chlorine Total	mg/L	5/15/2015		0.72
Chlorine Total	mg/L	5/16/2015		0.89
Chlorine Total	mg/L	5/17/2015		0.87
Chlorine Total	mg/L	5/18/2015		0.82
Chlorine Total	mg/L	5/19/2015		0.76
Chlorine Total	mg/L	5/20/2015		0.86
Chlorine Total	mg/L	5/21/2015		0.77
Chlorine Total	mg/L	5/22/2015		0.81
Chlorine Total	mg/L	5/23/2015		0.86
Chlorine Total	mg/L	5/24/2015		0.88
Chlorine Total	mg/L	5/25/2015	11	0.88
Chlorine Total	mg/L	5/26/2015		0.87
Chlorine Total	mg/L	5/27/2015		0.87
Chlorine Total	mg/L	5/28/2015		0.75
Chlorine Total	mg/L	5/29/2015		0.81
Chlorine Total	mg/L	5/30/2015		0.9
Chlorine Total	mg/L	5/31/2015		0.89
Chlorine Total	mg/L	6/1/2015		0.89

Analysis - Seymour	Units	Date Sampled	Source	Treated
Chlorine Total	mg/L	6/2/2015		0.73
Chlorine Total	mg/L	6/3/2015		0.66
Chlorine Total	mg/L	6/4/2015		0.86
Chlorine Total	mg/L	6/5/2015		0.71
Chlorine Total	mg/L	6/6/2015		0.93
Chlorine Total	mg/L	6/7/2015		0.89
Chlorine Total	mg/L	6/8/2015		0.74
Chlorine Total	mg/L	6/9/2015		0.89
Chlorine Total	mg/L	6/10/2015		0.73
Chlorine Total	mg/L	6/11/2015		0.78
Chlorine Total	mg/L	6/12/2015		0.87
Chlorine Total	mg/L	6/13/2015		0.91
Chlorine Total	mg/L	6/14/2015		0.9
Chlorine Total	mg/L	6/15/2015		0.75
Chlorine Total	mg/L	6/16/2015		0.68
Chlorine Total	mg/L	6/17/2015		0.9
Chlorine Total	mg/L	6/18/2015		LA
Chlorine Total	mg/L	6/19/2015		0.78
Chlorine Total	mg/L	6/20/2015		0.92
Chlorine Total	mg/L	6/21/2015		0.86
Chlorine Total	mg/L	6/22/2015		0.78
Chlorine Total	mg/L	6/23/2015		0.87
Chlorine Total	mg/L	6/24/2015		0.73
Chlorine Total	mg/L	6/25/2015		0.82
Chlorine Total	mg/L	6/27/2015		0.86
Chlorine Total	mg/L	6/28/2015		0.93
Chlorine Total	mg/L	6/29/2015		0.78
Chlorine Total	mg/L	6/30/2015		0.82
Chlorine Total	mg/L	7/1/2015		0.92
Chlorine Total	mg/L	7/2/2015		0.91
Chlorine Total	mg/L	7/3/2015		0.85
Chlorine Total	mg/L	7/4/2015		0.9
Chlorine Total	mg/L	7/5/2015		0.89
Chlorine Total	mg/L	7/6/2015		0.82
Chlorine Total	mg/L	7/7/2015		0.49
Chlorine Total	mg/L	7/8/2015		0.87
Chlorine Total	mg/L	7/9/2015		0.63
Chlorine Total	mg/L	7/10/2015		0.87
Chlorine Total	mg/L	7/11/2015		0.86
Chlorine Total	mg/L	7/12/2015		0.87
Chlorine Total	mg/L	7/13/2015		0.91
Chlorine Total	mg/L	7/14/2015		0.67
Chlorine Total	mg/L	7/15/2015		0.81
Chlorine Total	mg/L	7/16/2015		0.89
Chlorine Total	mg/L	7/17/2015		0.83

Analysis - Seymour	Units	Date Sampled	Source	Treated
Chlorine Total	mg/L	7/18/2015		0.87
Chlorine Total	mg/L	7/19/2015		0.87
Chlorine Total	mg/L	7/20/2015		0.91
Chlorine Total	mg/L	7/21/2015		0.76
Chlorine Total	mg/L	7/22/2015		1
Chlorine Total	mg/L	7/23/2015		0.82
Chlorine Total	mg/L	7/24/2015		0.86
Chlorine Total	mg/L	7/25/2015		0.88
Chlorine Total	mg/L	7/26/2015		0.87
Chlorine Total	mg/L	7/27/2015		0.77
Chlorine Total	mg/L	7/28/2015		0.82
Chlorine Total	mg/L	7/29/2015		0.67
Chlorine Total	mg/L	7/30/2015		0.83
Chlorine Total	mg/L	7/31/2015		0.93
Chlorine Total	mg/L	8/1/2015		0.82
Chlorine Total	mg/L	8/2/2015		0.86
Chlorine Total	mg/L	8/3/2015		0.87
Chlorine Total	mg/L	8/4/2015		0.8
Chlorine Total	mg/L	8/5/2015		0.65
Chlorine Total	mg/L	8/6/2015		0.82
Chlorine Total	mg/L	8/7/2015		0.79
Chlorine Total	mg/L	8/8/2015		0.86
Chlorine Total	mg/L	8/9/2015		0.79
Chlorine Total	mg/L	8/10/2015		0.78
Chlorine Total	mg/L	8/11/2015		0.83
Chlorine Total	mg/L	8/12/2015		0.84
Chlorine Total	mg/L	8/13/2015		0.84
Chlorine Total	mg/L	8/14/2015		0.83
Chlorine Total	mg/L	8/15/2015		0.83
Chlorine Total	mg/L	8/16/2015		0.8
Chlorine Total	mg/L	8/17/2015		0.91
Chlorine Total	mg/L	8/18/2015		0.84
Chlorine Total	mg/L	8/19/2015		0.77
Chlorine Total	mg/L	8/20/2015		0.8
Chlorine Total	mg/L	8/21/2015		0.75
Chlorine Total	mg/L	8/22/2015		0.87
Chlorine Total	mg/L	8/23/2015		0.89
Chlorine Total	mg/L	8/24/2015		0.63
Chlorine Total	mg/L	8/25/2015		0.58
Chlorine Total	mg/L	8/26/2015		0.72
Chlorine Total	mg/L	8/27/2015		0.7
Chlorine Total	mg/L	8/28/2015		LA
Chlorine Total	mg/L	8/29/2015		0.83
Chlorine Total	mg/L	8/30/2015		0.8
Chlorine Total	mg/L	8/31/2015		0.81

Analysis - Seymour	Units	Date Sampled	Source	Treated
Chlorine Total	mg/L	9/1/2015		0.85
Chlorine Total	mg/L	9/2/2015		0.79
Chlorine Total	mg/L	9/3/2015		0.79
Chlorine Total	mg/L	9/4/2015		0.8
Chlorine Total	mg/L	9/5/2015		0.83
Chlorine Total	mg/L	9/6/2015		0.86
Chlorine Total	mg/L	9/7/2015		0.85
Chlorine Total	mg/L	9/8/2015		0.78
Chlorine Total	mg/L	9/9/2015		0.77
Chlorine Total	mg/L	9/10/2015		0.89
Chlorine Total	mg/L	9/11/2015		0.8
Chlorine Total	mg/L	9/12/2015		0.88
Chlorine Total	mg/L	9/13/2015		0.85
Chlorine Total	mg/L	9/14/2015		0.89
Chlorine Total	mg/L	9/15/2015		0.83
Chlorine Total	mg/L	9/16/2015		0.78
Chlorine Total	mg/L	9/17/2015		0.76
Chlorine Total	mg/L	9/18/2015		0.85
Chlorine Total	mg/L	9/19/2015		0.86
Chlorine Total	mg/L	9/20/2015		0.83
Chlorine Total	mg/L	9/21/2015		0.82
Chlorine Total	mg/L	9/22/2015		0.8
Chlorine Total	mg/L	9/23/2015		0.71
Chlorine Total	mg/L	9/24/2015		0.87
Chlorine Total	mg/L	9/25/2015		0.73
Chlorine Total	mg/L	9/26/2015		0.84
Chlorine Total	mg/L	9/27/2015		0.82
Chlorine Total	mg/L	9/28/2015		0.8
Chlorine Total	mg/L	9/29/2015		0.76
Chlorine Total	mg/L	9/30/2015		0.82
Chlorine Total	mg/L	10/1/2015		0.85
Chlorine Total	mg/L	10/2/2015		0.77
Chlorine Total	mg/L	10/3/2015		LA
Chlorine Total	mg/L	10/4/2015		0.87
Chlorine Total	mg/L	10/5/2015		1.1
Chlorine Total	mg/L	10/6/2015		0.81
Chlorine Total	mg/L	10/7/2015		0.84
Chlorine Total	mg/L	10/8/2015		0.82
Chlorine Total	mg/L	10/9/2015		0.75
Chlorine Total	mg/L	10/10/2015		0.82
Chlorine Total	mg/L	10/11/2015		0.81
Chlorine Total	mg/L	10/12/2015		0.85
Chlorine Total	mg/L	10/13/2015		0.81
Chlorine Total	mg/L	10/14/2015		0.8
Chlorine Total	mg/L	10/15/2015		0.74

Analysis - Seymour	Units	Date Sampled	Source	Treated
Chlorine Total	mg/L	10/16/2015		0.72
Chlorine Total	mg/L	10/17/2015		0.87
Chlorine Total	mg/L	10/18/2015		0.81
Chlorine Total	mg/L	10/19/2015		0.8
Chlorine Total	mg/L	10/20/2015		0.82
Chlorine Total	mg/L	10/21/2015		0.83
Chlorine Total	mg/L	10/22/2015		0.76
Chlorine Total	mg/L	10/23/2015		0.75
Chlorine Total	mg/L	10/24/2015		0.83
Chlorine Total	mg/L	10/25/2015		0.85
Chlorine Total	mg/L	10/26/2015		0.88
Chlorine Total	mg/L	10/27/2015		0.86
Chlorine Total	mg/L	10/28/2015		0.65
Chlorine Total	mg/L	10/29/2015		0.77
Chlorine Total	mg/L	10/30/2015		0.8
Chlorine Total	mg/L	10/31/2015		0.88
Chlorine Total	mg/L	11/1/2015		0.87
Chlorine Total	mg/L	11/2/2015		0.87
Chlorine Total	mg/L	11/3/2015		0.75
Chlorine Total	mg/L	11/4/2015		0.78
Chlorine Total	mg/L	11/5/2015		0.81
Chlorine Total	mg/L	11/6/2015		0.76
Chlorine Total	mg/L	11/7/2015		0.86
Chlorine Total	mg/L	11/8/2015		0.86
Chlorine Total	mg/L	11/9/2015		0.74
Chlorine Total	mg/L	11/10/2015		0.73
Chlorine Total	mg/L	11/11/2015		0.85
Chlorine Total	mg/L	11/12/2015		0.64
Chlorine Total	mg/L	11/13/2015		0.87
Chlorine Total	mg/L	11/14/2015		0.86
Chlorine Total	mg/L	11/15/2015		0.85
Chlorine Total	mg/L	11/16/2015		0.74
Chlorine Total	mg/L	11/17/2015		0.78
Chlorine Total	mg/L	11/18/2015		0.63
Chlorine Total	mg/L	11/19/2015		0.74
Chlorine Total	mg/L	11/20/2015		0.79
Chlorine Total	mg/L	11/21/2015		0.86
Chlorine Total	mg/L	11/22/2015		0.83
Chlorine Total	mg/L	11/23/2015		0.77
Chlorine Total	mg/L	11/24/2015		0.64
Chlorine Total	mg/L	11/25/2015		0.68
Chlorine Total	mg/L	11/26/2015		0.81
Chlorine Total	mg/L	11/27/2015		0.79
Chlorine Total	mg/L	11/28/2015		0.88
Chlorine Total	mg/L	11/29/2015		0.87

Analysis - Seymour	Units	Date Sampled	Source	Treated
Chlorine Total	mg/L	11/30/2015		0.55
Chlorine Total	mg/L	12/1/2015		0.79
Chlorine Total	mg/L	12/2/2015	4.9	0.83
Chlorine Total	mg/L	12/3/2015		0.81
Chlorine Total	mg/L	12/4/2015		LA
Chlorine Total	mg/L	12/5/2015		0.86
Chlorine Total	mg/L	12/6/2015		0.83
Chlorine Total	mg/L	12/7/2015		0.84
Chlorine Total	mg/L	12/8/2015		0.86
Chlorine Total	mg/L	12/9/2015		0.87
Chlorine Total	mg/L	12/10/2015		0.83
Chlorine Total	mg/L	12/11/2015		0.8
Chlorine Total	mg/L	12/12/2015		0.87
Chlorine Total	mg/L	12/13/2015		0.86
Chlorine Total	mg/L	12/14/2015		0.87
Chlorine Total	mg/L	12/15/2015		0.86
Chlorine Total	mg/L	12/16/2015		0.76
Chlorine Total	mg/L	12/17/2015		0.79
Chlorine Total	mg/L	12/18/2015		0.75
Chlorine Total	mg/L	12/19/2015		0.89
Chlorine Total	mg/L	12/20/2015		0.88
Chlorine Total	mg/L	12/21/2015		0.72
Chlorine Total	mg/L	12/22/2015		0.87
Chlorine Total	mg/L	12/23/2015		0.61
Chlorine Total	mg/L	12/24/2015		0.81
Chlorine Total	mg/L	12/26/2015		0.79
Chlorine Total	mg/L	12/27/2015		0.79
Chlorine Total	mg/L	12/28/2015		0.83
Chlorine Total	mg/L	12/29/2015		0.8
Chlorine Total	mg/L	12/30/2015		0.83
Chlorine Total	mg/L	12/31/2015		0.83
Chlorodibromomethane	ppb	2/17/2015	<1	<1
Chlorodibromomethane	ppb	5/20/2015	<1	<1
Chlorodibromomethane	ppb	8/18/2015	<1	<1
Chlorodibromomethane	ppb	11/25/2015	<1	<1
Chloroform	ppb	2/17/2015	<1	17
Chloroform	ppb	5/20/2015	<1	16
Chloroform	ppb	8/18/2015	<1	20
Chloroform	ppb	11/25/2015	<1	15
Chromium Total	µg/L	2/17/2015	0.06	<0.05
Chromium Total	µg/L	5/5/2015	<0.05	<0.05
Chromium Total	µg/L	6/1/2015	<0.05	<0.05
Chromium Total	µg/L	10/20/2015	0.12	0.17
Chromium Total	µg/L	12/7/2015	0.15	<0.05
Cobalt Total	µg/L	2/17/2015	<0.5	<0.5

Analysis - Seymour	Units	Date Sampled	Source	Treated
Cobalt Total	µg/L	5/5/2015	<0.5	<0.5
Cobalt Total	µg/L	10/20/2015	<0.5	<0.5
Color - Apparent	ACU	1/5/2015	23	<1
Color - Apparent	ACU	1/12/2015	20	<1
Color - Apparent	ACU	1/19/2015	20	<1
Color - Apparent	ACU	1/26/2015	21	<1
Color - Apparent	ACU	2/2/2015	24	<1
Color - Apparent	ACU	2/10/2015	30	<1
Color - Apparent	ACU	2/16/2015	30	<1
Color - Apparent	ACU	2/23/2015	24	<1
Color - Apparent	ACU	3/2/2015	23	<1
Color - Apparent	ACU	3/9/2015	20	<1
Color - Apparent	ACU	3/16/2015	21	<1
Color - Apparent	ACU	3/23/2015	23	<1
Color - Apparent	ACU	3/30/2015	22	<1
Color - Apparent	ACU	4/7/2015	24	<1
Color - Apparent	ACU	4/13/2015	20	<1
Color - Apparent	ACU	4/20/2015	19	<1
Color - Apparent	ACU	4/27/2015	18	<1
Color - Apparent	ACU	5/4/2015	15	<1
Color - Apparent	ACU	5/11/2015	17	<1
Color - Apparent	ACU	5/19/2015	16	1
Color - Apparent	ACU	5/25/2015	22	<1
Color - Apparent	ACU	6/1/2015	17	<1
Color - Apparent	ACU	6/8/2015	17	<1
Color - Apparent	ACU	6/15/2015	17	<1
Color - Apparent	ACU	6/22/2015	17	<1
Color - Apparent	ACU	6/29/2015	21	<1
Color - Apparent	ACU	7/6/2015	21	<1
Color - Apparent	ACU	7/13/2015	20	1
Color - Apparent	ACU	7/20/2015	25	2
Color - Apparent	ACU	7/27/2015	36	4
Color - Apparent	ACU	8/4/2015	25	5
Color - Apparent	ACU	8/10/2015	28	6
Color - Apparent	ACU	8/17/2015	23	6
Color - Apparent	ACU	8/24/2015	24	6
Color - Apparent	ACU	8/31/2015	36	5
Color - Apparent	ACU	9/8/2015	56	5
Color - Apparent	ACU	9/14/2015	52	<1
Color - Apparent	ACU	9/21/2015	26	3
Color - Apparent	ACU	9/28/2015	36	1
Color - Apparent	ACU	10/5/2015	32	3
Color - Apparent	ACU	10/13/2015	36	<1
Color - Apparent	ACU	10/19/2015	36	<1
Color - Apparent	ACU	10/26/2015	30	<1

Analysis - Seymour	Units	Date Sampled	Source	Treated
Color - Apparent	ACU	11/2/2015	28	<1
Color - Apparent	ACU	11/9/2015	25	1
Color - Apparent	ACU	11/16/2015	28	<1
Color - Apparent	ACU	11/23/2015	25	<1
Color - Apparent	ACU	11/30/2015	24	<1
Color - Apparent	ACU	12/7/2015	36	<1
Color - Apparent	ACU	12/14/2015	30	<1
Color - Apparent	ACU	12/21/2015	26	<1
Color - True	TCU	1/5/2015	14	<1
Color - True	TCU	1/12/2015	12	<1
Color - True	TCU	1/19/2015	12	<1
Color - True	TCU	1/26/2015	19	<1
Color - True	TCU	2/2/2015	15	<1
Color - True	TCU	2/10/2015	20	<1
Color - True	TCU	2/16/2015	17	<2
Color - True	TCU	2/23/2015	14	<2
Color - True	TCU	3/2/2015	15	<1
Color - True	TCU	3/9/2015	13	<1
Color - True	TCU	3/16/2015	12	<1
Color - True	TCU	3/23/2015	14	<1
Color - True	TCU	3/30/2015	16	<1
Color - True	TCU	4/7/2015	15	<1
Color - True	TCU	4/13/2015	14	<1
Color - True	TCU	4/20/2015	13	<1
Color - True	TCU	4/27/2015	12	<1
Color - True	TCU	5/4/2015	10	<1
Color - True	TCU	5/11/2015	11	<1
Color - True	TCU	5/19/2015	11	<1
Color - True	TCU	5/25/2015	10	<1
Color - True	TCU	6/1/2015	10	<1
Color - True	TCU	6/8/2015	9	<1
Color - True	TCU	6/15/2015	9	<1
Color - True	TCU	6/22/2015	9	<1
Color - True	TCU	6/29/2015	10	<1
Color - True	TCU	7/6/2015	9	<1
Color - True	TCU	7/13/2015	10	<1
Color - True	TCU	7/20/2015	12	<1
Color - True	TCU	7/27/2015	12	<1
Color - True	TCU	8/4/2015	13	<1
Color - True	TCU	8/10/2015	13	<1
Color - True	TCU	8/17/2015	12	<1
Color - True	TCU	8/24/2015	12	<1
Color - True	TCU	8/31/2015	12	<1
Color - True	TCU	9/8/2015	21	<1
Color - True	TCU	9/14/2015	13	<1

Analysis - Seymour	Units	Date Sampled	Source	Treated
Color - True	TCU	9/21/2015	15	2
Color - True	TCU	9/28/2015	20	<1
Color - True	TCU	10/5/2015	16	1
Color - True	TCU	10/13/2015	15	<1
Color - True	TCU	10/19/2015	19	<1
Color - True	TCU	10/26/2015	15	<1
Color - True	TCU	11/2/2015	17	<1
Color - True	TCU	11/9/2015	18	<1
Color - True	TCU	11/16/2015	18	<1
Color - True	TCU	11/23/2015	17	<1
Color - True	TCU	11/30/2015	16	<1
Color - True	TCU	12/7/2015	19	<1
Color - True	TCU	12/14/2015	18	<1
Color - True	TCU	12/21/2015	15	<1
Conductivity	μmhos/cm	1/5/2015	12	26
Conductivity	μmhos/cm	1/12/2015	12	26
Conductivity	μmhos/cm	1/19/2015	13	26
Conductivity	μmhos/cm	1/26/2015	12	26
Conductivity	μmhos/cm	2/2/2015	12	26
Conductivity	μmhos/cm	2/10/2015	8	22
Conductivity	μmhos/cm	2/16/2015	9	23
Conductivity	μmhos/cm	2/23/2015	10	24
Conductivity	μmhos/cm	3/2/2015	10	21
Conductivity	μmhos/cm	3/9/2015	11	23
Conductivity	μmhos/cm	3/16/2015	13	26
Conductivity	μmhos/cm	3/23/2015	12	25
Conductivity	μmhos/cm	3/30/2015	12	25
Conductivity	μmhos/cm	4/7/2015	12	28
Conductivity	μmhos/cm	4/13/2015	11	24
Conductivity	μmhos/cm	4/20/2015	12	24
Conductivity	μmhos/cm	4/27/2015	13	25
Conductivity	μmhos/cm	5/4/2015	14	26
Conductivity	μmhos/cm	5/11/2015	14	26
Conductivity	μmhos/cm	5/19/2015	15	27
Conductivity	μmhos/cm	5/25/2015	15	27
Conductivity	μmhos/cm	6/1/2015	15	27
Conductivity	μmhos/cm	6/8/2015	14	26
Conductivity	μmhos/cm	6/15/2015	15	28
Conductivity	μmhos/cm	6/22/2015	15	28
Conductivity	μmhos/cm	6/29/2015	15	28
Conductivity	μmhos/cm	7/6/2015	16	31
Conductivity	μmhos/cm	7/13/2015	17	32
Conductivity	μmhos/cm	7/20/2015	16	32
Conductivity	μmhos/cm	7/27/2015	17	34
Conductivity	μmhos/cm	8/4/2015	16	33

Analysis - Seymour	Units	Date Sampled	Source	Treated
Conductivity	μmhos/cm	8/10/2015	17	34
Conductivity	μmhos/cm	8/17/2015	16	33
Conductivity	μmhos/cm	8/24/2015	16	32
Conductivity	μmhos/cm	8/31/2015	16	29
Conductivity	μmhos/cm	9/8/2015	15	30
Conductivity	μmhos/cm	9/14/2015	16	32
Conductivity	μmhos/cm	9/21/2015	16	31
Conductivity	μmhos/cm	9/28/2015	16	32
Conductivity	μmhos/cm	10/5/2015	17	33
Conductivity	μmhos/cm	10/13/2015	18	34
Conductivity	μmhos/cm	10/19/2015	18	33
Conductivity	μmhos/cm	10/26/2015	17	31
Conductivity	μmhos/cm	11/2/2015	17	30
Conductivity	μmhos/cm	11/9/2015	15	28
Conductivity	μmhos/cm	11/16/2015	14	27
Conductivity	μmhos/cm	11/23/2015	14	27
Conductivity	μmhos/cm	11/30/2015	15	27
Conductivity	μmhos/cm	12/7/2015	13	27
Conductivity	μmhos/cm	12/14/2015	11	24
Conductivity	μmhos/cm	12/21/2015	13	26
Copper Total	μg/L	2/17/2015	11.5	<0.5
Copper Total	μg/L	5/5/2015	18.3	<0.5
Copper Total	μg/L	6/1/2015	16.7	<0.5
Copper Total	μg/L	10/20/2015	13.3	1.2
Copper Total	μg/L	12/7/2015	6.7	<0.5
Cyanide Total	mg/L	6/1/2015	<0.02	<0.02
Cyanide Total	mg/L	12/7/2015	<0.02	<0.02
Dibromoacetic Acid	ppb	2/17/2015	<0.5	<0.5
Dibromoacetic Acid	ppb	5/20/2015	<0.5	<0.5
Dibromoacetic Acid	ppb	8/18/2015	<0.5	<0.5
Dibromoacetic Acid	ppb	11/25/2015	<0.5	<0.5
Dichloroacetic Acid	ppb	2/17/2015	<1	9
Dichloroacetic Acid	ppb	5/20/2015	<1	6
Dichloroacetic Acid	ppb	8/18/2015	<1	6
Dichloroacetic Acid	ppb	11/25/2015	<1	8
Fluoride	mg/L	1/5/2015	<0.05	<0.05
Fluoride	mg/L	2/2/2015	<0.05	<0.05
Fluoride	mg/L	3/2/2015	<0.05	<0.05
Fluoride	mg/L	4/7/2015	<0.05	<0.05
Fluoride	mg/L	5/4/2015	<0.05	<0.05
Fluoride	mg/L	6/1/2015	<0.05	<0.05
Fluoride	mg/L	7/6/2015	<0.05	<0.05
Fluoride	mg/L	8/10/2015	<0.05	<0.05
Fluoride	mg/L	9/8/2015	<0.05	<0.05
Fluoride	mg/L	10/13/2015	<0.05	<0.05

Analysis - Seymour	Units	Date Sampled	Source	Treated
Fluoride	mg/L	11/9/2015	<0.05	<0.05
Fluoride	mg/L	12/7/2015	<0.05	<0.05
HAA - Total Haloacetic Acid	ppb	2/17/2015	<3	19.9
HAA - Total Haloacetic Acid	ppb	5/20/2015	<3	15.7
HAA - Total Haloacetic Acid	ppb	8/18/2015	<3	19.4
HAA - Total Haloacetic Acid	ppb	11/25/2015	<3	19.6
Hardness as CaCO3	mg/L	1/5/2015	4.33	8.61
Hardness as CaCO3	mg/L	2/2/2015	4.28	8.60
Hardness as CaCO3	mg/L	3/2/2015	3.85	7.88
Hardness as CaCO3	mg/L	4/7/2015	4.01	9.47
Hardness as CaCO3	mg/L	5/4/2015	5.00	8.90
Hardness as CaCO3	mg/L	6/1/2015	5.67	8.98
Hardness as CaCO3	mg/L	7/6/2015	5.84	11.1
Hardness as CaCO3	mg/L	8/10/2015	6.02	11.8
Hardness as CaCO3	mg/L	9/8/2015	6.04	10.6
Hardness as CaCO3	mg/L	10/13/2015	6.31	11.1
Hardness as CaCO3	mg/L	11/9/2015	5.20	9.27
Hardness as CaCO3	mg/L	12/7/2015	4.57	8.85
Iron Dissolved	µg/L	1/5/2015	49	<5
Iron Dissolved	µg/L	1/12/2015	49	<5
Iron Dissolved	µg/L	1/19/2015	53	<5
Iron Dissolved	µg/L	1/26/2015	48	<5
Iron Dissolved	µg/L	2/2/2015	38	<5
Iron Dissolved	µg/L	2/10/2015	36	<5
Iron Dissolved	µg/L	2/16/2015	36	<5
Iron Dissolved	µg/L	2/23/2015	39	<5
Iron Dissolved	µg/L	3/2/2015	39	<5
Iron Dissolved	µg/L	3/9/2015	48	<5
Iron Dissolved	µg/L	3/16/2015	72	<5
Iron Dissolved	µg/L	3/23/2015	65	<5
Iron Dissolved	µg/L	3/30/2015	41	<5
Iron Dissolved	µg/L	4/7/2015	36	<5
Iron Dissolved	µg/L	4/13/2015	41	<5
Iron Dissolved	µg/L	4/20/2015	47	<5
Iron Dissolved	µg/L	4/27/2015	47	<5
Iron Dissolved	µg/L	5/4/2015	62	<5
Iron Dissolved	µg/L	5/11/2015	64	<5
Iron Dissolved	µg/L	5/19/2015	74	<5
Iron Dissolved	µg/L	5/25/2015	80	<5
Iron Dissolved	µg/L	6/1/2015	87	<5
Iron Dissolved	µg/L	6/8/2015	109	<5
Iron Dissolved	µg/L	6/15/2015	143	<5
Iron Dissolved	µg/L	6/22/2015	146	<5
Iron Dissolved	µg/L	6/29/2015	177	5
Iron Dissolved	µg/L	7/6/2015	202	<5

Analysis - Seymour	Units	Date Sampled	Source	Treated
Iron Dissolved	µg/L	7/13/2015	136	6
Iron Dissolved	µg/L	7/20/2015	216	<5
Iron Dissolved	µg/L	7/27/2015	260	<5
Iron Dissolved	µg/L	8/4/2015	295	6
Iron Dissolved	µg/L	8/10/2015	311	<5
Iron Dissolved	µg/L	8/17/2015	299	<5
Iron Dissolved	µg/L	8/24/2015	279	6
Iron Dissolved	µg/L	8/31/2015	301	<5
Iron Dissolved	µg/L	9/8/2015	123	<5
Iron Dissolved	µg/L	9/14/2015	178	<5
Iron Dissolved	µg/L	9/21/2015	201	<5
Iron Dissolved	µg/L	9/28/2015	170	<5
Iron Dissolved	µg/L	10/5/2015	152	<5
Iron Dissolved	µg/L	10/13/2015	171	<5
Iron Dissolved	µg/L	10/19/2015	182	<5
Iron Dissolved	µg/L	10/26/2015	169	<5
Iron Dissolved	µg/L	11/2/2015	166	<5
Iron Dissolved	µg/L	11/9/2015	102	<5
Iron Dissolved	µg/L	11/16/2015	87	<5
Iron Dissolved	µg/L	11/23/2015	74	<5
Iron Dissolved	µg/L	11/30/2015	73	<5
Iron Dissolved	µg/L	12/7/2015	73	<5
Iron Dissolved	µg/L	12/14/2015	49	<5
Iron Dissolved	µg/L	12/21/2015	50	<5
Iron Total	µg/L	1/5/2015	137	<5
Iron Total	µg/L	1/12/2015	153	<5
Iron Total	µg/L	1/19/2015	153	<5
Iron Total	µg/L	1/26/2015	101	<5
Iron Total	µg/L	2/2/2015	108	<5
Iron Total	µg/L	2/10/2015	233	<5
Iron Total	µg/L	2/16/2015	264	<5
Iron Total	µg/L	2/17/2015	108	<5
Iron Total	µg/L	2/23/2015	190	<5
Iron Total	µg/L	3/2/2015	118	<5
Iron Total	µg/L	3/9/2015	121	<5
Iron Total	µg/L	3/16/2015	177	<5
Iron Total	µg/L	3/23/2015	168	<5
Iron Total	µg/L	3/30/2015	104	<5
Iron Total	µg/L	4/7/2015	90	<5
Iron Total	µg/L	4/13/2015	113	<5
Iron Total	µg/L	4/20/2015	104	<5
Iron Total	µg/L	4/27/2015	111	<5
Iron Total	µg/L	5/4/2015	129	<5
Iron Total	µg/L	5/5/2015	139	<5
Iron Total	µg/L	5/11/2015	128	<5

Analysis - Seymour	Units	Date Sampled	Source	Treated
Iron Total	µg/L	5/19/2015	150	<5
Iron Total	µg/L	5/25/2015	189	<5
Iron Total	µg/L	6/1/2015	162	<5
Iron Total	µg/L	6/8/2015	184	6
Iron Total	µg/L	6/15/2015	233	27
Iron Total	µg/L	6/22/2015	232	<5
Iron Total	µg/L	6/29/2015	351	5
Iron Total	µg/L	7/6/2015	374	11
Iron Total	µg/L	7/13/2015	425	9
Iron Total	µg/L	7/20/2015	512	7
Iron Total	µg/L	7/27/2015	621	<5
Iron Total	µg/L	8/4/2015	561	<5
Iron Total	µg/L	8/10/2015	539	<5
Iron Total	µg/L	8/17/2015	474	<5
Iron Total	µg/L	8/24/2015	452	<5
Iron Total	µg/L	8/31/2015	513	<5
Iron Total	µg/L	9/8/2015	628	7
Iron Total	µg/L	9/14/2015	471	12
Iron Total	µg/L	9/21/2015	382	7
Iron Total	µg/L	9/28/2015	514	<5
Iron Total	µg/L	10/5/2015	434	<5
Iron Total	µg/L	10/13/2015	445	6
Iron Total	µg/L	10/19/2015	427	<5
Iron Total	µg/L	10/20/2015	380	5
Iron Total	µg/L	10/26/2015	377	<5
Iron Total	µg/L	11/2/2015	378	<5
Iron Total	µg/L	11/9/2015	234	<5
Iron Total	µg/L	11/16/2015	177	<5
Iron Total	µg/L	11/23/2015	178	<5
Iron Total	µg/L	11/30/2015	160	<5
Iron Total	µg/L	12/7/2015	298	<5
Iron Total	µg/L	12/14/2015	211	<5
Iron Total	µg/L	12/21/2015	181	<5
Lead Total	µg/L	2/17/2015	<0.5	<0.5
Lead Total	µg/L	5/5/2015	<0.5	<0.5
Lead Total	µg/L	6/1/2015	<0.5	<0.5
Lead Total	µg/L	10/20/2015	<0.5	<0.5
Lead Total	µg/L	12/7/2015	<0.5	<0.5
Magnesium Total	µg/L	1/5/2015	154	140
Magnesium Total	µg/L	2/2/2015	144	142
Magnesium Total	µg/L	2/17/2015	121	116
Magnesium Total	µg/L	3/2/2015	130	134
Magnesium Total	µg/L	4/7/2015	130	143
Magnesium Total	µg/L	5/4/2015	154	161
Magnesium Total	µg/L	5/5/2015	165	169

Analysis - Seymour	Units	Date Sampled	Source	Treated
Magnesium Total	µg/L	6/1/2015	176	171
Magnesium Total	µg/L	7/6/2015	177	194
Magnesium Total	µg/L	8/10/2015	179	202
Magnesium Total	µg/L	9/8/2015	259	193
Magnesium Total	µg/L	10/13/2015	211	205
Magnesium Total	µg/L	10/20/2015	199	207
Magnesium Total	µg/L	11/9/2015	165	172
Magnesium Total	µg/L	12/7/2015	206	156
Manganese Dissolved	µg/L	1/5/2015	4.4	4.2
Manganese Dissolved	µg/L	2/2/2015	4	3.8
Manganese Dissolved	µg/L	3/2/2015	4.3	4.1
Manganese Dissolved	µg/L	4/7/2015	3.2	3.8
Manganese Dissolved	µg/L	5/4/2015	3.6	4.6
Manganese Dissolved	µg/L	6/1/2015	2.6	4.1
Manganese Dissolved	µg/L	7/6/2015	7	9.5
Manganese Dissolved	µg/L	8/10/2015	16.1	4.2
Manganese Dissolved	µg/L	9/8/2015	14.9	10.1
Manganese Dissolved	µg/L	10/13/2015	14.9	8.6
Manganese Dissolved	µg/L	11/9/2015	7.6	5.2
Manganese Dissolved	µg/L	12/7/2015	6	5
Manganese Total	µg/L	1/5/2015	6.2	4.3
Manganese Total	µg/L	2/2/2015	5.1	4
Manganese Total	µg/L	2/17/2015	4.6	3
Manganese Total	µg/L	3/2/2015	5.4	4.3
Manganese Total	µg/L	4/7/2015	5.9	4.2
Manganese Total	µg/L	5/4/2015	4.6	4.8
Manganese Total	µg/L	5/5/2015	5.1	5.4
Manganese Total	µg/L	6/1/2015	4.2	4.3
Manganese Total	µg/L	7/6/2015	8.9	11.3
Manganese Total	µg/L	8/10/2015	23.5	15.1
Manganese Total	µg/L	9/8/2015	29.9	13.2
Manganese Total	µg/L	10/13/2015	18.8	10.8
Manganese Total	µg/L	10/20/2015	14.6	11.6
Manganese Total	µg/L	11/9/2015	8.8	5.5
Manganese Total	µg/L	12/7/2015	10.4	5.2
Mercury Total	µg/L	2/17/2015	<0.05	<0.05
Mercury Total	µg/L	5/5/2015	<0.05	<0.05
Mercury Total	µg/L	6/1/2015	<0.05	<0.05
Mercury Total	µg/L	10/20/2015	<0.05	<0.05
Mercury Total	µg/L	12/7/2015	<0.05	<0.05
Molybdenum Total	µg/L	2/17/2015	<0.5	<0.5
Molybdenum Total	µg/L	5/5/2015	<0.5	<0.5
Molybdenum Total	µg/L	10/20/2015	<0.5	<0.5
Monobromoacetic Acid	ppb	2/17/2015	<1	<1
Monobromoacetic Acid	ppb	5/20/2015	<1	<1

Analysis - Seymour	Units	Date Sampled	Source	Treated
Monobromoacetic Acid	ppb	8/18/2015	<1	<1
Monobromoacetic Acid	ppb	11/25/2015	<1	<1
Monochloroacetic Acid	ppb	2/17/2015	<2	4
Monochloroacetic Acid	ppb	5/20/2015	<2	4
Monochloroacetic Acid	ppb	8/18/2015	<2	8
Monochloroacetic Acid	ppb	11/25/2015	<2	6
Nickel Total	µg/L	2/17/2015	<0.5	<0.5
Nickel Total	µg/L	5/5/2015	<0.5	<0.5
Nickel Total	µg/L	6/1/2015	<0.5	<0.5
Nickel Total	µg/L	10/20/2015	<0.5	<0.5
Nickel Total	µg/L	12/7/2015	<0.5	<0.5
Nitrogen - Ammonia as N	mg/L	1/5/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	1/12/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	1/19/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	1/26/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	2/2/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	2/10/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	2/16/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	2/23/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	3/2/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	3/9/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	3/16/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	3/23/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	3/30/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	4/7/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	4/13/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	4/20/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	4/27/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	5/4/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	5/11/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	5/19/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	5/25/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	6/1/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	6/8/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	6/15/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	6/22/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	6/29/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	7/6/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	7/13/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	7/20/2015	0.02	<0.02
Nitrogen - Ammonia as N	mg/L	7/27/2015	0.03	<0.02
Nitrogen - Ammonia as N	mg/L	8/4/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	8/10/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	8/17/2015	0.02	<0.02
Nitrogen - Ammonia as N	mg/L	8/24/2015	<0.02	<0.02

Analysis - Seymour	Units	Date Sampled	Source	Treated
Nitrogen - Ammonia as N	mg/L	8/31/2015	0.03	<0.02
Nitrogen - Ammonia as N	mg/L	9/8/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	9/14/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	9/21/2015	0.02	<0.02
Nitrogen - Ammonia as N	mg/L	9/28/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	10/5/2015	0.02	<0.02
Nitrogen - Ammonia as N	mg/L	10/13/2015	0.03	<0.02
Nitrogen - Ammonia as N	mg/L	10/19/2015	0.02	<0.02
Nitrogen - Ammonia as N	mg/L	10/26/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	11/2/2015	0.02	<0.02
Nitrogen - Ammonia as N	mg/L	11/9/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	11/16/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	11/23/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	11/30/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	12/7/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	12/14/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	12/21/2015	<0.02	<0.02
Nitrogen - Nitrate as N	mg/L	1/5/2015	0.06	0.06
Nitrogen - Nitrate as N	mg/L	2/2/2015	0.08	0.08
Nitrogen - Nitrate as N	mg/L	3/2/2015	0.06	0.07
Nitrogen - Nitrate as N	mg/L	4/7/2015	0.06	0.06
Nitrogen - Nitrate as N	mg/L	5/4/2015	0.06	0.07
Nitrogen - Nitrate as N	mg/L	6/1/2015	0.06	0.06
Nitrogen - Nitrate as N	mg/L	7/6/2015	0.04	0.05
Nitrogen - Nitrate as N	mg/L	8/10/2015	0.03	0.03
Nitrogen - Nitrate as N	mg/L	9/8/2015	0.14	0.15
Nitrogen - Nitrate as N	mg/L	10/13/2015	0.12	0.14
Nitrogen - Nitrate as N	mg/L	11/9/2015	0.11	0.12
Nitrogen - Nitrate as N	mg/L	12/7/2015	0.1	0.1
Nitrogen - Nitrite as N	mg/L	1/5/2015	<0.01	<0.01
Nitrogen - Nitrite as N	mg/L	2/2/2015	<0.01	<0.01
Nitrogen - Nitrite as N	mg/L	3/2/2015	<0.01	<0.01
Nitrogen - Nitrite as N	mg/L	4/7/2015	<0.01	<0.01
Nitrogen - Nitrite as N	mg/L	5/4/2015	<0.01	<0.01
Nitrogen - Nitrite as N	mg/L	6/1/2015	<0.01	<0.01
Nitrogen - Nitrite as N	mg/L	7/6/2015	<0.01	<0.01
Nitrogen - Nitrite as N	mg/L	8/10/2015	<0.01	<0.01
Nitrogen - Nitrite as N	mg/L	9/8/2015	<0.01	<0.01
Nitrogen - Nitrite as N	mg/L	10/13/2015	<0.01	<0.01
Nitrogen - Nitrite as N	mg/L	11/9/2015	<0.01	<0.01
Nitrogen - Nitrite as N	mg/L	12/7/2015	<0.01	<0.01
pH	pH units	1/5/2015	6.5	7.1
pH	pH units	1/12/2015	6.6	7
pH	pH units	1/19/2015	6.6	7.2
pH	pH units	1/26/2015	6.6	7.1

Analysis - Seymour	Units	Date Sampled	Source	Treated
pH	pH units	2/2/2015	6.4	7.2
pH	pH units	2/10/2015	6.5	7
pH	pH units	2/16/2015	6.6	7
pH	pH units	2/17/2015	6.4	7.1
pH	pH units	2/23/2015	6.5	7.1
pH	pH units	3/2/2015	6.5	7.1
pH	pH units	3/9/2015	6.6	7.1
pH	pH units	3/16/2015	6.6	7.1
pH	pH units	3/23/2015	6.6	7.1
pH	pH units	3/30/2015	6.6	7.1
pH	pH units	4/7/2015	6.5	7.2
pH	pH units	4/13/2015	6.6	7.2
pH	pH units	4/20/2015	6.6	7.1
pH	pH units	4/27/2015	6.7	7.1
pH	pH units	5/4/2015	6.6	7.2
pH	pH units	5/11/2015	6.7	7.2
pH	pH units	5/19/2015	6.7	7.2
pH	pH units	5/20/2015	6.5	7.2
pH	pH units	5/25/2015	6.7	7.2
pH	pH units	6/1/2015	6.6	7.2
pH	pH units	6/8/2015	6.6	7.2
pH	pH units	6/15/2015	6.7	7.3
pH	pH units	6/22/2015	6.6	7.3
pH	pH units	6/29/2015	6.7	7.3
pH	pH units	7/6/2015	6.6	7.4
pH	pH units	7/13/2015	6.7	7.4
pH	pH units	7/20/2015	6.8	7.4
pH	pH units	7/27/2015	6.6	7.4
pH	pH units	8/4/2015	6.8	7.3
pH	pH units	8/10/2015	6.7	7.4
pH	pH units	8/17/2015	6.7	7.3
pH	pH units	8/18/2015	6.6	7.3
pH	pH units	8/24/2015	6.8	7.3
pH	pH units	8/31/2015	6.8	7.3
pH	pH units	9/8/2015	6.5	7.2
pH	pH units	9/14/2015	6.6	7.2
pH	pH units	9/21/2015	6.6	7.2
pH	pH units	9/28/2015	6.4	7.2
pH	pH units	10/5/2015	6.6	7.2
pH	pH units	10/13/2015	6.5	7.2
pH	pH units	10/19/2015	6.5	7.2
pH	pH units	10/26/2015	6.5	7.2
pH	pH units	11/2/2015	6.4	7.2
pH	pH units	11/9/2015	6.5	7.2
pH	pH units	11/16/2015	6.6	7.1

Analysis - Seymour	Units	Date Sampled	Source	Treated
pH	pH units	11/23/2015	6.6	7.1
pH	pH units	11/25/2015	6.4	7.1
pH	pH units	11/30/2015	6.7	7.1
pH	pH units	12/7/2015	6.4	7.1
pH	pH units	12/14/2015	6.6	7.1
pH	pH units	12/21/2015	6.6	7.1
Phenol	mg/L	6/1/2015	<0.005	<0.005
Phenol	mg/L	12/7/2015	<0.005	<0.005
Phosphorus Dissolved Reactive	mg/L	1/5/2015	<0.005	<0.005
Phosphorus Dissolved Reactive	mg/L	2/2/2015	<0.005	<0.005
Phosphorus Dissolved Reactive	mg/L	3/2/2015	<0.005	<0.005
Phosphorus Dissolved Reactive	mg/L	4/7/2015	<0.005	<0.005
Phosphorus Dissolved Reactive	mg/L	5/4/2015	<0.005	<0.005
Phosphorus Dissolved Reactive	mg/L	6/1/2015	<0.005	<0.005
Phosphorus Dissolved Reactive	mg/L	7/6/2015	<0.005	<0.005
Phosphorus Dissolved Reactive	mg/L	8/10/2015	<0.005	<0.005
Phosphorus Dissolved Reactive	mg/L	9/8/2015	0.02	<0.005
Phosphorus Dissolved Reactive	mg/L	10/13/2015	<0.005	<0.005
Phosphorus Dissolved Reactive	mg/L	11/9/2015	<0.005	<0.005
Phosphorus Dissolved Reactive	mg/L	12/7/2015	0.01	<0.005
Phosphorus Total	mg/L	1/5/2015	<0.005	<0.005
Phosphorus Total	mg/L	2/2/2015	<0.005	<0.005
Phosphorus Total	mg/L	3/2/2015	<0.005	<0.005
Phosphorus Total	mg/L	4/7/2015	<0.005	<0.005
Phosphorus Total	mg/L	5/4/2015	<0.005	<0.005
Phosphorus Total	mg/L	6/1/2015	<0.005	<0.005
Phosphorus Total	mg/L	7/6/2015	<0.005	<0.005
Phosphorus Total	mg/L	8/10/2015	<0.005	<0.005
Phosphorus Total	mg/L	9/8/2015	0.019	<0.005
Phosphorus Total	mg/L	10/13/2015	0.007	<0.005
Phosphorus Total	mg/L	11/9/2015	<0.005	<0.005
Phosphorus Total	mg/L	12/7/2015	0.011	<0.005
Potassium Total	µg/L	5/5/2015	180	166
Potassium Total	µg/L	6/1/2015	196	175
Potassium Total	µg/L	10/20/2015	253	235
Potassium Total	µg/L	12/7/2015	196	163

Analysis - Seymour	Units	Date Sampled	Source	Treated
Residue Total	mg/L	2/2/2015	18	22
Residue Total	mg/L	4/7/2015	16	22
Residue Total	mg/L	6/1/2015	19	23
Residue Total	mg/L	8/10/2015	30	40
Residue Total	mg/L	10/13/2015	26	30
Residue Total	mg/L	12/7/2015	22	22
Residue Total Dissolved	mg/L	2/2/2015	16	20
Residue Total Dissolved	mg/L	4/7/2015	18	22
Residue Total Dissolved	mg/L	6/1/2015	16	22
Residue Total Dissolved	mg/L	8/10/2015	29	27
Residue Total Dissolved	mg/L	10/13/2015	18	25
Residue Total Dissolved	mg/L	12/7/2015	17	16
Residue Total Fixed	mg/L	2/2/2015	10	14
Residue Total Fixed	mg/L	4/7/2015	8	13
Residue Total Fixed	mg/L	6/1/2015	12	15
Residue Total Fixed	mg/L	8/10/2015	21	31
Residue Total Fixed	mg/L	10/13/2015	17	21
Residue Total Fixed	mg/L	12/7/2015	12	16
Residue Total Volatile	mg/L	2/2/2015	8	8
Residue Total Volatile	mg/L	4/7/2015	8	8
Residue Total Volatile	mg/L	6/1/2015	7	8
Residue Total Volatile	mg/L	8/10/2015	9	9
Residue Total Volatile	mg/L	10/13/2015	10	10
Residue Total Volatile	mg/L	12/7/2015	9	6
Selenium Total	µg/L	2/17/2015	<0.5	<0.5
Selenium Total	µg/L	5/5/2015	<0.5	<0.5
Selenium Total	µg/L	6/1/2015	<0.5	<0.5
Selenium Total	µg/L	10/20/2015	<0.5	<0.5
Selenium Total	µg/L	12/7/2015	<0.5	<0.5
Silica as SiO2	mg/L	2/2/2015	2.9	2.9
Silica as SiO2	mg/L	4/7/2015	2.7	2.7
Silica as SiO2	mg/L	6/1/2015	3.2	3.1
Silica as SiO2	mg/L	8/10/2015	3.2	3.4
Silica as SiO2	mg/L	10/13/2015	3.4	3.5
Silica as SiO2	mg/L	12/7/2015	2.9	3.1
Silver Total	µg/L	2/17/2015	<0.5	<0.5
Silver Total	µg/L	5/5/2015	<0.5	<0.5
Silver Total	µg/L	6/1/2015	<0.5	<0.5
Silver Total	µg/L	10/20/2015	<0.5	<0.5
Silver Total	µg/L	12/7/2015	<0.5	<0.5
Sodium Total	µg/L	2/2/2015	520	1260
Sodium Total	µg/L	2/17/2015	463	1370
Sodium Total	µg/L	4/7/2015	482	1390
Sodium Total	µg/L	5/5/2015	592	1520
Sodium Total	µg/L	5/20/2015	612	1510

Analysis - Seymour	Units	Date Sampled	Source	Treated
Sodium Total	µg/L	6/1/2015	622	1520
Sodium Total	µg/L	8/10/2015	666	1740
Sodium Total	µg/L	8/18/2015	636	1810
Sodium Total	µg/L	10/13/2015	644	1940
Sodium Total	µg/L	10/20/2015	649	1770
Sodium Total	µg/L	11/25/2015	557	1500
Sodium Total	µg/L	12/7/2015	536	1370
Sulphate	mg/L	1/5/2015	1.2	1.2
Sulphate	mg/L	2/2/2015	1.2	1.2
Sulphate	mg/L	3/2/2015	1	0.9
Sulphate	mg/L	4/7/2015	1.1	1
Sulphate	mg/L	5/4/2015	1.5	1.1
Sulphate	mg/L	6/1/2015	1.6	1.1
Sulphate	mg/L	7/6/2015	1.7	1.1
Sulphate	mg/L	8/10/2015	1.7	1.3
Sulphate	mg/L	9/8/2015	1.3	1.1
Sulphate	mg/L	10/13/2015	1.6	1.2
Sulphate	mg/L	11/9/2015	1.3	1.1
Sulphate	mg/L	12/7/2015	1.1	1.1
Temperature	°C	1/5/2015	4.2	4.4
Temperature	°C	1/12/2015	4.4	
Temperature	°C	1/19/2015	5.1	4.5
Temperature	°C	1/26/2015	5.7	5.7
Temperature	°C	2/2/2015	6.1	5.8
Temperature	°C	2/10/2015	6.8	6.8
Temperature	°C	2/16/2015	7.1	7.1
Temperature	°C	2/23/2015	6.1	6.7
Temperature	°C	3/2/2015	6.6	6.7
Temperature	°C	3/9/2015	6.7	6.7
Temperature	°C	3/16/2015	6.3	7
Temperature	°C	3/23/2015	7.3	7.4
Temperature	°C	3/30/2015	7.4	7.6
Temperature	°C	4/7/2015	7.7	7.9
Temperature	°C	4/13/2015	7.6	7.3
Temperature	°C	4/20/2015	9	7.9
Temperature	°C	4/27/2015	9.3	7.8
Temperature	°C	5/4/2015	9.9	9.8
Temperature	°C	5/11/2015	8.9	8
Temperature	°C	5/19/2015	10	8.9
Temperature	°C	5/25/2015	11	9
Temperature	°C	6/1/2015	9	9.1
Temperature	°C	6/8/2015	13	10
Temperature	°C	6/15/2015	14	10
Temperature	°C	6/22/2015	12	12
Temperature	°C	6/29/2015	17	13

Analysis - Seymour	Units	Date Sampled	Source	Treated
Temperature	°C	7/6/2015	18	16
Temperature	°C	7/13/2015	19	14
Temperature	°C	7/20/2015	20	16
Temperature	°C	7/27/2015	18	18
Temperature	°C	8/4/2015	18	17
Temperature	°C	8/10/2015	18	17
Temperature	°C	8/17/2015	18	18
Temperature	°C	8/24/2015	20	19
Temperature	°C	8/31/2015	17	17
Temperature	°C	9/8/2015	17	17
Temperature	°C	9/14/2015	14	14
Temperature	°C	9/21/2015	14	14
Temperature	°C	9/28/2015	13	13
Temperature	°C	10/5/2015	12	12
Temperature	°C	10/13/2015	12	12
Temperature	°C	10/19/2015	12	12
Temperature	°C	10/26/2015	12	12
Temperature	°C	11/2/2015	11	11
Temperature	°C	11/3/2015	10	10
Temperature	°C	11/4/2015	9.9	10
Temperature	°C	11/5/2015	10	10
Temperature	°C	11/6/2015	9.7	9.7
Temperature	°C	11/7/2015	LA	
Temperature	°C	11/8/2015	LA	
Temperature	°C	11/9/2015	8.9	9.1
Temperature	°C	11/10/2015	9.3	9.2
Temperature	°C	11/11/2015	LA	
Temperature	°C	11/12/2015	LA	
Temperature	°C	11/13/2015	8.8	9.3
Temperature	°C	11/14/2015	8.3	8.3
Temperature	°C	11/15/2015	7.9	8.2
Temperature	°C	11/16/2015	6.7	7.9
Temperature	°C	11/17/2015	7.3	7.8
Temperature	°C	11/18/2015	7.3	9.3
Temperature	°C	11/19/2015	6.9	7.2
Temperature	°C	11/20/2015	7.3	7.5
Temperature	°C	11/21/2015	6.5	7
Temperature	°C	11/22/2015	6.5	6.9
Temperature	°C	11/23/2015	6.8	7.1
Temperature	°C	11/24/2015	6.4	7
Temperature	°C	11/25/2015	3.9	6.4
Temperature	°C	11/26/2015	5.8	6.4
Temperature	°C	11/27/2015	LA	6.1
Temperature	°C	11/28/2015	5.5	6.1
Temperature	°C	11/29/2015	5.1	5.9

Analysis - Seymour	Units	Date Sampled	Source	Treated
Temperature	°C	11/30/2015	4.5	5.5
Temperature	°C	12/1/2015	5.8	LA
Temperature	°C	12/2/2015	LA	6.1
Temperature	°C	12/3/2015	5.2	5.9
Temperature	°C	12/4/2015	5.5	6.3
Temperature	°C	12/5/2015	5.1	5.4
Temperature	°C	12/6/2015	5.2	5.5
Temperature	°C	12/7/2015	5.8	6.1
Temperature	°C	12/8/2015	6.4	6.2
Temperature	°C	12/9/2015	6.1	6.3
Temperature	°C	12/10/2015	6.1	6.2
Temperature	°C	12/11/2015	6	6.5
Temperature	°C	12/12/2015	6	6.3
Temperature	°C	12/13/2015	6	6.2
Temperature	°C	12/14/2015	6	6
Temperature	°C	12/15/2015	6.2	6.3
Temperature	°C	12/16/2015	6.3	6.6
Temperature	°C	12/17/2015	6.2	6.4
Temperature	°C	12/18/2015	6.2	6.4
Temperature	°C	12/19/2015	5.6	5.9
Temperature	°C	12/20/2015	5.7	5.8
Temperature	°C	12/21/2015	5.7	5.9
Temperature	°C	12/22/2015	5.6	5.9
Temperature	°C	12/23/2015	7.4	6
Temperature	°C	12/24/2015	5.4	5.5
Temperature	°C	12/26/2015	5.8	6.1
Temperature	°C	12/27/2015	5.4	5.8
Temperature	°C	12/28/2015	3.8	4.7
Temperature	°C	12/29/2015	4.4	5.2
Temperature	°C	12/30/2015	3.8	4.9
Temperature	°C	12/31/2015	3.7	4.2
THM-Total Trihalomethanes	ppb	2/17/2015	<2.0	17.7
THM-Total Trihalomethanes	ppb	5/20/2015	<2.0	16.6
THM-Total Trihalomethanes	ppb	8/18/2015	<2.0	20.9
THM-Total Trihalomethanes	ppb	11/25/2015	<2	17.1
Trichloroacetic Acid	ppb	2/17/2015	<0.5	5.5
Trichloroacetic Acid	ppb	5/20/2015	<0.5	4.8
Trichloroacetic Acid	ppb	8/18/2015	<0.5	4.5
Trichloroacetic Acid	ppb	11/25/2015	<0.5	5
Turbidity	NTU	1/1/2015	1.3	0.1
Turbidity	NTU	1/2/2015	2.2	0.11
Turbidity	NTU	1/3/2015	1.1	0.09
Turbidity	NTU	1/4/2015	1.2	0.12
Turbidity	NTU	1/5/2015	1.3	0.09
Turbidity	NTU	1/6/2015	1.3	0.13

Analysis - Seymour	Units	Date Sampled	Source	Treated
Turbidity	NTU	1/7/2015	1	0.09
Turbidity	NTU	1/8/2015	1.6	0.11
Turbidity	NTU	1/9/2015	1.2	0.11
Turbidity	NTU	1/10/2015	0.92	0.1
Turbidity	NTU	1/11/2015	0.94	0.12
Turbidity	NTU	1/12/2015	0.92	0.1
Turbidity	NTU	1/13/2015	0.88	0.13
Turbidity	NTU	1/14/2015	1.1	0.13
Turbidity	NTU	1/15/2015	1.3	0.13
Turbidity	NTU	1/16/2015	0.82	0.1
Turbidity	NTU	1/17/2015	0.84	0.11
Turbidity	NTU	1/18/2015	1.1	0.08
Turbidity	NTU	1/19/2015	0.98	0.13
Turbidity	NTU	1/20/2015	0.63	0.1
Turbidity	NTU	1/21/2015	0.61	0.1
Turbidity	NTU	1/22/2015	0.61	0.12
Turbidity	NTU	1/23/2015	1.2	0.13
Turbidity	NTU	1/24/2015	0.64	0.13
Turbidity	NTU	1/25/2015	0.75	0.1
Turbidity	NTU	1/26/2015	0.67	0.08
Turbidity	NTU	1/27/2015	1.8	0.12
Turbidity	NTU	1/28/2015	0.72	0.1
Turbidity	NTU	1/29/2015	0.85	0.12
Turbidity	NTU	1/30/2015	0.79	0.13
Turbidity	NTU	1/31/2015	0.6	0.08
Turbidity	NTU	2/1/2015	0.6	0.08
Turbidity	NTU	2/2/2015	0.69	0.12
Turbidity	NTU	2/3/2015	0.8	0.13
Turbidity	NTU	2/4/2015	0.6	0.08
Turbidity	NTU	2/5/2015	0.66	0.09
Turbidity	NTU	2/6/2015	0.57	0.08
Turbidity	NTU	2/7/2015	3.2	0.12
Turbidity	NTU	2/8/2015	4.1	0.11
Turbidity	NTU	2/9/2015	3.8	0.09
Turbidity	NTU	2/10/2015	4.2	0.12
Turbidity	NTU	2/11/2015	3.2	0.14
Turbidity	NTU	2/12/2015	3.2	0.11
Turbidity	NTU	2/13/2015	2.7	0.11
Turbidity	NTU	2/14/2015	2	0.09
Turbidity	NTU	2/15/2015	1.9	0.1
Turbidity	NTU	2/16/2015	2.4	0.09
Turbidity	NTU	2/17/2015	1.8	0.11
Turbidity	NTU	2/18/2015	1.5	0.12
Turbidity	NTU	2/19/2015	1.9	0.13
Turbidity	NTU	2/20/2015	1.6	0.11

Analysis - Seymour	Units	Date Sampled	Source	Treated
Turbidity	NTU	2/21/2015	1.3	0.09
Turbidity	NTU	2/22/2015	1.3	0.1
Turbidity	NTU	2/23/2015	1.6	0.11
Turbidity	NTU	2/24/2015	1.2	0.12
Turbidity	NTU	2/25/2015	1.2	0.13
Turbidity	NTU	2/26/2015	1.2	0.09
Turbidity	NTU	2/27/2015	7.6	0.13
Turbidity	NTU	2/28/2015	1	0.11
Turbidity	NTU	3/1/2015	0.99	0.13
Turbidity	NTU	3/2/2015	1.1	0.1
Turbidity	NTU	3/3/2015	1.2	0.11
Turbidity	NTU	3/4/2015	1.3	0.1
Turbidity	NTU	3/5/2015	0.93	0.09
Turbidity	NTU	3/6/2015	1.3	0.09
Turbidity	NTU	3/7/2015	0.76	0.12
Turbidity	NTU	3/8/2015	0.78	0.09
Turbidity	NTU	3/9/2015	0.87	0.1
Turbidity	NTU	3/10/2015	1	0.09
Turbidity	NTU	3/11/2015	1.2	0.12
Turbidity	NTU	3/12/2015	0.9	0.11
Turbidity	NTU	3/13/2015	0.85	0.1
Turbidity	NTU	3/14/2015	0.69	0.13
Turbidity	NTU	3/15/2015	0.69	0.1
Turbidity	NTU	3/16/2015	1.4	0.11
Turbidity	NTU	3/17/2015	0.75	0.12
Turbidity	NTU	3/18/2015	1.1	0.09
Turbidity	NTU	3/19/2015	0.86	0.09
Turbidity	NTU	3/20/2015	0.94	0.1
Turbidity	NTU	3/21/2015	0.7	0.1
Turbidity	NTU	3/22/2015	0.69	0.1
Turbidity	NTU	3/23/2015	0.88	0.09
Turbidity	NTU	3/24/2015	0.68	0.11
Turbidity	NTU	3/25/2015	1.2	0.11
Turbidity	NTU	3/26/2015	0.79	0.1
Turbidity	NTU	3/27/2015	0.68	0.1
Turbidity	NTU	3/28/2015	0.68	0.12
Turbidity	NTU	3/29/2015	0.62	0.08
Turbidity	NTU	3/30/2015	0.68	0.12
Turbidity	NTU	3/31/2015	0.69	0.12
Turbidity	NTU	4/1/2015	0.6	0.11
Turbidity	NTU	4/2/2015	0.58	0.11
Turbidity	NTU	4/3/2015	0.5	0.12
Turbidity	NTU	4/4/2015	0.48	0.09
Turbidity	NTU	4/5/2015	0.43	0.1
Turbidity	NTU	4/6/2015	0.45	0.1

Analysis - Seymour	Units	Date Sampled	Source	Treated
Turbidity	NTU	4/7/2015	0.47	0.1
Turbidity	NTU	4/8/2015	0.55	0.14
Turbidity	NTU	4/9/2015	0.42	0.11
Turbidity	NTU	4/10/2015	0.59	0.13
Turbidity	NTU	4/11/2015	0.43	0.09
Turbidity	NTU	4/12/2015	0.39	0.09
Turbidity	NTU	4/13/2015	0.5	0.12
Turbidity	NTU	4/14/2015	0.53	0.13
Turbidity	NTU	4/15/2015	0.45	0.1
Turbidity	NTU	4/16/2015	0.54	0.11
Turbidity	NTU	4/17/2015	0.37	0.12
Turbidity	NTU	4/18/2015	0.39	0.1
Turbidity	NTU	4/19/2015	0.36	0.08
Turbidity	NTU	4/20/2015	0.37	0.11
Turbidity	NTU	4/21/2015	0.68	0.09
Turbidity	NTU	4/22/2015	0.45	0.1
Turbidity	NTU	4/23/2015	1.2	0.11
Turbidity	NTU	4/24/2015	1.1	0.13
Turbidity	NTU	4/25/2015	0.31	0.09
Turbidity	NTU	4/26/2015	0.35	0.07
Turbidity	NTU	4/27/2015	0.92	0.12
Turbidity	NTU	4/28/2015	0.36	0.11
Turbidity	NTU	4/29/2015	0.35	0.13
Turbidity	NTU	4/30/2015	0.34	0.08
Turbidity	NTU	5/1/2015	0.39	0.13
Turbidity	NTU	5/2/2015	0.34	0.09
Turbidity	NTU	5/3/2015	0.29	0.08
Turbidity	NTU	5/4/2015	0.3	LA
Turbidity	NTU	5/5/2015	0.32	0.09
Turbidity	NTU	5/6/2015	0.31	0.13
Turbidity	NTU	5/7/2015	0.29	0.09
Turbidity	NTU	5/8/2015	0.34	0.12
Turbidity	NTU	5/9/2015	0.31	0.09
Turbidity	NTU	5/10/2015	0.29	0.1
Turbidity	NTU	5/11/2015	0.42	0.12
Turbidity	NTU	5/12/2015	0.96	0.11
Turbidity	NTU	5/13/2015	0.4	0.13
Turbidity	NTU	5/14/2015	0.38	0.1
Turbidity	NTU	5/15/2015	0.38	0.13
Turbidity	NTU	5/16/2015	0.27	0.08
Turbidity	NTU	5/17/2015	0.28	0.1
Turbidity	NTU	5/18/2015	0.29	0.1
Turbidity	NTU	5/19/2015	0.33	0.11
Turbidity	NTU	5/20/2015	0.31	0.08
Turbidity	NTU	5/21/2015	0.31	0.11

Analysis - Seymour	Units	Date Sampled	Source	Treated
Turbidity	NTU	5/22/2015	0.3	0.12
Turbidity	NTU	5/23/2015	0.36	0.08
Turbidity	NTU	5/24/2015	0.34	0.1
Turbidity	NTU	5/25/2015	0.37	0.13
Turbidity	NTU	5/26/2015	0.36	0.1
Turbidity	NTU	5/27/2015	0.32	0.12
Turbidity	NTU	5/28/2015	0.33	0.13
Turbidity	NTU	5/29/2015	0.32	0.1
Turbidity	NTU	5/30/2015	0.28	0.09
Turbidity	NTU	5/31/2015	0.29	0.09
Turbidity	NTU	6/1/2015	0.51	0.12
Turbidity	NTU	6/2/2015	0.3	0.13
Turbidity	NTU	6/3/2015	0.32	0.13
Turbidity	NTU	6/4/2015	0.34	0.13
Turbidity	NTU	6/5/2015	0.44	0.12
Turbidity	NTU	6/6/2015	0.27	0.1
Turbidity	NTU	6/7/2015	0.28	0.1
Turbidity	NTU	6/8/2015	0.37	0.14
Turbidity	NTU	6/9/2015	0.34	0.13
Turbidity	NTU	6/10/2015	0.34	0.11
Turbidity	NTU	6/11/2015	0.36	0.14
Turbidity	NTU	6/12/2015	0.41	0.11
Turbidity	NTU	6/13/2015	0.39	0.1
Turbidity	NTU	6/14/2015	0.34	0.09
Turbidity	NTU	6/15/2015	0.35	0.14
Turbidity	NTU	6/16/2015	0.41	0.13
Turbidity	NTU	6/17/2015	0.36	0.12
Turbidity	NTU	6/18/2015	0.37	0.13
Turbidity	NTU	6/19/2015	0.48	0.13
Turbidity	NTU	6/20/2015	0.38	0.13
Turbidity	NTU	6/21/2015	0.39	0.11
Turbidity	NTU	6/22/2015	0.38	0.09
Turbidity	NTU	6/23/2015	0.48	0.1
Turbidity	NTU	6/24/2015	0.53	0.12
Turbidity	NTU	6/25/2015	0.42	0.1
Turbidity	NTU	6/26/2015	0.44	
Turbidity	NTU	6/27/2015	0.47	0.13
Turbidity	NTU	6/28/2015	0.45	0.11
Turbidity	NTU	6/29/2015	0.51	0.14
Turbidity	NTU	6/30/2015	0.5	0.14
Turbidity	NTU	7/1/2015	0.49	0.11
Turbidity	NTU	7/2/2015	0.52	0.12
Turbidity	NTU	7/3/2015	0.55	0.13
Turbidity	NTU	7/4/2015	0.51	0.1
Turbidity	NTU	7/5/2015	0.54	0.1

Analysis - Seymour	Units	Date Sampled	Source	Treated
Turbidity	NTU	7/6/2015	0.58	0.11
Turbidity	NTU	7/7/2015	0.97	0.13
Turbidity	NTU	7/8/2015	0.58	0.12
Turbidity	NTU	7/9/2015	0.72	0.12
Turbidity	NTU	7/10/2015	0.58	0.09
Turbidity	NTU	7/11/2015	0.59	0.1
Turbidity	NTU	7/12/2015	0.63	0.1
Turbidity	NTU	7/13/2015	0.61	0.13
Turbidity	NTU	7/14/2015	0.59	0.13
Turbidity	NTU	7/15/2015	0.62	0.12
Turbidity	NTU	7/16/2015	0.59	0.12
Turbidity	NTU	7/17/2015	0.63	0.12
Turbidity	NTU	7/18/2015	0.6	0.12
Turbidity	NTU	7/19/2015	0.58	0.1
Turbidity	NTU	7/20/2015	0.67	0.14
Turbidity	NTU	7/21/2015	0.74	0.12
Turbidity	NTU	7/22/2015	0.68	0.12
Turbidity	NTU	7/23/2015	0.66	0.07
Turbidity	NTU	7/24/2015	0.68	0.13
Turbidity	NTU	7/25/2015	0.77	0.1
Turbidity	NTU	7/26/2015	0.78	0.13
Turbidity	NTU	7/27/2015	0.87	0.13
Turbidity	NTU	7/28/2015	0.86	0.14
Turbidity	NTU	7/29/2015	0.86	0.13
Turbidity	NTU	7/30/2015	0.77	0.13
Turbidity	NTU	7/31/2015	0.77	0.11
Turbidity	NTU	8/1/2015	0.75	0.13
Turbidity	NTU	8/2/2015	0.71	0.13
Turbidity	NTU	8/3/2015	0.69	0.12
Turbidity	NTU	8/4/2015	0.75	0.13
Turbidity	NTU	8/5/2015	0.71	0.13
Turbidity	NTU	8/6/2015	0.72	0.13
Turbidity	NTU	8/7/2015	0.69	0.13
Turbidity	NTU	8/8/2015	0.65	0.11
Turbidity	NTU	8/9/2015	0.7	0.13
Turbidity	NTU	8/10/2015	0.65	0.13
Turbidity	NTU	8/11/2015	0.68	0.08
Turbidity	NTU	8/12/2015	0.64	0.11
Turbidity	NTU	8/13/2015	0.66	0.13
Turbidity	NTU	8/14/2015	0.76	0.13
Turbidity	NTU	8/15/2015	0.56	0.13
Turbidity	NTU	8/16/2015	0.56	0.12
Turbidity	NTU	8/17/2015	0.58	0.13
Turbidity	NTU	8/18/2015	0.62	0.13
Turbidity	NTU	8/19/2015	0.57	0.12

Analysis - Seymour	Units	Date Sampled	Source	Treated
Turbidity	NTU	8/20/2015	0.6	0.15
Turbidity	NTU	8/21/2015	0.53	0.14
Turbidity	NTU	8/22/2015	0.48	0.13
Turbidity	NTU	8/23/2015	0.51	0.13
Turbidity	NTU	8/24/2015	0.58	0.13
Turbidity	NTU	8/25/2015	0.63	0.1
Turbidity	NTU	8/26/2015	0.74	0.11
Turbidity	NTU	8/27/2015	0.55	0.08
Turbidity	NTU	8/28/2015	0.54	0.08
Turbidity	NTU	8/29/2015	0.51	0.11
Turbidity	NTU	8/30/2015	0.56	0.13
Turbidity	NTU	8/31/2015	0.97	0.08
Turbidity	NTU	9/1/2015	0.73	0.14
Turbidity	NTU	9/2/2015	2.1	0.15
Turbidity	NTU	9/3/2015	5.2	0.1
Turbidity	NTU	9/4/2015	5.6	0.1
Turbidity	NTU	9/5/2015	7.8	0.11
Turbidity	NTU	9/6/2015	8.2	0.12
Turbidity	NTU	9/7/2015	6.4	0.1
Turbidity	NTU	9/8/2015	6.7	0.13
Turbidity	NTU	9/9/2015	6.2	0.13
Turbidity	NTU	9/10/2015	6.9	0.19
Turbidity	NTU	9/11/2015	5.9	0.13
Turbidity	NTU	9/12/2015	5	0.09
Turbidity	NTU	9/13/2015	4.7	0.08
Turbidity	NTU	9/14/2015	4.4	0.17
Turbidity	NTU	9/15/2015	2.8	0.12
Turbidity	NTU	9/16/2015	2.2	0.11
Turbidity	NTU	9/17/2015	2.2	0.13
Turbidity	NTU	9/18/2015	1.9	0.08
Turbidity	NTU	9/19/2015	1.7	0.1
Turbidity	NTU	9/20/2015	1.5	0.08
Turbidity	NTU	9/21/2015	1.3	0.11
Turbidity	NTU	9/22/2015	4	0.11
Turbidity	NTU	9/23/2015	6	0.08
Turbidity	NTU	9/24/2015	7.4	0.09
Turbidity	NTU	9/25/2015	8.2	0.12
Turbidity	NTU	9/26/2015	7.4	0.08
Turbidity	NTU	9/27/2015	5	0.1
Turbidity	NTU	9/28/2015	4.6	0.11
Turbidity	NTU	9/29/2015	3.8	0.16
Turbidity	NTU	9/30/2015	4.9	0.13
Turbidity	NTU	10/1/2015	4.5	0.13
Turbidity	NTU	10/2/2015	4.5	0.12
Turbidity	NTU	10/3/2015	4.5	0.1

Analysis - Seymour	Units	Date Sampled	Source	Treated
Turbidity	NTU	10/4/2015	3.3	0.08
Turbidity	NTU	10/5/2015	3.2	0.09
Turbidity	NTU	10/6/2015	3.2	0.11
Turbidity	NTU	10/7/2015	3.1	0.1
Turbidity	NTU	10/8/2015	4	0.11
Turbidity	NTU	10/9/2015	2.5	0.12
Turbidity	NTU	10/10/2015	2.5	0.1
Turbidity	NTU	10/11/2015	2.2	0.1
Turbidity	NTU	10/12/2015	2	0.09
Turbidity	NTU	10/13/2015	2	0.09
Turbidity	NTU	10/14/2015	2.4	0.08
Turbidity	NTU	10/15/2015	2.1	0.1
Turbidity	NTU	10/16/2015	2.1	0.13
Turbidity	NTU	10/17/2015	2	0.08
Turbidity	NTU	10/18/2015	1.9	0.09
Turbidity	NTU	10/19/2015	2	0.12
Turbidity	NTU	10/20/2015	1.8	0.12
Turbidity	NTU	10/21/2015	1.7	0.12
Turbidity	NTU	10/22/2015	1.8	0.12
Turbidity	NTU	10/23/2015	1.6	0.11
Turbidity	NTU	10/24/2015	1.5	0.1
Turbidity	NTU	10/25/2015	1.5	0.08
Turbidity	NTU	10/26/2015	1.6	0.09
Turbidity	NTU	10/27/2015	1.5	0.11
Turbidity	NTU	10/28/2015	1.6	0.13
Turbidity	NTU	10/29/2015	1.5	0.09
Turbidity	NTU	10/30/2015	1.5	0.12
Turbidity	NTU	10/31/2015	1.4	0.1
Turbidity	NTU	11/1/2015	1.5	0.09
Turbidity	NTU	11/2/2015	1.4	0.13
Turbidity	NTU	11/3/2015	1.3	0.13
Turbidity	NTU	11/4/2015	1.2	0.11
Turbidity	NTU	11/5/2015	1.3	0.1
Turbidity	NTU	11/6/2015	1	0.12
Turbidity	NTU	11/7/2015	0.89	0.08
Turbidity	NTU	11/8/2015	0.81	0.11
Turbidity	NTU	11/9/2015	0.92	0.12
Turbidity	NTU	11/10/2015	1	0.13
Turbidity	NTU	11/11/2015	1.3	0.13
Turbidity	NTU	11/12/2015	1.1	0.12
Turbidity	NTU	11/13/2015	1.2	0.11
Turbidity	NTU	11/14/2015	0.97	0.1
Turbidity	NTU	11/15/2015	0.91	0.08
Turbidity	NTU	11/16/2015	0.9	0.1
Turbidity	NTU	11/17/2015	0.84	0.12

Analysis - Seymour	Units	Date Sampled	Source	Treated
Turbidity	NTU	11/18/2015	1.1	0.13
Turbidity	NTU	11/19/2015	0.92	0.13
Turbidity	NTU	11/20/2015	0.89	0.13
Turbidity	NTU	11/21/2015	0.89	0.09
Turbidity	NTU	11/22/2015	0.84	0.09
Turbidity	NTU	11/23/2015	1	0.11
Turbidity	NTU	11/24/2015	1.2	0.12
Turbidity	NTU	11/25/2015	1.2	0.13
Turbidity	NTU	11/26/2015	1.1	0.09
Turbidity	NTU	11/27/2015	1	0.11
Turbidity	NTU	11/28/2015	0.83	0.12
Turbidity	NTU	11/29/2015	0.79	0.07
Turbidity	NTU	11/30/2015	0.86	0.1
Turbidity	NTU	12/1/2015	0.95	0.11
Turbidity	NTU	12/2/2015	0.85	0.13
Turbidity	NTU	12/3/2015	0.8	0.1
Turbidity	NTU	12/4/2015	0.75	0.13
Turbidity	NTU	12/5/2015	1.4	0.1
Turbidity	NTU	12/6/2015	2.9	0.11
Turbidity	NTU	12/7/2015	4.4	0.1
Turbidity	NTU	12/8/2015	2.9	0.11
Turbidity	NTU	12/9/2015	2.5	0.09
Turbidity	NTU	12/10/2015	2.2	0.11
Turbidity	NTU	12/11/2015	3.2	0.09
Turbidity	NTU	12/12/2015	3.2	0.09
Turbidity	NTU	12/13/2015	3.5	0.09
Turbidity	NTU	12/14/2015	3.3	0.13
Turbidity	NTU	12/15/2015	3.4	0.13
Turbidity	NTU	12/16/2015	3.9	0.13
Turbidity	NTU	12/17/2015	2.8	0.13
Turbidity	NTU	12/18/2015	3.7	0.13
Turbidity	NTU	12/19/2015	2.5	0.1
Turbidity	NTU	12/20/2015	2.5	0.08
Turbidity	NTU	12/21/2015	2.3	0.1
Turbidity	NTU	12/22/2015	2	0.13
Turbidity	NTU	12/23/2015	2.4	0.1
Turbidity	NTU	12/24/2015	3.2	0.11
Turbidity	NTU	12/26/2015	1.7	0.08
Turbidity	NTU	12/27/2015	1.5	0.08
Turbidity	NTU	12/28/2015	1.5	0.09
Turbidity	NTU	12/29/2015	3.6	0.12
Turbidity	NTU	12/30/2015	1.2	0.09
Turbidity	NTU	12/31/2015	1.2	0.1
UV Absorbance 254 nm	Abs/cm	1/5/2015	0.084	0.01
UV Absorbance 254 nm	Abs/cm	1/12/2015	0.078	0.01

Analysis - Seymour	Units	Date Sampled	Source	Treated
UV Absorbance 254 nm	Abs/cm	1/19/2015	0.072	0.01
UV Absorbance 254 nm	Abs/cm	1/26/2015	0.089	0.01
UV Absorbance 254 nm	Abs/cm	2/2/2015	0.09	0.011
UV Absorbance 254 nm	Abs/cm	2/10/2015	0.12	0.013
UV Absorbance 254 nm	Abs/cm	2/16/2015	0.096	0.011
UV Absorbance 254 nm	Abs/cm	2/23/2015	0.089	0.011
UV Absorbance 254 nm	Abs/cm	3/2/2015	0.085	0.011
UV Absorbance 254 nm	Abs/cm	3/9/2015	0.078	0.01
UV Absorbance 254 nm	Abs/cm	3/16/2015	0.07	0.011
UV Absorbance 254 nm	Abs/cm	3/23/2015	0.083	0.01
UV Absorbance 254 nm	Abs/cm	3/30/2015	0.094	0.012
UV Absorbance 254 nm	Abs/cm	4/7/2015	0.095	0.012
UV Absorbance 254 nm	Abs/cm	4/13/2015	0.088	0.011
UV Absorbance 254 nm	Abs/cm	4/20/2015	0.079	0.011
UV Absorbance 254 nm	Abs/cm	4/27/2015	0.072	0.011
UV Absorbance 254 nm	Abs/cm	5/4/2015	0.067	0.01
UV Absorbance 254 nm	Abs/cm	5/11/2015	0.065	0.011
UV Absorbance 254 nm	Abs/cm	5/19/2015	0.062	0.009
UV Absorbance 254 nm	Abs/cm	5/25/2015	0.062	0.011
UV Absorbance 254 nm	Abs/cm	6/1/2015	0.06	0.011
UV Absorbance 254 nm	Abs/cm	6/8/2015	0.059	0.011
UV Absorbance 254 nm	Abs/cm	6/15/2015	0.058	0.011
UV Absorbance 254 nm	Abs/cm	6/22/2015	0.055	0.011
UV Absorbance 254 nm	Abs/cm	6/29/2015	0.058	0.012
UV Absorbance 254 nm	Abs/cm	7/6/2015	0.055	0.011
UV Absorbance 254 nm	Abs/cm	7/13/2015	0.06	0.011
UV Absorbance 254 nm	Abs/cm	7/20/2015	0.066	0.012
UV Absorbance 254 nm	Abs/cm	7/27/2015	0.065	0.011
UV Absorbance 254 nm	Abs/cm	8/4/2015	0.068	0.011
UV Absorbance 254 nm	Abs/cm	8/10/2015	0.066	0.01
UV Absorbance 254 nm	Abs/cm	8/17/2015	0.063	0.01
UV Absorbance 254 nm	Abs/cm	8/24/2015	0.061	0.01
UV Absorbance 254 nm	Abs/cm	8/31/2015	0.064	0.01
UV Absorbance 254 nm	Abs/cm	9/8/2015	0.111	0.014
UV Absorbance 254 nm	Abs/cm	9/14/2015	0.086	0.014
UV Absorbance 254 nm	Abs/cm	9/21/2015	0.084	0.014
UV Absorbance 254 nm	Abs/cm	9/28/2015	0.093	0.015
UV Absorbance 254 nm	Abs/cm	10/5/2015	0.093	0.014
UV Absorbance 254 nm	Abs/cm	10/13/2015	0.088	0.014
UV Absorbance 254 nm	Abs/cm	10/19/2015	0.11	0.015
UV Absorbance 254 nm	Abs/cm	10/26/2015	0.094	0.015
UV Absorbance 254 nm	Abs/cm	11/2/2015	0.094	0.015
UV Absorbance 254 nm	Abs/cm	11/9/2015	0.104	0.015
UV Absorbance 254 nm	Abs/cm	11/16/2015	0.104	0.014
UV Absorbance 254 nm	Abs/cm	11/23/2015	0.102	0.013

Analysis - Seymour	Units	Date Sampled	Source	Treated
UV Absorbance 254 nm	Abs/cm	11/30/2015	0.1	0.014
UV Absorbance 254 nm	Abs/cm	12/7/2015	0.114	0.011
UV Absorbance 254 nm	Abs/cm	12/14/2015	0.107	0.014
UV Absorbance 254 nm	Abs/cm	12/21/2015	0.091	0.012
Zinc Total	µg/L	2/17/2015	<3	<3
Zinc Total	µg/L	5/5/2015	<3	<3
Zinc Total	µg/L	6/1/2015	<3	<3
Zinc Total	µg/L	10/20/2015	<3	<3
Zinc Total	µg/L	12/7/2015	<3	<3

Coquitlam

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
Alkalinity as CaCO3	mg/L	1/5/2015	1.6	9.7
Alkalinity as CaCO3	mg/L	2/2/2015	1.6	8.9
Alkalinity as CaCO3	mg/L	3/2/2015	1.5	9.4
Alkalinity as CaCO3	mg/L	4/7/2015	1.5	8.1
Alkalinity as CaCO3	mg/L	5/4/2015	1.6	8.1
Alkalinity as CaCO3	mg/L	6/1/2015	1.7	9.2
Alkalinity as CaCO3	mg/L	7/6/2015	1.9	9.3
Alkalinity as CaCO3	mg/L	8/10/2015	2	10.2
Alkalinity as CaCO3	mg/L	9/8/2015	1.9	9.4
Alkalinity as CaCO3	mg/L	10/13/2015	2	10.6
Alkalinity as CaCO3	mg/L	11/9/2015	1.6	9.8
Alkalinity as CaCO3	mg/L	12/7/2015	1.6	8.7
Aluminium Dissolved	µg/L	2/2/2015	98	82
Aluminium Dissolved	µg/L	4/7/2015	78	75
Aluminium Dissolved	µg/L	6/1/2015	79	75
Aluminium Dissolved	µg/L	8/10/2015	40	53
Aluminium Dissolved	µg/L	10/13/2015	59	63
Aluminium Dissolved	µg/L	12/7/2015	86	86
Aluminum Total	µg/L	2/2/2015	153	216
Aluminum Total	µg/L	4/7/2015	120	99
Aluminum Total	µg/L	5/5/2015	112	110
Aluminum Total	µg/L	6/1/2015	102	99
Aluminum Total	µg/L	8/10/2015	61	68
Aluminum Total	µg/L	10/13/2015	82	83
Aluminum Total	µg/L	10/19/2015	81	77
Aluminum Total	µg/L	12/7/2015	110	115
Antimony Total	µg/L	5/5/2015	<0.5	<0.5
Antimony Total	µg/L	6/1/2015	<0.5	<0.5
Antimony Total	µg/L	10/19/2015	<0.5	<0.5
Antimony Total	µg/L	12/7/2015	<0.5	<0.5
Arsenic Total	µg/L	5/5/2015	<0.5	<0.5
Arsenic Total	µg/L	6/1/2015	<0.5	<0.5
Arsenic Total	µg/L	10/19/2015	<0.5	<0.5
Arsenic Total	µg/L	12/7/2015	<0.5	<0.5
Barium Total	µg/L	5/5/2015	2.2	2.3
Barium Total	µg/L	6/1/2015	2.3	2.1
Barium Total	µg/L	10/19/2015	2.8	2.9
Barium Total	µg/L	12/7/2015	2.9	2.9
Boron Total	µg/L	5/5/2015	<10	<10
Boron Total	µg/L	6/1/2015	<10	<10
Boron Total	µg/L	10/19/2015	<10	<10
Boron Total	µg/L	12/7/2015	<10	<10
Bromate	mg/L	2/18/2015		<0.01
Bromate	mg/L	5/19/2015		<0.01
Bromate	mg/L	8/18/2015		<0.01

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
Bromate	mg/L	11/23/2015		<0.01
Bromide	mg/L	2/18/2015		<0.01
Bromide	mg/L	5/19/2015		<0.01
Bromide	mg/L	8/18/2015		<0.01
Bromide	mg/L	11/23/2015		<0.01
Bromodichloromethane	ppb	2/18/2015	<1	<1
Bromodichloromethane	ppb	5/19/2015		<1
Bromodichloromethane	ppb	5/20/2015	<1	
Bromodichloromethane	ppb	8/18/2015	<1	<1
Bromodichloromethane	ppb	11/23/2015	<1	<1
Bromoform	ppb	2/18/2015	<1	<1
Bromoform	ppb	5/19/2015		<1
Bromoform	ppb	5/20/2015	<1	
Bromoform	ppb	8/18/2015	<1	<1
Bromoform	ppb	11/23/2015	<1	<1
Cadmium Total	µg/L	5/5/2015	<0.2	<0.2
Cadmium Total	µg/L	6/1/2015	<0.2	<0.2
Cadmium Total	µg/L	10/19/2015	<0.2	<0.2
Cadmium Total	µg/L	12/7/2015	<0.2	<0.2
Calcium Total	µg/L	1/5/2015	875	843
Calcium Total	µg/L	2/2/2015	850	867
Calcium Total	µg/L	3/2/2015	845	812
Calcium Total	µg/L	4/7/2015	812	818
Calcium Total	µg/L	5/4/2015	831	869
Calcium Total	µg/L	5/5/2015	850	871
Calcium Total	µg/L	6/1/2015	888	793
Calcium Total	µg/L	7/6/2015	872	850
Calcium Total	µg/L	8/10/2015	904	845
Calcium Total	µg/L	9/8/2015	987	964
Calcium Total	µg/L	10/13/2015	956	959
Calcium Total	µg/L	10/19/2015	985	992
Calcium Total	µg/L	11/9/2015	925	916
Calcium Total	µg/L	12/7/2015	881	892
Carbon Organic - Dissolved	mg/L	1/5/2015	2	1.8
Carbon Organic - Dissolved	mg/L	1/12/2015	1.9	1.8
Carbon Organic - Dissolved	mg/L	1/19/2015	1.8	1.7
Carbon Organic - Dissolved	mg/L	1/26/2015	2.1	1.9
Carbon Organic - Dissolved	mg/L	2/2/2015	1.9	1.7
Carbon Organic - Dissolved	mg/L	2/10/2015	1.8	1.7
Carbon Organic - Dissolved	mg/L	2/16/2015	1.8	1.7
Carbon Organic - Dissolved	mg/L	2/23/2015	1.8	1.7
Carbon Organic - Dissolved	mg/L	3/2/2015	1.7	1.6
Carbon Organic - Dissolved	mg/L	3/9/2015	1.7	1.6
Carbon Organic - Dissolved	mg/L	3/16/2015	1.8	1.8
Carbon Organic - Dissolved	mg/L	3/23/2015	1.9	1.8

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
Carbon Organic - Dissolved	mg/L	3/30/2015	2.1	2
Carbon Organic - Dissolved	mg/L	4/7/2015	1.7	1.6
Carbon Organic - Dissolved	mg/L	4/13/2015	1.9	1.8
Carbon Organic - Dissolved	mg/L	4/20/2015	1.8	1.8
Carbon Organic - Dissolved	mg/L	4/27/2015	1.9	1.8
Carbon Organic - Dissolved	mg/L	5/4/2015	1.8	1.7
Carbon Organic - Dissolved	mg/L	5/11/2015	1.8	1.7
Carbon Organic - Dissolved	mg/L	5/19/2015	1.8	1.7
Carbon Organic - Dissolved	mg/L	5/25/2015	1.7	1.7
Carbon Organic - Dissolved	mg/L	6/1/2015	1.8	1.7
Carbon Organic - Dissolved	mg/L	6/8/2015	1.7	1.7
Carbon Organic - Dissolved	mg/L	6/15/2015	1.7	1.6
Carbon Organic - Dissolved	mg/L	6/22/2015	1.7	1.6
Carbon Organic - Dissolved	mg/L	6/29/2015	1.6	1.6
Carbon Organic - Dissolved	mg/L	7/6/2015	1.6	1.5
Carbon Organic - Dissolved	mg/L	7/13/2015	1.5	1.5
Carbon Organic - Dissolved	mg/L	7/20/2015	1.5	1.4
Carbon Organic - Dissolved	mg/L	7/27/2015	1.4	1.4
Carbon Organic - Dissolved	mg/L	8/4/2015	1.4	1.4
Carbon Organic - Dissolved	mg/L	8/10/2015	1.4	1.4
Carbon Organic - Dissolved	mg/L	8/17/2015	1.4	1.4
Carbon Organic - Dissolved	mg/L	8/24/2015	1.4	1.3
Carbon Organic - Dissolved	mg/L	8/31/2015		1.3
Carbon Organic - Dissolved	mg/L	9/8/2015	1.7	1.7
Carbon Organic - Dissolved	mg/L	9/14/2015	1.8	1.7
Carbon Organic - Dissolved	mg/L	9/21/2015	1.9	1.9
Carbon Organic - Dissolved	mg/L	9/28/2015	1.8	1.7
Carbon Organic - Dissolved	mg/L	10/5/2015	1.7	1.6
Carbon Organic - Dissolved	mg/L	10/13/2015	1.9	1.8
Carbon Organic - Dissolved	mg/L	10/19/2015	1.7	1.7
Carbon Organic - Dissolved	mg/L	10/26/2015	1.7	1.7
Carbon Organic - Dissolved	mg/L	11/2/2015	2.2	2.3
Carbon Organic - Dissolved	mg/L	11/9/2015	2.3	2.2
Carbon Organic - Dissolved	mg/L	11/16/2015	2.1	1.9
Carbon Organic - Dissolved	mg/L	11/23/2015	1.9	1.8
Carbon Organic - Dissolved	mg/L	11/30/2015	1.9	1.8
Carbon Organic - Dissolved	mg/L	12/7/2015	2.2	2.1
Carbon Organic - Dissolved	mg/L	12/14/2015	1.8	1.7
Carbon Organic - Dissolved	mg/L	12/21/2015	1.9	1.8
Carbon Organic - Total	mg/L	1/2/2015	2.34	
Carbon Organic - Total	mg/L	1/5/2015	2.5	1.8
Carbon Organic - Total	mg/L	1/7/2015	2.52	
Carbon Organic - Total	mg/L	1/8/2015	2.32	
Carbon Organic - Total	mg/L	1/9/2015	2.34	
Carbon Organic - Total	mg/L	1/12/2015	2.18	1.8

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
Carbon Organic - Total	mg/L	1/15/2015	2.22	
Carbon Organic - Total	mg/L	1/19/2015	2.2	1.7
Carbon Organic - Total	mg/L	1/20/2015	2.15	
Carbon Organic - Total	mg/L	1/21/2015	2.33	
Carbon Organic - Total	mg/L	1/22/2015	2.22	
Carbon Organic - Total	mg/L	1/23/2015	2.22	
Carbon Organic - Total	mg/L	1/26/2015	2.6	2
Carbon Organic - Total	mg/L	1/27/2015	2.47	
Carbon Organic - Total	mg/L	1/28/2015	2.36	
Carbon Organic - Total	mg/L	1/29/2015	2.25	
Carbon Organic - Total	mg/L	1/30/2015	2.12	
Carbon Organic - Total	mg/L	2/2/2015	2.15	1.8
Carbon Organic - Total	mg/L	2/4/2015	2.19	
Carbon Organic - Total	mg/L	2/6/2015	2.08	
Carbon Organic - Total	mg/L	2/10/2015	2.03	1.7
Carbon Organic - Total	mg/L	2/11/2015	2.34	
Carbon Organic - Total	mg/L	2/13/2015	2.15	
Carbon Organic - Total	mg/L	2/16/2015	2.16	1.7
Carbon Organic - Total	mg/L	2/18/2015	2.14	
Carbon Organic - Total	mg/L	2/20/2015	2.16	
Carbon Organic - Total	mg/L	2/23/2015	1.8	1.7
Carbon Organic - Total	mg/L	2/24/2015	2.17	
Carbon Organic - Total	mg/L	2/27/2015	2.24	
Carbon Organic - Total	mg/L	3/2/2015	1.8	1.7
Carbon Organic - Total	mg/L	3/9/2015	1.7	1.6
Carbon Organic - Total	mg/L	3/16/2015	1.9	1.8
Carbon Organic - Total	mg/L	3/23/2015	1.9	1.9
Carbon Organic - Total	mg/L	3/30/2015	2.1	2
Carbon Organic - Total	mg/L	3/31/2015	2.23	
Carbon Organic - Total	mg/L	4/1/2015	2.18	
Carbon Organic - Total	mg/L	4/7/2015	2.3	1.6
Carbon Organic - Total	mg/L	4/10/2015	2.3	
Carbon Organic - Total	mg/L	4/13/2015	1.9	1.8
Carbon Organic - Total	mg/L	4/14/2015	2.48	
Carbon Organic - Total	mg/L	4/20/2015	1.8	1.8
Carbon Organic - Total	mg/L	4/21/2015	2.34	
Carbon Organic - Total	mg/L	4/24/2015	2.4	
Carbon Organic - Total	mg/L	4/27/2015	1.9	1.8
Carbon Organic - Total	mg/L	4/29/2015	2.18	
Carbon Organic - Total	mg/L	5/1/2015	2.18	
Carbon Organic - Total	mg/L	5/4/2015	2.34	1.8
Carbon Organic - Total	mg/L	5/6/2015	2.28	
Carbon Organic - Total	mg/L	5/8/2015	2.25	
Carbon Organic - Total	mg/L	5/11/2015	2.32	1.8
Carbon Organic - Total	mg/L	5/14/2015	2.25	

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
Carbon Organic - Total	mg/L	5/19/2015	1.8	1.7
Carbon Organic - Total	mg/L	5/20/2015	2.2	
Carbon Organic - Total	mg/L	5/22/2015	2.28	
Carbon Organic - Total	mg/L	5/25/2015	2.25	1.7
Carbon Organic - Total	mg/L	5/27/2015	2.26	
Carbon Organic - Total	mg/L	5/29/2015	2.2	
Carbon Organic - Total	mg/L	6/1/2015	1.7	1.7
Carbon Organic - Total	mg/L	6/2/2015	2.22	
Carbon Organic - Total	mg/L	6/8/2015	2.24	1.7
Carbon Organic - Total	mg/L	6/12/2015	2.3	
Carbon Organic - Total	mg/L	6/15/2015	2.14	1.7
Carbon Organic - Total	mg/L	6/22/2015	2.08	1.6
Carbon Organic - Total	mg/L	6/26/2015	2.12	
Carbon Organic - Total	mg/L	6/29/2015	1.6	1.6
Carbon Organic - Total	mg/L	6/30/2015	2.18	
Carbon Organic - Total	mg/L	7/2/2015	2.28	
Carbon Organic - Total	mg/L	7/6/2015	2.15	1.5
Carbon Organic - Total	mg/L	7/8/2015	2.08	
Carbon Organic - Total	mg/L	7/9/2015	2.5	
Carbon Organic - Total	mg/L	7/10/2015	2.09	
Carbon Organic - Total	mg/L	7/13/2015	2.12	1.5
Carbon Organic - Total	mg/L	7/15/2015	2.02	
Carbon Organic - Total	mg/L	7/16/2015	1.99	
Carbon Organic - Total	mg/L	7/20/2015	1.5	1.4
Carbon Organic - Total	mg/L	7/21/2015	1.93	
Carbon Organic - Total	mg/L	7/22/2015	2.03	
Carbon Organic - Total	mg/L	7/23/2015	2.03	
Carbon Organic - Total	mg/L	7/27/2015	1.4	1.4
Carbon Organic - Total	mg/L	7/28/2015	2	
Carbon Organic - Total	mg/L	7/29/2015	2.25	
Carbon Organic - Total	mg/L	8/4/2015	1.4	1.3
Carbon Organic - Total	mg/L	8/10/2015	1.4	1.4
Carbon Organic - Total	mg/L	8/17/2015	1.4	1.3
Carbon Organic - Total	mg/L	8/24/2015	1.4	1.4
Carbon Organic - Total	mg/L	8/31/2015		1.4
Carbon Organic - Total	mg/L	9/8/2015	1.7	1.7
Carbon Organic - Total	mg/L	9/14/2015	1.8	1.7
Carbon Organic - Total	mg/L	9/21/2015	1.9	1.9
Carbon Organic - Total	mg/L	9/28/2015	1.8	1.7
Carbon Organic - Total	mg/L	10/5/2015	1.8	1.7
Carbon Organic - Total	mg/L	10/13/2015	1.9	1.8
Carbon Organic - Total	mg/L	10/19/2015	1.8	1.7
Carbon Organic - Total	mg/L	10/26/2015	1.7	1.6
Carbon Organic - Total	mg/L	11/2/2015	2.2	2.3
Carbon Organic - Total	mg/L	11/9/2015	2.4	2.2

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
Carbon Organic - Total	mg/L	11/16/2015	2.1	1.9
Carbon Organic - Total	mg/L	11/23/2015	1.9	1.8
Carbon Organic - Total	mg/L	11/30/2015	1.9	1.8
Carbon Organic - Total	mg/L	12/7/2015	2.2	2.1
Carbon Organic - Total	mg/L	12/14/2015	1.8	1.7
Carbon Organic - Total	mg/L	12/21/2015	1.9	1.8
Chlorate	mg/L	2/18/2015		<0.01
Chlorate	mg/L	5/19/2015		<0.01
Chlorate	mg/L	8/18/2015		<0.01
Chlorate	mg/L	11/23/2015		<0.01
Chloride	mg/L	1/5/2015	0.6	1.8
Chloride	mg/L	2/2/2015	<0.5	2
Chloride	mg/L	2/18/2015		1.7
Chloride	mg/L	3/2/2015	0.5	2
Chloride	mg/L	4/7/2015	<0.5	2
Chloride	mg/L	5/4/2015	<0.5	1.9
Chloride	mg/L	5/19/2015		2
Chloride	mg/L	6/1/2015	<0.5	2
Chloride	mg/L	7/6/2015	<0.5	2
Chloride	mg/L	8/10/2015	<0.5	1.9
Chloride	mg/L	8/18/2015		2.1
Chloride	mg/L	9/8/2015	0.6	2.3
Chloride	mg/L	10/13/2015	0.5	2.2
Chloride	mg/L	11/9/2015	0.6	2.4
Chloride	mg/L	11/23/2015		2.2
Chloride	mg/L	12/7/2015	0.5	2.1
Chlorine Free	mg/L	1/1/2015		1.2
Chlorine Free	mg/L	1/2/2015		1.2
Chlorine Free	mg/L	1/3/2015		1.1
Chlorine Free	mg/L	1/4/2015		1.2
Chlorine Free	mg/L	1/5/2015		1.34
Chlorine Free	mg/L	1/6/2015		1.4
Chlorine Free	mg/L	1/7/2015		1.35
Chlorine Free	mg/L	1/8/2015		1.41
Chlorine Free	mg/L	1/9/2015		1.1
Chlorine Free	mg/L	1/10/2015		1.2
Chlorine Free	mg/L	1/11/2015		1.4
Chlorine Free	mg/L	1/12/2015		1.2
Chlorine Free	mg/L	1/13/2015		1.2
Chlorine Free	mg/L	1/14/2015		1.2
Chlorine Free	mg/L	1/15/2015		1.4
Chlorine Free	mg/L	1/16/2015		1.3
Chlorine Free	mg/L	1/17/2015		1.1
Chlorine Free	mg/L	1/18/2015		1
Chlorine Free	mg/L	1/19/2015		1.2

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
Chlorine Free	mg/L	1/20/2015		1.2
Chlorine Free	mg/L	1/21/2015		1.14
Chlorine Free	mg/L	1/22/2015		1.21
Chlorine Free	mg/L	1/23/2015		1.3
Chlorine Free	mg/L	1/24/2015		1.4
Chlorine Free	mg/L	1/25/2015		1.8
Chlorine Free	mg/L	1/26/2015		1.4
Chlorine Free	mg/L	1/27/2015		1.45
Chlorine Free	mg/L	1/28/2015		1.6
Chlorine Free	mg/L	1/29/2015		1.22
Chlorine Free	mg/L	1/30/2015		1.34
Chlorine Free	mg/L	1/31/2015		1.4
Chlorine Free	mg/L	2/1/2015		1.3
Chlorine Free	mg/L	2/2/2015		1.3
Chlorine Free	mg/L	2/3/2015		1.2
Chlorine Free	mg/L	2/4/2015		1.8
Chlorine Free	mg/L	2/5/2015		1.3
Chlorine Free	mg/L	2/6/2015		1.3
Chlorine Free	mg/L	2/7/2015		1.4
Chlorine Free	mg/L	2/8/2015		1.2
Chlorine Free	mg/L	2/9/2015		1.3
Chlorine Free	mg/L	2/10/2015		1.3
Chlorine Free	mg/L	2/11/2015		1.22
Chlorine Free	mg/L	2/12/2015		1.4
Chlorine Free	mg/L	2/13/2015		1.26
Chlorine Free	mg/L	2/14/2015		1.4
Chlorine Free	mg/L	2/15/2015		1.5
Chlorine Free	mg/L	2/16/2015		1.4
Chlorine Free	mg/L	2/17/2015		1.3
Chlorine Free	mg/L	2/18/2015		1.2
Chlorine Free	mg/L	2/19/2015		1.3
Chlorine Free	mg/L	2/20/2015		1.25
Chlorine Free	mg/L	2/21/2015		1.1
Chlorine Free	mg/L	2/22/2015		1.3
Chlorine Free	mg/L	2/23/2015		1.3
Chlorine Free	mg/L	2/24/2015		1.4
Chlorine Free	mg/L	2/25/2015		1.3
Chlorine Free	mg/L	2/26/2015		1.2
Chlorine Free	mg/L	2/27/2015		1.3
Chlorine Free	mg/L	2/28/2015		1.4
Chlorine Free	mg/L	3/1/2015		1.4
Chlorine Free	mg/L	3/2/2015		1.4
Chlorine Free	mg/L	3/3/2015		1.4
Chlorine Free	mg/L	3/4/2015		1.2
Chlorine Free	mg/L	3/5/2015		1.4

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
Chlorine Free	mg/L	3/6/2015		1.3
Chlorine Free	mg/L	3/7/2015		1.3
Chlorine Free	mg/L	3/8/2015		1.4
Chlorine Free	mg/L	3/9/2015		1.4
Chlorine Free	mg/L	3/10/2015		1.3
Chlorine Free	mg/L	3/11/2015		1.3
Chlorine Free	mg/L	3/12/2015		1.4
Chlorine Free	mg/L	3/13/2015		1.4
Chlorine Free	mg/L	3/14/2015		1.3
Chlorine Free	mg/L	3/15/2015		1.2
Chlorine Free	mg/L	3/16/2015		1.5
Chlorine Free	mg/L	3/17/2015		1.4
Chlorine Free	mg/L	3/18/2015		1.4
Chlorine Free	mg/L	3/19/2015		1.4
Chlorine Free	mg/L	3/20/2015		1.3
Chlorine Free	mg/L	3/21/2015		1.3
Chlorine Free	mg/L	3/22/2015		1.4
Chlorine Free	mg/L	3/23/2015		1.4
Chlorine Free	mg/L	3/24/2015		1.3
Chlorine Free	mg/L	3/25/2015		1.3
Chlorine Free	mg/L	3/26/2015		1.3
Chlorine Free	mg/L	3/27/2015		1.4
Chlorine Free	mg/L	3/28/2015		1.5
Chlorine Free	mg/L	3/29/2015		1.2
Chlorine Free	mg/L	3/30/2015		1.2
Chlorine Free	mg/L	3/31/2015		1.36
Chlorine Free	mg/L	4/1/2015		1.4
Chlorine Free	mg/L	4/2/2015		1.4
Chlorine Free	mg/L	4/3/2015		1.3
Chlorine Free	mg/L	4/4/2015		1.3
Chlorine Free	mg/L	4/5/2015		1.3
Chlorine Free	mg/L	4/6/2015		1.4
Chlorine Free	mg/L	4/7/2015		1.4
Chlorine Free	mg/L	4/8/2015		1.2
Chlorine Free	mg/L	4/9/2015		1.1
Chlorine Free	mg/L	4/10/2015		1.2
Chlorine Free	mg/L	4/11/2015		1.2
Chlorine Free	mg/L	4/12/2015		1.2
Chlorine Free	mg/L	4/13/2015		1.2
Chlorine Free	mg/L	4/14/2015		1.17
Chlorine Free	mg/L	4/15/2015		1.3
Chlorine Free	mg/L	4/16/2015		1.2
Chlorine Free	mg/L	4/17/2015		1.3
Chlorine Free	mg/L	4/18/2015		1.3
Chlorine Free	mg/L	4/19/2015		1.2

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
Chlorine Free	mg/L	4/20/2015		1.2
Chlorine Free	mg/L	4/21/2015		1.2
Chlorine Free	mg/L	4/22/2015		1.2
Chlorine Free	mg/L	4/23/2015		1.1
Chlorine Free	mg/L	4/24/2015		1.2
Chlorine Free	mg/L	4/25/2015		1.4
Chlorine Free	mg/L	4/26/2015		1.2
Chlorine Free	mg/L	4/27/2015		1.3
Chlorine Free	mg/L	4/28/2015		1.3
Chlorine Free	mg/L	4/29/2015		1.2
Chlorine Free	mg/L	4/30/2015		1.1
Chlorine Free	mg/L	5/1/2015		1.22
Chlorine Free	mg/L	5/2/2015		1.4
Chlorine Free	mg/L	5/3/2015		1.4
Chlorine Free	mg/L	5/4/2015		1.32
Chlorine Free	mg/L	5/5/2015		1.4
Chlorine Free	mg/L	5/6/2015		1.16
Chlorine Free	mg/L	5/7/2015		1.5
Chlorine Free	mg/L	5/8/2015		1.3
Chlorine Free	mg/L	5/9/2015		1.3
Chlorine Free	mg/L	5/10/2015		1.3
Chlorine Free	mg/L	5/11/2015		1.3
Chlorine Free	mg/L	5/12/2015		1.2
Chlorine Free	mg/L	5/13/2015		1.3
Chlorine Free	mg/L	5/14/2015		1.4
Chlorine Free	mg/L	5/15/2015		1.2
Chlorine Free	mg/L	5/16/2015		1.4
Chlorine Free	mg/L	5/17/2015		1.4
Chlorine Free	mg/L	5/18/2015		1.3
Chlorine Free	mg/L	5/19/2015		1.2
Chlorine Free	mg/L	5/20/2015		1.32
Chlorine Free	mg/L	5/21/2015		1.3
Chlorine Free	mg/L	5/22/2015		1.3
Chlorine Free	mg/L	5/23/2015		1.2
Chlorine Free	mg/L	5/24/2015		1.3
Chlorine Free	mg/L	5/25/2015		1.2
Chlorine Free	mg/L	5/26/2015		1.2
Chlorine Free	mg/L	5/27/2015		1.2
Chlorine Free	mg/L	5/28/2015		1.3
Chlorine Free	mg/L	5/29/2015		1.26
Chlorine Free	mg/L	5/30/2015		1.3
Chlorine Free	mg/L	5/31/2015		1.2
Chlorine Free	mg/L	6/1/2015		1.4
Chlorine Free	mg/L	6/2/2015		1.24
Chlorine Free	mg/L	6/3/2015		1.3

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
Chlorine Free	mg/L	6/4/2015		1.3
Chlorine Free	mg/L	6/5/2015		1.4
Chlorine Free	mg/L	6/6/2015		1.4
Chlorine Free	mg/L	6/7/2015		1.4
Chlorine Free	mg/L	6/8/2015		1.2
Chlorine Free	mg/L	6/9/2015		1.3
Chlorine Free	mg/L	6/10/2015		1.3
Chlorine Free	mg/L	6/11/2015		1.3
Chlorine Free	mg/L	6/12/2015		1.25
Chlorine Free	mg/L	6/13/2015		1.3
Chlorine Free	mg/L	6/14/2015		1.3
Chlorine Free	mg/L	6/15/2015		1.3
Chlorine Free	mg/L	6/16/2015		1.3
Chlorine Free	mg/L	6/17/2015		1.3
Chlorine Free	mg/L	6/18/2015		1.3
Chlorine Free	mg/L	6/19/2015		1.3
Chlorine Free	mg/L	6/20/2015		1.3
Chlorine Free	mg/L	6/21/2015		1.3
Chlorine Free	mg/L	6/22/2015		1.31
Chlorine Free	mg/L	6/23/2015		1.2
Chlorine Free	mg/L	6/24/2015		1.3
Chlorine Free	mg/L	6/25/2015		1.2
Chlorine Free	mg/L	6/26/2015		1.2
Chlorine Free	mg/L	6/27/2015		1.2
Chlorine Free	mg/L	6/28/2015		1.1
Chlorine Free	mg/L	6/29/2015		1.3
Chlorine Free	mg/L	6/30/2015		1.4
Chlorine Free	mg/L	7/1/2015		1.5
Chlorine Free	mg/L	7/2/2015		1.5
Chlorine Free	mg/L	7/3/2015		1.3
Chlorine Free	mg/L	7/4/2015		1.4
Chlorine Free	mg/L	7/5/2015		1.4
Chlorine Free	mg/L	7/6/2015		1.45
Chlorine Free	mg/L	7/7/2015		1.2
Chlorine Free	mg/L	7/8/2015		1.6
Chlorine Free	mg/L	7/9/2015		1.51
Chlorine Free	mg/L	7/10/2015		1.38
Chlorine Free	mg/L	7/11/2015		1.4
Chlorine Free	mg/L	7/12/2015		1.4
Chlorine Free	mg/L	7/13/2015		1.43
Chlorine Free	mg/L	7/14/2015		1.4
Chlorine Free	mg/L	7/15/2015		1.3
Chlorine Free	mg/L	7/16/2015		1.4
Chlorine Free	mg/L	7/17/2015		1.3
Chlorine Free	mg/L	7/18/2015		1.4

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
Chlorine Free	mg/L	7/19/2015		1.4
Chlorine Free	mg/L	7/20/2015		1.6
Chlorine Free	mg/L	7/21/2015		1.38
Chlorine Free	mg/L	7/22/2015		1.6
Chlorine Free	mg/L	7/23/2015		1.47
Chlorine Free	mg/L	7/24/2015		1.3
Chlorine Free	mg/L	7/25/2015		1.3
Chlorine Free	mg/L	7/26/2015		1.4
Chlorine Free	mg/L	7/27/2015		1.3
Chlorine Free	mg/L	7/28/2015		1.45
Chlorine Free	mg/L	7/29/2015		1.5
Chlorine Free	mg/L	7/30/2015		1.2
Chlorine Free	mg/L	7/31/2015		1.4
Chlorine Free	mg/L	8/1/2015		1.4
Chlorine Free	mg/L	8/2/2015		1.4
Chlorine Free	mg/L	8/3/2015		1.4
Chlorine Free	mg/L	8/4/2015		1.5
Chlorine Free	mg/L	8/5/2015		1.4
Chlorine Free	mg/L	8/6/2015		1.4
Chlorine Free	mg/L	8/7/2015		1.6
Chlorine Free	mg/L	8/8/2015		1.4
Chlorine Free	mg/L	8/9/2015		1.3
Chlorine Free	mg/L	8/10/2015		1.4
Chlorine Free	mg/L	8/11/2015		1.4
Chlorine Free	mg/L	8/12/2015		1.5
Chlorine Free	mg/L	8/13/2015		1.5
Chlorine Free	mg/L	8/14/2015		1.4
Chlorine Free	mg/L	8/15/2015		1.5
Chlorine Free	mg/L	8/16/2015		1.4
Chlorine Free	mg/L	8/17/2015		1.6
Chlorine Free	mg/L	8/18/2015		1.5
Chlorine Free	mg/L	8/19/2015		1.4
Chlorine Free	mg/L	8/20/2015		1.5
Chlorine Free	mg/L	8/21/2015		1.3
Chlorine Free	mg/L	8/22/2015		1.4
Chlorine Free	mg/L	8/23/2015		1.4
Chlorine Free	mg/L	8/24/2015		1.4
Chlorine Free	mg/L	8/25/2015		1.4
Chlorine Free	mg/L	8/26/2015		1.4
Chlorine Free	mg/L	8/27/2015		1.4
Chlorine Free	mg/L	8/28/2015		1.4
Chlorine Free	mg/L	8/29/2015		1.3
Chlorine Free	mg/L	8/30/2015		1.5
Chlorine Free	mg/L	8/31/2015		1.5
Chlorine Free	mg/L	9/1/2015		1.5

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
Chlorine Free	mg/L	9/2/2015		1.4
Chlorine Free	mg/L	9/3/2015		1.4
Chlorine Free	mg/L	9/4/2015		1.4
Chlorine Free	mg/L	9/5/2015		1.6
Chlorine Free	mg/L	9/6/2015		1.6
Chlorine Free	mg/L	9/7/2015		1.6
Chlorine Free	mg/L	9/8/2015		1.4
Chlorine Free	mg/L	9/9/2015		1.5
Chlorine Free	mg/L	9/10/2015		1.4
Chlorine Free	mg/L	9/11/2015		1.5
Chlorine Free	mg/L	9/12/2015		1.6
Chlorine Free	mg/L	9/13/2015		1.6
Chlorine Free	mg/L	9/14/2015		1.5
Chlorine Free	mg/L	9/15/2015		1.6
Chlorine Free	mg/L	9/16/2015		1.2
Chlorine Free	mg/L	9/17/2015		1.4
Chlorine Free	mg/L	9/18/2015		1.4
Chlorine Free	mg/L	9/19/2015		1.3
Chlorine Free	mg/L	9/20/2015		1.4
Chlorine Free	mg/L	9/21/2015		1.4
Chlorine Free	mg/L	9/22/2015		1.2
Chlorine Free	mg/L	9/23/2015		1.4
Chlorine Free	mg/L	9/24/2015		1.5
Chlorine Free	mg/L	9/25/2015		1.2
Chlorine Free	mg/L	9/26/2015		1.2
Chlorine Free	mg/L	9/27/2015		1.5
Chlorine Free	mg/L	9/28/2015		1.4
Chlorine Free	mg/L	9/29/2015		1.6
Chlorine Free	mg/L	9/30/2015		1.5
Chlorine Free	mg/L	10/1/2015		1.6
Chlorine Free	mg/L	10/2/2015		1.4
Chlorine Free	mg/L	10/3/2015		1.6
Chlorine Free	mg/L	10/4/2015		1.4
Chlorine Free	mg/L	10/5/2015		1.5
Chlorine Free	mg/L	10/6/2015		1.4
Chlorine Free	mg/L	10/7/2015		1.3
Chlorine Free	mg/L	10/8/2015		1.5
Chlorine Free	mg/L	10/9/2015		1.3
Chlorine Free	mg/L	10/10/2015		1.4
Chlorine Free	mg/L	10/11/2015		1.3
Chlorine Free	mg/L	10/12/2015		1.3
Chlorine Free	mg/L	10/13/2015		1.4
Chlorine Free	mg/L	10/14/2015		1.4
Chlorine Free	mg/L	10/15/2015		1.4
Chlorine Free	mg/L	10/16/2015		1.1

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
Chlorine Free	mg/L	10/17/2015		1.3
Chlorine Free	mg/L	10/18/2015		1.2
Chlorine Free	mg/L	10/19/2015		1.3
Chlorine Free	mg/L	10/20/2015		1.3
Chlorine Free	mg/L	10/21/2015		1.3
Chlorine Free	mg/L	10/22/2015		1.3
Chlorine Free	mg/L	10/23/2015		1.2
Chlorine Free	mg/L	10/24/2015		1.4
Chlorine Free	mg/L	10/25/2015		1.4
Chlorine Free	mg/L	10/26/2015		1.2
Chlorine Free	mg/L	10/27/2015		1.2
Chlorine Free	mg/L	10/28/2015		1.2
Chlorine Free	mg/L	10/29/2015		1.2
Chlorine Free	mg/L	10/30/2015		1.2
Chlorine Free	mg/L	10/31/2015		1.7
Chlorine Free	mg/L	11/1/2015		1.4
Chlorine Free	mg/L	11/2/2015		1.5
Chlorine Free	mg/L	11/3/2015		1.4
Chlorine Free	mg/L	11/4/2015		1.5
Chlorine Free	mg/L	11/5/2015		1.2
Chlorine Free	mg/L	11/6/2015		1.3
Chlorine Free	mg/L	11/7/2015		1.5
Chlorine Free	mg/L	11/8/2015		1.6
Chlorine Free	mg/L	11/9/2015		1.9
Chlorine Free	mg/L	11/10/2015		1.3
Chlorine Free	mg/L	11/11/2015		1.7
Chlorine Free	mg/L	11/12/2015		1.4
Chlorine Free	mg/L	11/13/2015		1.3
Chlorine Free	mg/L	11/14/2015		1.7
Chlorine Free	mg/L	11/15/2015		1.8
Chlorine Free	mg/L	11/16/2015		1.6
Chlorine Free	mg/L	11/17/2015		1.4
Chlorine Free	mg/L	11/18/2015		1.4
Chlorine Free	mg/L	11/19/2015		1.5
Chlorine Free	mg/L	11/20/2015		1.5
Chlorine Free	mg/L	11/21/2015		1.5
Chlorine Free	mg/L	11/22/2015		1.4
Chlorine Free	mg/L	11/23/2015		1.2
Chlorine Free	mg/L	11/24/2015		1.4
Chlorine Free	mg/L	11/25/2015		1.4
Chlorine Free	mg/L	11/26/2015		1.4
Chlorine Free	mg/L	11/27/2015		1.1
Chlorine Free	mg/L	11/28/2015		1.4
Chlorine Free	mg/L	11/29/2015		1.4
Chlorine Free	mg/L	11/30/2015		1.3

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
Chlorine Free	mg/L	12/1/2015		1.3
Chlorine Free	mg/L	12/2/2015		1.2
Chlorine Free	mg/L	12/3/2015		1.4
Chlorine Free	mg/L	12/4/2015		1.3
Chlorine Free	mg/L	12/5/2015		1.6
Chlorine Free	mg/L	12/6/2015		1.4
Chlorine Free	mg/L	12/7/2015		1.4
Chlorine Free	mg/L	12/8/2015		1.4
Chlorine Free	mg/L	12/9/2015		1.6
Chlorine Free	mg/L	12/10/2015		1.2
Chlorine Free	mg/L	12/11/2015		1.4
Chlorine Free	mg/L	12/12/2015		1.3
Chlorine Free	mg/L	12/13/2015		1.4
Chlorine Free	mg/L	12/14/2015		1.4
Chlorine Free	mg/L	12/15/2015		1.6
Chlorine Free	mg/L	12/16/2015		1.5
Chlorine Free	mg/L	12/17/2015		1.5
Chlorine Free	mg/L	12/18/2015		1.3
Chlorine Free	mg/L	12/19/2015		1.3
Chlorine Free	mg/L	12/20/2015		1.3
Chlorine Free	mg/L	12/21/2015		1.4
Chlorine Free	mg/L	12/22/2015		1.2
Chlorine Free	mg/L	12/23/2015		1.3
Chlorine Free	mg/L	12/24/2015		1.2
Chlorine Free	mg/L	12/26/2015		1.4
Chlorine Free	mg/L	12/27/2015		1.2
Chlorine Free	mg/L	12/28/2015		1.1
Chlorine Free	mg/L	12/29/2015		1.3
Chlorine Free	mg/L	12/30/2015		1.3
Chlorine Free	mg/L	12/31/2015		1.2
Chlorine Total	mg/L	1/1/2015		1.3
Chlorine Total	mg/L	1/2/2015		1.3
Chlorine Total	mg/L	1/3/2015		1.2
Chlorine Total	mg/L	1/4/2015		1.3
Chlorine Total	mg/L	1/5/2015		1.2
Chlorine Total	mg/L	1/6/2015		1.5
Chlorine Total	mg/L	1/7/2015		1.4
Chlorine Total	mg/L	1/8/2015		1.3
Chlorine Total	mg/L	1/9/2015		1.2
Chlorine Total	mg/L	1/10/2015		1.2
Chlorine Total	mg/L	1/11/2015		1.5
Chlorine Total	mg/L	1/12/2015		1.2
Chlorine Total	mg/L	1/13/2015		1.2
Chlorine Total	mg/L	1/14/2015		1.2
Chlorine Total	mg/L	1/15/2015		1.4

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
Chlorine Total	mg/L	1/16/2015		1.3
Chlorine Total	mg/L	1/17/2015		1.2
Chlorine Total	mg/L	1/18/2015		1.3
Chlorine Total	mg/L	1/19/2015		1.2
Chlorine Total	mg/L	1/20/2015		1.2
Chlorine Total	mg/L	1/21/2015		1.1
Chlorine Total	mg/L	1/22/2015		1.2
Chlorine Total	mg/L	1/23/2015		1.3
Chlorine Total	mg/L	1/24/2015		1.6
Chlorine Total	mg/L	1/25/2015		2.2
Chlorine Total	mg/L	1/26/2015		1.4
Chlorine Total	mg/L	1/27/2015		1.4
Chlorine Total	mg/L	1/28/2015		1.7
Chlorine Total	mg/L	1/29/2015		1.4
Chlorine Total	mg/L	1/30/2015		1.4
Chlorine Total	mg/L	1/31/2015		1.4
Chlorine Total	mg/L	2/1/2015		1.4
Chlorine Total	mg/L	2/2/2015		1.4
Chlorine Total	mg/L	2/3/2015		1.2
Chlorine Total	mg/L	2/4/2015		1.8
Chlorine Total	mg/L	2/5/2015		1.3
Chlorine Total	mg/L	2/6/2015		1.3
Chlorine Total	mg/L	2/7/2015		1.4
Chlorine Total	mg/L	2/8/2015		1.2
Chlorine Total	mg/L	2/9/2015		1.3
Chlorine Total	mg/L	2/10/2015		1.4
Chlorine Total	mg/L	2/11/2015		1.2
Chlorine Total	mg/L	2/12/2015		1.4
Chlorine Total	mg/L	2/13/2015		1.4
Chlorine Total	mg/L	2/14/2015		1.4
Chlorine Total	mg/L	2/15/2015		1.6
Chlorine Total	mg/L	2/16/2015		1.4
Chlorine Total	mg/L	2/17/2015		1.4
Chlorine Total	mg/L	2/18/2015		1.2
Chlorine Total	mg/L	2/19/2015		1.3
Chlorine Total	mg/L	2/20/2015		1.3
Chlorine Total	mg/L	2/21/2015		1.2
Chlorine Total	mg/L	2/22/2015		1.4
Chlorine Total	mg/L	2/23/2015		1.4
Chlorine Total	mg/L	2/24/2015		1.4
Chlorine Total	mg/L	2/25/2015		1.4
Chlorine Total	mg/L	2/26/2015		1.2
Chlorine Total	mg/L	2/27/2015		1.3
Chlorine Total	mg/L	2/28/2015		1.4
Chlorine Total	mg/L	3/1/2015		1.6

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
Chlorine Total	mg/L	3/2/2015		1.5
Chlorine Total	mg/L	3/3/2015		1.4
Chlorine Total	mg/L	3/4/2015		1.2
Chlorine Total	mg/L	3/5/2015		1.4
Chlorine Total	mg/L	3/6/2015		1.4
Chlorine Total	mg/L	3/7/2015		1.4
Chlorine Total	mg/L	3/8/2015		1.5
Chlorine Total	mg/L	3/9/2015		1.4
Chlorine Total	mg/L	3/10/2015		1.3
Chlorine Total	mg/L	3/11/2015		1.3
Chlorine Total	mg/L	3/12/2015		1.4
Chlorine Total	mg/L	3/13/2015		1.4
Chlorine Total	mg/L	3/14/2015		1.4
Chlorine Total	mg/L	3/15/2015		1.3
Chlorine Total	mg/L	3/16/2015		1.5
Chlorine Total	mg/L	3/17/2015		1.4
Chlorine Total	mg/L	3/18/2015		1.5
Chlorine Total	mg/L	3/19/2015		1.4
Chlorine Total	mg/L	3/20/2015		1.3
Chlorine Total	mg/L	3/21/2015		1.4
Chlorine Total	mg/L	3/22/2015		1.5
Chlorine Total	mg/L	3/23/2015		1.4
Chlorine Total	mg/L	3/24/2015		1.4
Chlorine Total	mg/L	3/25/2015		1.3
Chlorine Total	mg/L	3/26/2015		1.3
Chlorine Total	mg/L	3/27/2015		1.4
Chlorine Total	mg/L	3/28/2015		1.5
Chlorine Total	mg/L	3/29/2015		1.4
Chlorine Total	mg/L	3/30/2015		1.2
Chlorine Total	mg/L	3/31/2015		1.4
Chlorine Total	mg/L	4/1/2015		1.4
Chlorine Total	mg/L	4/2/2015		1.4
Chlorine Total	mg/L	4/3/2015		1.4
Chlorine Total	mg/L	4/4/2015		1.5
Chlorine Total	mg/L	4/5/2015		1.4
Chlorine Total	mg/L	4/6/2015		1.4
Chlorine Total	mg/L	4/7/2015		1.4
Chlorine Total	mg/L	4/8/2015		1.2
Chlorine Total	mg/L	4/9/2015		1.2
Chlorine Total	mg/L	4/10/2015		1.3
Chlorine Total	mg/L	4/11/2015		1.3
Chlorine Total	mg/L	4/12/2015		1.4
Chlorine Total	mg/L	4/13/2015		1.3
Chlorine Total	mg/L	4/14/2015		1.2
Chlorine Total	mg/L	4/15/2015		1.4

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
Chlorine Total	mg/L	4/16/2015		1.2
Chlorine Total	mg/L	4/17/2015		1.3
Chlorine Total	mg/L	4/18/2015		1.4
Chlorine Total	mg/L	4/19/2015		1.2
Chlorine Total	mg/L	4/20/2015		1.3
Chlorine Total	mg/L	4/21/2015		1.2
Chlorine Total	mg/L	4/22/2015		1.3
Chlorine Total	mg/L	4/23/2015		1.2
Chlorine Total	mg/L	4/24/2015		1.2
Chlorine Total	mg/L	4/25/2015		1.5
Chlorine Total	mg/L	4/26/2015		1.2
Chlorine Total	mg/L	4/27/2015		1.3
Chlorine Total	mg/L	4/28/2015		1.3
Chlorine Total	mg/L	4/29/2015		1.2
Chlorine Total	mg/L	4/30/2015		1.3
Chlorine Total	mg/L	5/1/2015		1.2
Chlorine Total	mg/L	5/2/2015		1.5
Chlorine Total	mg/L	5/3/2015		1.5
Chlorine Total	mg/L	5/4/2015		1.3
Chlorine Total	mg/L	5/5/2015		1.5
Chlorine Total	mg/L	5/6/2015		1.2
Chlorine Total	mg/L	5/7/2015		1.5
Chlorine Total	mg/L	5/8/2015		1.3
Chlorine Total	mg/L	5/9/2015		1.4
Chlorine Total	mg/L	5/10/2015		1.4
Chlorine Total	mg/L	5/11/2015		1.4
Chlorine Total	mg/L	5/12/2015		1.3
Chlorine Total	mg/L	5/13/2015		1.4
Chlorine Total	mg/L	5/14/2015		1.5
Chlorine Total	mg/L	5/15/2015		1.3
Chlorine Total	mg/L	5/16/2015		1.4
Chlorine Total	mg/L	5/17/2015		1.5
Chlorine Total	mg/L	5/18/2015		1.4
Chlorine Total	mg/L	5/19/2015		1.3
Chlorine Total	mg/L	5/20/2015		1.4
Chlorine Total	mg/L	5/21/2015		1.4
Chlorine Total	mg/L	5/22/2015		1.4
Chlorine Total	mg/L	5/23/2015		1.3
Chlorine Total	mg/L	5/24/2015		1.3
Chlorine Total	mg/L	5/25/2015		1.3
Chlorine Total	mg/L	5/26/2015		1.2
Chlorine Total	mg/L	5/27/2015		1.2
Chlorine Total	mg/L	5/28/2015		1.4
Chlorine Total	mg/L	5/29/2015		1.3
Chlorine Total	mg/L	5/30/2015		1.3

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
Chlorine Total	mg/L	5/31/2015		1.3
Chlorine Total	mg/L	6/1/2015		1.4
Chlorine Total	mg/L	6/2/2015		1.3
Chlorine Total	mg/L	6/3/2015		1.4
Chlorine Total	mg/L	6/4/2015		1.4
Chlorine Total	mg/L	6/5/2015		1.4
Chlorine Total	mg/L	6/6/2015		1.4
Chlorine Total	mg/L	6/7/2015		1.5
Chlorine Total	mg/L	6/8/2015		1.3
Chlorine Total	mg/L	6/9/2015		1.4
Chlorine Total	mg/L	6/10/2015		1.3
Chlorine Total	mg/L	6/11/2015		1.4
Chlorine Total	mg/L	6/12/2015		1.4
Chlorine Total	mg/L	6/13/2015		1.4
Chlorine Total	mg/L	6/14/2015		1.4
Chlorine Total	mg/L	6/15/2015		1.4
Chlorine Total	mg/L	6/16/2015		1.3
Chlorine Total	mg/L	6/17/2015		1.4
Chlorine Total	mg/L	6/18/2015		1.4
Chlorine Total	mg/L	6/19/2015		1.4
Chlorine Total	mg/L	6/20/2015		1.4
Chlorine Total	mg/L	6/21/2015		1.3
Chlorine Total	mg/L	6/22/2015		1.3
Chlorine Total	mg/L	6/23/2015		1.3
Chlorine Total	mg/L	6/24/2015		1.4
Chlorine Total	mg/L	6/25/2015		1.3
Chlorine Total	mg/L	6/26/2015		1.2
Chlorine Total	mg/L	6/27/2015		1.3
Chlorine Total	mg/L	6/28/2015		1.3
Chlorine Total	mg/L	6/29/2015		1.4
Chlorine Total	mg/L	6/30/2015		1.5
Chlorine Total	mg/L	7/1/2015		1.6
Chlorine Total	mg/L	7/2/2015		1.6
Chlorine Total	mg/L	7/3/2015		1.4
Chlorine Total	mg/L	7/4/2015		1.5
Chlorine Total	mg/L	7/5/2015		1.4
Chlorine Total	mg/L	7/6/2015		1.4
Chlorine Total	mg/L	7/7/2015		1.2
Chlorine Total	mg/L	7/8/2015		1.7
Chlorine Total	mg/L	7/9/2015		1.4
Chlorine Total	mg/L	7/10/2015		1.5
Chlorine Total	mg/L	7/11/2015		1.5
Chlorine Total	mg/L	7/12/2015		1.4
Chlorine Total	mg/L	7/13/2015		1.5
Chlorine Total	mg/L	7/14/2015		1.4

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
Chlorine Total	mg/L	7/15/2015		1.4
Chlorine Total	mg/L	7/16/2015		1.6
Chlorine Total	mg/L	7/17/2015		1.4
Chlorine Total	mg/L	7/18/2015		1.4
Chlorine Total	mg/L	7/19/2015		1.4
Chlorine Total	mg/L	7/20/2015		1.6
Chlorine Total	mg/L	7/21/2015		1.5
Chlorine Total	mg/L	7/22/2015		1.6
Chlorine Total	mg/L	7/23/2015		1.5
Chlorine Total	mg/L	7/24/2015		1.3
Chlorine Total	mg/L	7/25/2015		1.4
Chlorine Total	mg/L	7/26/2015		1.4
Chlorine Total	mg/L	7/27/2015		1.4
Chlorine Total	mg/L	7/28/2015		1.8
Chlorine Total	mg/L	7/29/2015		1.5
Chlorine Total	mg/L	7/30/2015		1.4
Chlorine Total	mg/L	7/31/2015		1.4
Chlorine Total	mg/L	8/1/2015		1.5
Chlorine Total	mg/L	8/2/2015		1.5
Chlorine Total	mg/L	8/3/2015		1.5
Chlorine Total	mg/L	8/4/2015		1.5
Chlorine Total	mg/L	8/5/2015		1.5
Chlorine Total	mg/L	8/6/2015		1.9
Chlorine Total	mg/L	8/7/2015		1.6
Chlorine Total	mg/L	8/8/2015		1.4
Chlorine Total	mg/L	8/9/2015		1.4
Chlorine Total	mg/L	8/10/2015		1.5
Chlorine Total	mg/L	8/11/2015		1.5
Chlorine Total	mg/L	8/12/2015		1.5
Chlorine Total	mg/L	8/13/2015		1.5
Chlorine Total	mg/L	8/14/2015		1.5
Chlorine Total	mg/L	8/15/2015		1.6
Chlorine Total	mg/L	8/16/2015		1.5
Chlorine Total	mg/L	8/17/2015		1.6
Chlorine Total	mg/L	8/18/2015		1.5
Chlorine Total	mg/L	8/19/2015		1.5
Chlorine Total	mg/L	8/20/2015		1.6
Chlorine Total	mg/L	8/21/2015		1.4
Chlorine Total	mg/L	8/22/2015		1.5
Chlorine Total	mg/L	8/23/2015		1.5
Chlorine Total	mg/L	8/24/2015		1.4
Chlorine Total	mg/L	8/25/2015		1.4
Chlorine Total	mg/L	8/26/2015		1.4
Chlorine Total	mg/L	8/27/2015		1.5
Chlorine Total	mg/L	8/28/2015		1.4

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
Chlorine Total	mg/L	8/29/2015		1.4
Chlorine Total	mg/L	8/30/2015		1.6
Chlorine Total	mg/L	8/31/2015		1.7
Chlorine Total	mg/L	9/1/2015		1.5
Chlorine Total	mg/L	9/2/2015		1.6
Chlorine Total	mg/L	9/3/2015		1.5
Chlorine Total	mg/L	9/4/2015		1.6
Chlorine Total	mg/L	9/5/2015		1.7
Chlorine Total	mg/L	9/6/2015		1.6
Chlorine Total	mg/L	9/7/2015		1.6
Chlorine Total	mg/L	9/8/2015		1.5
Chlorine Total	mg/L	9/9/2015		1.6
Chlorine Total	mg/L	9/10/2015		1.4
Chlorine Total	mg/L	9/11/2015		1.6
Chlorine Total	mg/L	9/12/2015		1.7
Chlorine Total	mg/L	9/13/2015		1.7
Chlorine Total	mg/L	9/14/2015		1.7
Chlorine Total	mg/L	9/15/2015		1.6
Chlorine Total	mg/L	9/16/2015		1.3
Chlorine Total	mg/L	9/17/2015		1.5
Chlorine Total	mg/L	9/18/2015		1.8
Chlorine Total	mg/L	9/19/2015		1.5
Chlorine Total	mg/L	9/20/2015		1.5
Chlorine Total	mg/L	9/21/2015		1.4
Chlorine Total	mg/L	9/22/2015		1.6
Chlorine Total	mg/L	9/23/2015		1.5
Chlorine Total	mg/L	9/24/2015		1.7
Chlorine Total	mg/L	9/25/2015		1.3
Chlorine Total	mg/L	9/26/2015		1.3
Chlorine Total	mg/L	9/27/2015		1.6
Chlorine Total	mg/L	9/28/2015		1.5
Chlorine Total	mg/L	9/29/2015		1.6
Chlorine Total	mg/L	9/30/2015		1.5
Chlorine Total	mg/L	10/1/2015		1.6
Chlorine Total	mg/L	10/2/2015		1.5
Chlorine Total	mg/L	10/3/2015		1.6
Chlorine Total	mg/L	10/4/2015		1.5
Chlorine Total	mg/L	10/5/2015		1.5
Chlorine Total	mg/L	10/6/2015		1.5
Chlorine Total	mg/L	10/7/2015		1.4
Chlorine Total	mg/L	10/8/2015		1.5
Chlorine Total	mg/L	10/9/2015		1.4
Chlorine Total	mg/L	10/10/2015		1.5
Chlorine Total	mg/L	10/11/2015		1.4
Chlorine Total	mg/L	10/12/2015		1.4

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
Chlorine Total	mg/L	10/13/2015		1.4
Chlorine Total	mg/L	10/14/2015		1.4
Chlorine Total	mg/L	10/15/2015		1.4
Chlorine Total	mg/L	10/16/2015		1.3
Chlorine Total	mg/L	10/17/2015		1.3
Chlorine Total	mg/L	10/18/2015		1.3
Chlorine Total	mg/L	10/19/2015		1.3
Chlorine Total	mg/L	10/20/2015		1.4
Chlorine Total	mg/L	10/21/2015		1.3
Chlorine Total	mg/L	10/22/2015		1.3
Chlorine Total	mg/L	10/23/2015		1.3
Chlorine Total	mg/L	10/24/2015		1.5
Chlorine Total	mg/L	10/25/2015		1.5
Chlorine Total	mg/L	10/26/2015		1.2
Chlorine Total	mg/L	10/27/2015		1.3
Chlorine Total	mg/L	10/28/2015		1.3
Chlorine Total	mg/L	10/29/2015		1.3
Chlorine Total	mg/L	10/30/2015		LA
Chlorine Total	mg/L	10/31/2015		1.7
Chlorine Total	mg/L	11/1/2015		1.5
Chlorine Total	mg/L	11/2/2015		1.6
Chlorine Total	mg/L	11/3/2015		1.4
Chlorine Total	mg/L	11/4/2015		1.6
Chlorine Total	mg/L	11/5/2015		1.2
Chlorine Total	mg/L	11/6/2015		1.3
Chlorine Total	mg/L	11/7/2015		1.6
Chlorine Total	mg/L	11/8/2015		1.7
Chlorine Total	mg/L	11/9/2015		1.9
Chlorine Total	mg/L	11/10/2015		1.4
Chlorine Total	mg/L	11/11/2015		1.8
Chlorine Total	mg/L	11/12/2015		1.4
Chlorine Total	mg/L	11/13/2015		1.4
Chlorine Total	mg/L	11/14/2015		1.7
Chlorine Total	mg/L	11/15/2015		1.8
Chlorine Total	mg/L	11/16/2015		1.6
Chlorine Total	mg/L	11/17/2015		1.4
Chlorine Total	mg/L	11/18/2015		1.4
Chlorine Total	mg/L	11/19/2015		1.6
Chlorine Total	mg/L	11/20/2015		1.6
Chlorine Total	mg/L	11/21/2015		1.6
Chlorine Total	mg/L	11/22/2015		1.5
Chlorine Total	mg/L	11/23/2015		1.2
Chlorine Total	mg/L	11/24/2015		1.5
Chlorine Total	mg/L	11/25/2015		1.4
Chlorine Total	mg/L	11/26/2015		1.4

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
Chlorine Total	mg/L	11/27/2015		1.1
Chlorine Total	mg/L	11/28/2015		1.5
Chlorine Total	mg/L	11/29/2015		1.4
Chlorine Total	mg/L	11/30/2015		1.5
Chlorine Total	mg/L	12/1/2015		1.3
Chlorine Total	mg/L	12/2/2015		1.3
Chlorine Total	mg/L	12/3/2015		1.4
Chlorine Total	mg/L	12/4/2015		1.4
Chlorine Total	mg/L	12/5/2015		1.6
Chlorine Total	mg/L	12/6/2015		1.7
Chlorine Total	mg/L	12/7/2015		1.4
Chlorine Total	mg/L	12/8/2015		1.4
Chlorine Total	mg/L	12/9/2015		1.7
Chlorine Total	mg/L	12/10/2015		1.2
Chlorine Total	mg/L	12/11/2015		1.4
Chlorine Total	mg/L	12/12/2015		1.4
Chlorine Total	mg/L	12/13/2015		1.4
Chlorine Total	mg/L	12/14/2015		1.4
Chlorine Total	mg/L	12/15/2015		1.6
Chlorine Total	mg/L	12/16/2015		1.5
Chlorine Total	mg/L	12/17/2015		1.6
Chlorine Total	mg/L	12/18/2015		1.4
Chlorine Total	mg/L	12/19/2015		1.3
Chlorine Total	mg/L	12/20/2015		1.4
Chlorine Total	mg/L	12/21/2015		1.6
Chlorine Total	mg/L	12/22/2015		1.3
Chlorine Total	mg/L	12/23/2015		1.3
Chlorine Total	mg/L	12/24/2015		1.3
Chlorine Total	mg/L	12/26/2015		1.5
Chlorine Total	mg/L	12/27/2015		1.3
Chlorine Total	mg/L	12/28/2015		1.3
Chlorine Total	mg/L	12/29/2015		1.4
Chlorine Total	mg/L	12/30/2015		1.4
Chlorine Total	mg/L	12/31/2015		1.4
Chlorodibromomethane	ppb	2/18/2015	<1	<1
Chlorodibromomethane	ppb	5/19/2015		<1
Chlorodibromomethane	ppb	5/20/2015	<1	
Chlorodibromomethane	ppb	8/18/2015	<1	<1
Chlorodibromomethane	ppb	11/23/2015	<1	<1
Chloroform	ppb	2/18/2015	<1	9
Chloroform	ppb	5/19/2015		11
Chloroform	ppb	5/20/2015	<1	
Chloroform	ppb	8/18/2015	<1	8
Chloroform	ppb	11/23/2015	<1	7
Chromium Total	µg/L	5/5/2015	0.11	<0.05

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
Chromium Total	µg/L	6/1/2015	<0.05	<0.05
Chromium Total	µg/L	10/19/2015	0.22	0.25
Chromium Total	µg/L	12/7/2015	<0.05	<0.05
Cobalt Total	µg/L	5/5/2015	<0.5	<0.5
Cobalt Total	µg/L	10/19/2015	<0.5	<0.5
Color - Apparent	ACU	1/5/2015	20	2
Color - Apparent	ACU	1/12/2015	17	<1
Color - Apparent	ACU	1/19/2015	15	2
Color - Apparent	ACU	1/26/2015	23	3
Color - Apparent	ACU	2/2/2015	17	2
Color - Apparent	ACU	2/10/2015	18	<1
Color - Apparent	ACU	2/16/2015	16	<1
Color - Apparent	ACU	2/23/2015	19	2
Color - Apparent	ACU	3/2/2015	17	2
Color - Apparent	ACU	3/9/2015	17	<1
Color - Apparent	ACU	3/16/2015	18	4
Color - Apparent	ACU	3/23/2015	19	2
Color - Apparent	ACU	3/30/2015	21	2
Color - Apparent	ACU	4/7/2015	18	2
Color - Apparent	ACU	4/13/2015	18	3
Color - Apparent	ACU	4/20/2015	17	2
Color - Apparent	ACU	4/27/2015	17	2
Color - Apparent	ACU	5/4/2015	19	5
Color - Apparent	ACU	5/11/2015	19	2
Color - Apparent	ACU	5/19/2015	18	3
Color - Apparent	ACU	5/25/2015	18	2
Color - Apparent	ACU	6/1/2015	18	2
Color - Apparent	ACU	6/8/2015	18	3
Color - Apparent	ACU	6/15/2015	16	2
Color - Apparent	ACU	6/22/2015	16	2
Color - Apparent	ACU	6/29/2015	14	1
Color - Apparent	ACU	7/6/2015	14	<1
Color - Apparent	ACU	7/13/2015	15	<1
Color - Apparent	ACU	7/20/2015	13	2
Color - Apparent	ACU	7/27/2015	13	1
Color - Apparent	ACU	8/4/2015	13	1
Color - Apparent	ACU	8/10/2015	13	2
Color - Apparent	ACU	8/17/2015	17	6
Color - Apparent	ACU	8/24/2015	13	3
Color - Apparent	ACU	8/31/2015		5
Color - Apparent	ACU	9/8/2015	15	5
Color - Apparent	ACU	9/14/2015	16	2
Color - Apparent	ACU	9/21/2015	18	1
Color - Apparent	ACU	9/28/2015	17	2
Color - Apparent	ACU	10/5/2015	13	4

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
Color - Apparent	ACU	10/13/2015	17	2
Color - Apparent	ACU	10/19/2015	15	2
Color - Apparent	ACU	10/26/2015	13	<1
Color - Apparent	ACU	11/2/2015	22	3
Color - Apparent	ACU	11/9/2015	23	1
Color - Apparent	ACU	11/16/2015	20	1
Color - Apparent	ACU	11/23/2015	18	<1
Color - Apparent	ACU	11/30/2015	18	2
Color - Apparent	ACU	12/7/2015	19	1
Color - Apparent	ACU	12/14/2015	17	2
Color - Apparent	ACU	12/21/2015	17	2
Color - True	TCU	1/5/2015	14	2
Color - True	TCU	1/12/2015	12	<1
Color - True	TCU	1/19/2015	12	<1
Color - True	TCU	1/26/2015	15	<1
Color - True	TCU	2/2/2015	13	1
Color - True	TCU	2/10/2015	12	<1
Color - True	TCU	2/16/2015	12	<2
Color - True	TCU	2/23/2015	12	<2
Color - True	TCU	3/2/2015	12	1
Color - True	TCU	3/9/2015	12	<1
Color - True	TCU	3/16/2015	13	3
Color - True	TCU	3/23/2015	13	1
Color - True	TCU	3/30/2015	15	2
Color - True	TCU	4/7/2015	12	<1
Color - True	TCU	4/13/2015	12	<1
Color - True	TCU	4/20/2015	12	<1
Color - True	TCU	4/27/2015	12	<1
Color - True	TCU	5/4/2015	13	3
Color - True	TCU	5/11/2015	12	1
Color - True	TCU	5/19/2015	12	1
Color - True	TCU	5/25/2015	12	1
Color - True	TCU	6/1/2015	12	1
Color - True	TCU	6/8/2015	12	<1
Color - True	TCU	6/15/2015	11	<1
Color - True	TCU	6/22/2015	10	<1
Color - True	TCU	6/29/2015	10	<1
Color - True	TCU	7/6/2015	9	<1
Color - True	TCU	7/13/2015	9	<1
Color - True	TCU	7/20/2015	9	<1
Color - True	TCU	7/27/2015	8	<1
Color - True	TCU	8/4/2015	7	<1
Color - True	TCU	8/10/2015	7	<1
Color - True	TCU	8/17/2015	6	<1
Color - True	TCU	8/24/2015	7	<1

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
Color - True	TCU	8/31/2015		1
Color - True	TCU	9/8/2015	9	<1
Color - True	TCU	9/14/2015	8	<1
Color - True	TCU	9/21/2015	12	1
Color - True	TCU	9/28/2015	11	<1
Color - True	TCU	10/5/2015	11	<1
Color - True	TCU	10/13/2015	10	<1
Color - True	TCU	10/19/2015	9	<1
Color - True	TCU	10/26/2015	9	<1
Color - True	TCU	11/2/2015	15	<1
Color - True	TCU	11/9/2015	15	<1
Color - True	TCU	11/16/2015	13	<1
Color - True	TCU	11/23/2015	12	<1
Color - True	TCU	11/30/2015	12	<1
Color - True	TCU	12/7/2015	14	<1
Color - True	TCU	12/14/2015	12	<1
Color - True	TCU	12/21/2015	13	1
Conductivity	µmhos/cm	1/5/2015	8	29
Conductivity	µmhos/cm	1/12/2015	8	31
Conductivity	µmhos/cm	1/19/2015	8	30
Conductivity	µmhos/cm	1/26/2015	8	26
Conductivity	µmhos/cm	2/2/2015	8	28
Conductivity	µmhos/cm	2/10/2015	8	32
Conductivity	µmhos/cm	2/16/2015	8	32
Conductivity	µmhos/cm	2/23/2015	8	28
Conductivity	µmhos/cm	3/2/2015	8	25
Conductivity	µmhos/cm	3/9/2015	7	27
Conductivity	µmhos/cm	3/16/2015	8	28
Conductivity	µmhos/cm	3/23/2015	8	24
Conductivity	µmhos/cm	3/30/2015	8	29
Conductivity	µmhos/cm	4/7/2015	8	27
Conductivity	µmhos/cm	4/13/2015	8	27
Conductivity	µmhos/cm	4/20/2015	8	28
Conductivity	µmhos/cm	4/27/2015	8	27
Conductivity	µmhos/cm	5/4/2015	8	27
Conductivity	µmhos/cm	5/11/2015	8	26
Conductivity	µmhos/cm	5/19/2015	8	29
Conductivity	µmhos/cm	5/25/2015	8	28
Conductivity	µmhos/cm	6/1/2015	8	28
Conductivity	µmhos/cm	6/8/2015	7	28
Conductivity	µmhos/cm	6/15/2015	8	29
Conductivity	µmhos/cm	6/22/2015	8	27
Conductivity	µmhos/cm	6/29/2015	8	24
Conductivity	µmhos/cm	7/6/2015	8	28
Conductivity	µmhos/cm	7/13/2015	8	28

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
Conductivity	µmhos/cm	7/20/2015	8	28
Conductivity	µmhos/cm	7/27/2015	8	28
Conductivity	µmhos/cm	8/4/2015	8	26
Conductivity	µmhos/cm	8/10/2015	9	29
Conductivity	µmhos/cm	8/17/2015	8	27
Conductivity	µmhos/cm	8/24/2015	9	27
Conductivity	µmhos/cm	8/31/2015		27
Conductivity	µmhos/cm	9/8/2015	10	30
Conductivity	µmhos/cm	9/14/2015	10	31
Conductivity	µmhos/cm	9/21/2015	9	29
Conductivity	µmhos/cm	9/28/2015	10	31
Conductivity	µmhos/cm	10/5/2015	10	32
Conductivity	µmhos/cm	10/13/2015	10	33
Conductivity	µmhos/cm	10/19/2015	10	30
Conductivity	µmhos/cm	10/26/2015	10	29
Conductivity	µmhos/cm	11/2/2015	10	31
Conductivity	µmhos/cm	11/9/2015	10	32
Conductivity	µmhos/cm	11/16/2015	10	32
Conductivity	µmhos/cm	11/23/2015	10	28
Conductivity	µmhos/cm	11/30/2015	10	27
Conductivity	µmhos/cm	12/7/2015	10	29
Conductivity	µmhos/cm	12/14/2015	10	31
Conductivity	µmhos/cm	12/21/2015	10	30
Copper Total	µg/L	5/5/2015	8.3	<0.5
Copper Total	µg/L	6/1/2015	6.2	<0.5
Copper Total	µg/L	10/19/2015	6.6	<0.5
Copper Total	µg/L	12/7/2015	7.5	<0.5
Cyanide Total	mg/L	6/1/2015	<0.02	<0.02
Cyanide Total	mg/L	12/7/2015	<0.02	<0.02
Dibromoacetic Acid	ppb	2/18/2015	<0.5	<0.5
Dibromoacetic Acid	ppb	5/19/2015		<0.5
Dibromoacetic Acid	ppb	5/20/2015	<0.5	
Dibromoacetic Acid	ppb	8/18/2015	<0.5	<0.5
Dibromoacetic Acid	ppb	11/23/2015	<0.5	<0.5
Dichloroacetic Acid	ppb	2/18/2015	<1	15
Dichloroacetic Acid	ppb	5/19/2015		12
Dichloroacetic Acid	ppb	5/20/2015	<1	
Dichloroacetic Acid	ppb	8/18/2015	<1	6
Dichloroacetic Acid	ppb	11/23/2015	<1	8
Fluoride	mg/L	1/5/2015	<0.05	<0.05
Fluoride	mg/L	2/2/2015	<0.05	<0.05
Fluoride	mg/L	3/2/2015	<0.05	<0.05
Fluoride	mg/L	4/7/2015	<0.05	<0.05
Fluoride	mg/L	5/4/2015	<0.05	<0.05
Fluoride	mg/L	6/1/2015	<0.05	<0.05

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
Fluoride	mg/L	7/6/2015	<0.05	<0.05
Fluoride	mg/L	8/10/2015	<0.05	<0.05
Fluoride	mg/L	9/8/2015	<0.05	<0.05
Fluoride	mg/L	10/13/2015	<0.05	<0.05
Fluoride	mg/L	11/9/2015	<0.05	<0.05
Fluoride	mg/L	12/7/2015	<0.05	<0.05
HAA - Total Haloacetic Acid	ppb	2/18/2015	<3	27.3
HAA - Total Haloacetic Acid	ppb	5/19/2015		23
HAA - Total Haloacetic Acid	ppb	5/20/2015	<3	
HAA - Total Haloacetic Acid	ppb	8/18/2015	<3	20.1
HAA - Total Haloacetic Acid	ppb	11/23/2015	<3	23
Hardness as CaCO3	mg/L	1/5/2015	2.64	2.52
Hardness as CaCO3	mg/L	2/2/2015	2.57	2.67
Hardness as CaCO3	mg/L	3/2/2015	2.49	2.41
Hardness as CaCO3	mg/L	4/7/2015	2.42	2.41
Hardness as CaCO3	mg/L	5/4/2015	2.44	2.55
Hardness as CaCO3	mg/L	6/1/2015	2.63	2.35
Hardness as CaCO3	mg/L	7/6/2015	2.54	2.49
Hardness as CaCO3	mg/L	8/10/2015	2.64	2.47
Hardness as CaCO3	mg/L	9/8/2015	2.93	2.87
Hardness as CaCO3	mg/L	10/13/2015	2.82	2.82
Hardness as CaCO3	mg/L	11/9/2015	2.78	2.75
Hardness as CaCO3	mg/L	12/7/2015	2.6420695	2.68303
Iron Dissolved	µg/L	1/5/2015	22	21
Iron Dissolved	µg/L	1/12/2015	19	20
Iron Dissolved	µg/L	1/19/2015	17	18
Iron Dissolved	µg/L	1/26/2015	21	24
Iron Dissolved	µg/L	2/2/2015	29	19
Iron Dissolved	µg/L	2/10/2015	15	20
Iron Dissolved	µg/L	2/16/2015	18	20
Iron Dissolved	µg/L	2/23/2015	20	22
Iron Dissolved	µg/L	3/2/2015	21	22
Iron Dissolved	µg/L	3/9/2015	19	20
Iron Dissolved	µg/L	3/16/2015	18	19
Iron Dissolved	µg/L	3/23/2015	16	18
Iron Dissolved	µg/L	3/30/2015	14	16
Iron Dissolved	µg/L	4/7/2015	13	15
Iron Dissolved	µg/L	4/13/2015	12	14
Iron Dissolved	µg/L	4/20/2015	11	13
Iron Dissolved	µg/L	4/27/2015	13	14
Iron Dissolved	µg/L	5/4/2015	16	16
Iron Dissolved	µg/L	5/11/2015	15	17
Iron Dissolved	µg/L	5/19/2015	14	16
Iron Dissolved	µg/L	5/25/2015	15	16
Iron Dissolved	µg/L	6/1/2015	14	15

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
Iron Dissolved	µg/L	6/8/2015	15	17
Iron Dissolved	µg/L	6/15/2015	15	16
Iron Dissolved	µg/L	6/22/2015	14	15
Iron Dissolved	µg/L	6/29/2015	14	15
Iron Dissolved	µg/L	7/6/2015	15	16
Iron Dissolved	µg/L	7/13/2015	16	17
Iron Dissolved	µg/L	7/20/2015	17	19
Iron Dissolved	µg/L	7/27/2015	18	19
Iron Dissolved	µg/L	8/4/2015	18	19
Iron Dissolved	µg/L	8/10/2015	20	20
Iron Dissolved	µg/L	8/17/2015	23	25
Iron Dissolved	µg/L	8/24/2015	24	25
Iron Dissolved	µg/L	8/31/2015		28
Iron Dissolved	µg/L	9/8/2015	20	25
Iron Dissolved	µg/L	9/14/2015	19	23
Iron Dissolved	µg/L	9/21/2015	18	21
Iron Dissolved	µg/L	9/28/2015	16	19
Iron Dissolved	µg/L	10/5/2015	14	17
Iron Dissolved	µg/L	10/13/2015	14	18
Iron Dissolved	µg/L	10/19/2015	17	18
Iron Dissolved	µg/L	10/26/2015	14	15
Iron Dissolved	µg/L	11/2/2015	21	25
Iron Dissolved	µg/L	11/9/2015	18	22
Iron Dissolved	µg/L	11/16/2015	16	18
Iron Dissolved	µg/L	11/23/2015	15	16
Iron Dissolved	µg/L	11/30/2015	15	16
Iron Dissolved	µg/L	12/7/2015	20	21
Iron Dissolved	µg/L	12/14/2015	15	17
Iron Dissolved	µg/L	12/21/2015	20	22
Iron Total	µg/L	1/5/2015	76	49
Iron Total	µg/L	1/12/2015	42	39
Iron Total	µg/L	1/19/2015	38	38
Iron Total	µg/L	1/26/2015	85	83
Iron Total	µg/L	2/2/2015	73	116
Iron Total	µg/L	2/10/2015	42	42
Iron Total	µg/L	2/16/2015	37	41
Iron Total	µg/L	2/23/2015	43	43
Iron Total	µg/L	3/2/2015	40	40
Iron Total	µg/L	3/9/2015	41	39
Iron Total	µg/L	3/16/2015	46	44
Iron Total	µg/L	3/23/2015	50	52
Iron Total	µg/L	3/30/2015	42	41
Iron Total	µg/L	4/7/2015	49	38
Iron Total	µg/L	4/13/2015	36	37
Iron Total	µg/L	4/20/2015	35	35

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
Iron Total	µg/L	4/27/2015	34	36
Iron Total	µg/L	5/4/2015	42	39
Iron Total	µg/L	5/5/2015	48	49
Iron Total	µg/L	5/11/2015	40	54
Iron Total	µg/L	5/19/2015	40	42
Iron Total	µg/L	5/25/2015	41	41
Iron Total	µg/L	6/1/2015	38	38
Iron Total	µg/L	6/8/2015	46	49
Iron Total	µg/L	6/15/2015	39	38
Iron Total	µg/L	6/22/2015	32	37
Iron Total	µg/L	6/29/2015	32	33
Iron Total	µg/L	7/6/2015	31	32
Iron Total	µg/L	7/13/2015	35	37
Iron Total	µg/L	7/20/2015	42	40
Iron Total	µg/L	7/27/2015	47	47
Iron Total	µg/L	8/4/2015	47	49
Iron Total	µg/L	8/10/2015	51	55
Iron Total	µg/L	8/17/2015	59	62
Iron Total	µg/L	8/24/2015	65	66
Iron Total	µg/L	8/31/2015		85
Iron Total	µg/L	9/8/2015	83	81
Iron Total	µg/L	9/14/2015	78	84
Iron Total	µg/L	9/21/2015	64	61
Iron Total	µg/L	9/28/2015	55	56
Iron Total	µg/L	10/5/2015	49	53
Iron Total	µg/L	10/13/2015	47	47
Iron Total	µg/L	10/19/2015	51	52
Iron Total	µg/L	10/26/2015	39	40
Iron Total	µg/L	11/2/2015	69	53
Iron Total	µg/L	11/9/2015	49	49
Iron Total	µg/L	11/16/2015	61	46
Iron Total	µg/L	11/23/2015	52	37
Iron Total	µg/L	11/30/2015	37	40
Iron Total	µg/L	12/7/2015	38	42
Iron Total	µg/L	12/14/2015	65	57
Iron Total	µg/L	12/21/2015	44	47
Lead Total	µg/L	5/5/2015	<0.5	<0.5
Lead Total	µg/L	6/1/2015	<0.5	<0.5
Lead Total	µg/L	10/19/2015	<0.5	<0.5
Lead Total	µg/L	12/7/2015	<0.5	<0.5
Magnesium Total	µg/L	1/5/2015	110	100
Magnesium Total	µg/L	2/2/2015	110	122
Magnesium Total	µg/L	3/2/2015	93	92
Magnesium Total	µg/L	4/7/2015	95	90
Magnesium Total	µg/L	5/4/2015	90	93

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
Magnesium Total	µg/L	5/5/2015	94	96
Magnesium Total	µg/L	6/1/2015	100	89
Magnesium Total	µg/L	7/6/2015	89	88
Magnesium Total	µg/L	8/10/2015	93	88
Magnesium Total	µg/L	9/8/2015	114	112
Magnesium Total	µg/L	10/13/2015	106	104
Magnesium Total	µg/L	10/19/2015	110	112
Magnesium Total	µg/L	11/9/2015	114	113
Magnesium Total	µg/L	12/7/2015	108	111
Manganese Dissolved	µg/L	1/5/2015	3.7	2.9
Manganese Dissolved	µg/L	2/2/2015	3.3	2.6
Manganese Dissolved	µg/L	3/2/2015	3.6	2.8
Manganese Dissolved	µg/L	4/7/2015	2.9	2.3
Manganese Dissolved	µg/L	5/4/2015	3	2.1
Manganese Dissolved	µg/L	6/1/2015	3	2.1
Manganese Dissolved	µg/L	7/6/2015	3.4	2
Manganese Dissolved	µg/L	8/10/2015	4.8	2.5
Manganese Dissolved	µg/L	9/8/2015	4.9	3.2
Manganese Dissolved	µg/L	10/13/2015	4.2	2.6
Manganese Dissolved	µg/L	11/9/2015	3.6	2.8
Manganese Dissolved	µg/L	12/7/2015	3.3	2.7
Manganese Total	µg/L	1/5/2015	4.7	3.5
Manganese Total	µg/L	2/2/2015	4.2	5.4
Manganese Total	µg/L	3/2/2015	3.8	3.1
Manganese Total	µg/L	4/7/2015	4.2	2.8
Manganese Total	µg/L	5/4/2015	3.4	2.5
Manganese Total	µg/L	5/5/2015	3.6	3
Manganese Total	µg/L	6/1/2015	3.5	2.5
Manganese Total	µg/L	7/6/2015	3.5	2.4
Manganese Total	µg/L	8/10/2015	5	4.2
Manganese Total	µg/L	9/8/2015	6.2	4.3
Manganese Total	µg/L	10/13/2015	4.8	3.3
Manganese Total	µg/L	10/19/2015	4.7	3.4
Manganese Total	µg/L	11/9/2015	4.3	3.3
Manganese Total	µg/L	12/7/2015	3.8	3.2
Mercury Total	µg/L	5/5/2015	<0.05	<0.05
Mercury Total	µg/L	6/1/2015	<0.05	<0.05
Mercury Total	µg/L	10/19/2015	<0.05	<0.05
Mercury Total	µg/L	12/7/2015	<0.05	<0.05
Molybdenum Total	µg/L	5/5/2015	<0.5	<0.5
Molybdenum Total	µg/L	10/19/2015	<0.5	<0.5
Monobromoacetic Acid	ppb	2/18/2015	<1	1
Monobromoacetic Acid	ppb	5/19/2015		<1
Monobromoacetic Acid	ppb	5/20/2015	<1	
Monobromoacetic Acid	ppb	8/18/2015	<1	<1

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
Monobromoacetic Acid	ppb	11/23/2015	<1	<1
Monochloroacetic Acid	ppb	2/18/2015	<2	7
Monochloroacetic Acid	ppb	5/19/2015		7
Monochloroacetic Acid	ppb	5/20/2015	<2	
Monochloroacetic Acid	ppb	8/18/2015	<2	12
Monochloroacetic Acid	ppb	11/23/2015	<2	12
Nickel Total	µg/L	5/5/2015	<0.5	<0.5
Nickel Total	µg/L	6/1/2015	<0.5	<0.5
Nickel Total	µg/L	10/19/2015	<0.5	<0.5
Nickel Total	µg/L	12/7/2015	<0.5	<0.5
Nitrogen - Ammonia as N	mg/L	1/5/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	1/12/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	1/19/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	1/26/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	2/2/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	2/10/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	2/16/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	2/23/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	3/2/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	3/9/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	3/16/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	3/23/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	3/30/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	4/7/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	4/13/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	4/20/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	4/27/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	5/4/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	5/11/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	5/19/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	5/25/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	6/1/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	6/8/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	6/15/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	6/22/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	6/29/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	7/6/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	7/13/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	7/20/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	7/27/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	8/4/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	8/10/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	8/17/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	8/24/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	8/31/2015		<0.02

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
Nitrogen - Ammonia as N	mg/L	9/8/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	9/14/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	9/21/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	9/28/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	10/5/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	10/13/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	10/19/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	10/26/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	11/2/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	11/9/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	11/16/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	11/23/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	11/30/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	12/7/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	12/14/2015	<0.02	<0.02
Nitrogen - Ammonia as N	mg/L	12/21/2015	<0.02	<0.02
Nitrogen - Nitrate as N	mg/L	1/5/2015	0.09	0.09
Nitrogen - Nitrate as N	mg/L	2/2/2015	0.11	0.11
Nitrogen - Nitrate as N	mg/L	3/2/2015	0.11	0.11
Nitrogen - Nitrate as N	mg/L	4/7/2015	0.08	0.09
Nitrogen - Nitrate as N	mg/L	5/4/2015	0.08	0.09
Nitrogen - Nitrate as N	mg/L	6/1/2015	0.08	0.08
Nitrogen - Nitrate as N	mg/L	7/6/2015	0.07	0.07
Nitrogen - Nitrate as N	mg/L	8/10/2015	0.05	0.05
Nitrogen - Nitrate as N	mg/L	9/8/2015	0.12	0.14
Nitrogen - Nitrate as N	mg/L	10/13/2015	0.1	0.11
Nitrogen - Nitrate as N	mg/L	11/9/2015	0.11	0.12
Nitrogen - Nitrate as N	mg/L	12/7/2015	0.1	0.11
Nitrogen - Nitrite as N	mg/L	1/5/2015	<0.01	<0.01
Nitrogen - Nitrite as N	mg/L	2/2/2015	<0.01	<0.01
Nitrogen - Nitrite as N	mg/L	3/2/2015	<0.01	<0.01
Nitrogen - Nitrite as N	mg/L	4/7/2015	<0.01	<0.01
Nitrogen - Nitrite as N	mg/L	5/4/2015	<0.01	<0.01
Nitrogen - Nitrite as N	mg/L	6/1/2015	<0.01	<0.01
Nitrogen - Nitrite as N	mg/L	7/6/2015	<0.01	<0.01
Nitrogen - Nitrite as N	mg/L	8/10/2015	<0.01	<0.01
Nitrogen - Nitrite as N	mg/L	9/8/2015	<0.01	<0.01
Nitrogen - Nitrite as N	mg/L	10/13/2015	<0.01	<0.01
Nitrogen - Nitrite as N	mg/L	11/9/2015	<0.01	<0.01
Nitrogen - Nitrite as N	mg/L	12/7/2015	<0.01	<0.01
pH	pH units	1/2/2015	6.3	7.3
pH	pH units	1/5/2015	6.4	7.3
pH	pH units	1/7/2015	6.3	7.5
pH	pH units	1/8/2015	6.3	7.4
pH	pH units	1/9/2015	6.3	7.6

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
pH	pH units	1/12/2015	6.3	7.6
pH	pH units	1/15/2015	6.2	7.4
pH	pH units	1/19/2015	6.4	7.6
pH	pH units	1/20/2015	6.4	7.6
pH	pH units	1/21/2015	6.2	7.6
pH	pH units	1/22/2015	6.3	7.3
pH	pH units	1/23/2015	6.4	7.3
pH	pH units	1/26/2015	6.3	7.2
pH	pH units	1/27/2015	6.3	7.3
pH	pH units	1/28/2015	6.3	7.4
pH	pH units	1/29/2015	6.3	7.5
pH	pH units	1/30/2015	6.3	7.5
pH	pH units	2/2/2015	6.3	7.3
pH	pH units	2/4/2015	6.4	7.4
pH	pH units	2/6/2015	6.3	7.2
pH	pH units	2/10/2015	6.3	7.5
pH	pH units	2/11/2015	6.3	7.5
pH	pH units	2/13/2015	6.4	7.4
pH	pH units	2/16/2015	6.3	7.4
pH	pH units	2/18/2015	6.3	7.4
pH	pH units	2/20/2015	6.3	7.2
pH	pH units	2/23/2015	6.2	7.1
pH	pH units	2/24/2015	6.3	7.2
pH	pH units	2/27/2015	6.4	7.3
pH	pH units	3/2/2015	6.2	7.2
pH	pH units	3/9/2015	6.3	7.2
pH	pH units	3/16/2015	6.2	7.2
pH	pH units	3/23/2015	6.2	7
pH	pH units	3/30/2015	6.3	7.1
pH	pH units	3/31/2015	6.3	7.3
pH	pH units	4/1/2015	6.3	7.1
pH	pH units	4/7/2015	6.4	7.2
pH	pH units	4/10/2015	6.3	7.5
pH	pH units	4/13/2015	6.3	7.2
pH	pH units	4/14/2015	6.4	7.4
pH	pH units	4/20/2015	6.3	7.2
pH	pH units	4/21/2015	6.4	7.3
pH	pH units	4/24/2015	6.4	7.3
pH	pH units	4/27/2015	6.3	7.1
pH	pH units	4/29/2015	6.3	7.4
pH	pH units	5/1/2015	6.3	7.4
pH	pH units	5/4/2015	6.3	7.4
pH	pH units	5/6/2015	6.4	7.4
pH	pH units	5/8/2015	6.3	7.3
pH	pH units	5/11/2015	6.2	7.3

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
pH	pH units	5/14/2015	6.2	7.4
pH	pH units	5/19/2015	6.3	7.2
pH	pH units	5/20/2015	6.3	7.4
pH	pH units	5/22/2015	6.3	7.6
pH	pH units	5/25/2015	6.3	7.3
pH	pH units	5/27/2015	6.2	7.2
pH	pH units	5/29/2015	6.3	7.4
pH	pH units	6/1/2015	6.3	7.2
pH	pH units	6/2/2015	6.2	7.2
pH	pH units	6/8/2015	6.3	7.5
pH	pH units	6/12/2015	6.3	7.5
pH	pH units	6/15/2015	6.3	7.3
pH	pH units	6/22/2015	6.4	7.4
pH	pH units	6/26/2015	6.4	7.5
pH	pH units	6/29/2015	6.3	7.2
pH	pH units	6/30/2015	6.4	7.4
pH	pH units	7/2/2015	6.4	7.4
pH	pH units	7/6/2015	6.4	7.4
pH	pH units	7/8/2015	6.4	7.4
pH	pH units	7/9/2015	6.4	7.4
pH	pH units	7/10/2015	6.3	7.4
pH	pH units	7/13/2015	6.4	7.4
pH	pH units	7/15/2015	6.4	7.5
pH	pH units	7/16/2015	6.3	7.4
pH	pH units	7/20/2015	6.4	7.3
pH	pH units	7/21/2015	6.5	7.5
pH	pH units	7/22/2015	6.5	7.4
pH	pH units	7/23/2015	6.4	7.4
pH	pH units	7/27/2015	6.4	7.3
pH	pH units	7/28/2015	6.5	7.3
pH	pH units	7/29/2015	6.4	7.6
pH	pH units	8/4/2015	6.4	7.3
pH	pH units	8/10/2015	6.5	7.4
pH	pH units	8/17/2015	6.4	7.3
pH	pH units	8/18/2015	6.4	7.2
pH	pH units	8/24/2015	6.4	7.2
pH	pH units	8/31/2015		7.3
pH	pH units	9/8/2015	6.4	7.2
pH	pH units	9/14/2015	6.4	7.2
pH	pH units	9/21/2015	6.3	7.1
pH	pH units	9/28/2015	6.4	7.2
pH	pH units	10/5/2015	6.4	7.2
pH	pH units	10/13/2015	6.4	7.3
pH	pH units	10/19/2015	6.3	7.1
pH	pH units	10/26/2015	6.4	7.2

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
pH	pH units	11/2/2015	6.3	7
pH	pH units	11/9/2015	6.3	7.1
pH	pH units	11/16/2015	6.3	7.2
pH	pH units	11/23/2015	6.3	7.1
pH	pH units	11/30/2015	6.3	7
pH	pH units	12/7/2015	6.2	7.1
pH	pH units	12/14/2015	6.2	7.3
pH	pH units	12/21/2015	6.2	7.1
Phenol	mg/L	6/1/2015	<0.005	<0.005
Phenol	mg/L	12/7/2015	<0.005	<0.005
Phosphorus Dissolved Reactive	mg/L	1/5/2015	<0.005	<0.005
Phosphorus Dissolved Reactive	mg/L	2/2/2015	<0.005	<0.005
Phosphorus Dissolved Reactive	mg/L	3/2/2015	<0.005	<0.005
Phosphorus Dissolved Reactive	mg/L	4/7/2015	0.005	<0.005
Phosphorus Dissolved Reactive	mg/L	5/4/2015	<0.005	<0.005
Phosphorus Dissolved Reactive	mg/L	6/1/2015	<0.005	<0.005
Phosphorus Dissolved Reactive	mg/L	7/6/2015	<0.005	<0.005
Phosphorus Dissolved Reactive	mg/L	8/10/2015	<0.005	<0.005
Phosphorus Dissolved Reactive	mg/L	9/8/2015	<0.005	<0.005
Phosphorus Dissolved Reactive	mg/L	10/13/2015	<0.005	<0.005
Phosphorus Dissolved Reactive	mg/L	11/9/2015	<0.005	<0.005
Phosphorus Dissolved Reactive	mg/L	12/7/2015	<0.005	<0.005
Phosphorus Total	mg/L	1/5/2015	<0.005	<0.005
Phosphorus Total	mg/L	2/2/2015	<0.005	<0.005
Phosphorus Total	mg/L	3/2/2015	<0.005	<0.005
Phosphorus Total	mg/L	4/7/2015	<0.005	<0.005
Phosphorus Total	mg/L	5/4/2015	<0.005	<0.005
Phosphorus Total	mg/L	6/1/2015	<0.005	<0.005
Phosphorus Total	mg/L	7/6/2015	<0.005	<0.005
Phosphorus Total	mg/L	8/10/2015	<0.005	<0.005
Phosphorus Total	mg/L	9/8/2015	<0.005	<0.005
Phosphorus Total	mg/L	10/13/2015	<0.005	<0.005
Phosphorus Total	mg/L	11/9/2015	<0.005	<0.005
Phosphorus Total	mg/L	12/7/2015	<0.005	<0.005
Potassium Total	µg/L	5/5/2015	110	114

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
Potassium Total	µg/L	6/1/2015	111	111
Potassium Total	µg/L	10/19/2015	138	139
Potassium Total	µg/L	12/7/2015	120	118
Residue Total	mg/L	2/2/2015	14	31
Residue Total	mg/L	4/7/2015	13	27
Residue Total	mg/L	6/1/2015	13	30
Residue Total	mg/L	8/10/2015	15	42
Residue Total	mg/L	10/13/2015	15	33
Residue Total	mg/L	12/7/2015	14	30
Residue Total Dissolved	mg/L	2/2/2015	14	29
Residue Total Dissolved	mg/L	4/7/2015	12	27
Residue Total Dissolved	mg/L	6/1/2015	14	22
Residue Total Dissolved	mg/L	8/10/2015	13	26
Residue Total Dissolved	mg/L	10/13/2015	12	25
Residue Total Dissolved	mg/L	12/7/2015	6	14
Residue Total Fixed	mg/L	2/2/2015	7	20
Residue Total Fixed	mg/L	4/7/2015	6	17
Residue Total Fixed	mg/L	6/1/2015	7	20
Residue Total Fixed	mg/L	8/10/2015	10	30
Residue Total Fixed	mg/L	10/13/2015	8	22
Residue Total Fixed	mg/L	12/7/2015	8	20
Residue Total Volatile	mg/L	2/2/2015	7	11
Residue Total Volatile	mg/L	4/7/2015	7	10
Residue Total Volatile	mg/L	6/1/2015	6	10
Residue Total Volatile	mg/L	8/10/2015	6	12
Residue Total Volatile	mg/L	10/13/2015	7	11
Residue Total Volatile	mg/L	12/7/2015	6	9
Selenium Total	µg/L	5/5/2015	<0.5	<0.5
Selenium Total	µg/L	6/1/2015	<0.5	<0.5
Selenium Total	µg/L	10/19/2015	<0.5	<0.5
Selenium Total	µg/L	12/7/2015	<0.5	<0.5
Silica as SiO2	mg/L	2/2/2015	2.4	2.3
Silica as SiO2	mg/L	4/7/2015	2.1	2.1
Silica as SiO2	mg/L	6/1/2015	2.1	2.1
Silica as SiO2	mg/L	8/10/2015	2.2	2.2
Silica as SiO2	mg/L	10/13/2015	2.4	2.4
Silica as SiO2	mg/L	12/7/2015	2.4	2.5
Silver Total	µg/L	5/5/2015	<0.5	<0.5
Silver Total	µg/L	6/1/2015	<0.5	<0.5
Silver Total	µg/L	10/19/2015	<0.5	<0.5
Silver Total	µg/L	12/7/2015	<0.5	<0.5
Sodium Total	µg/L	2/2/2015	472	5210
Sodium Total	µg/L	2/18/2015		5580
Sodium Total	µg/L	4/7/2015	421	4950
Sodium Total	µg/L	5/5/2015	439	5630

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
Sodium Total	µg/L	5/19/2015		5640
Sodium Total	µg/L	6/1/2015	450	6390
Sodium Total	µg/L	8/10/2015	466	5750
Sodium Total	µg/L	8/18/2015		5370
Sodium Total	µg/L	10/13/2015	505	6040
Sodium Total	µg/L	10/19/2015	538	5710
Sodium Total	µg/L	11/23/2015		5370
Sodium Total	µg/L	12/7/2015	481	5260
Sulphate	mg/L	1/5/2015	0.6	0.7
Sulphate	mg/L	2/2/2015	0.6	0.6
Sulphate	mg/L	3/2/2015	0.6	0.6
Sulphate	mg/L	4/7/2015	0.6	0.6
Sulphate	mg/L	5/4/2015	0.6	0.7
Sulphate	mg/L	6/1/2015	0.7	0.7
Sulphate	mg/L	7/6/2015	0.6	0.6
Sulphate	mg/L	8/10/2015	0.7	0.7
Sulphate	mg/L	9/8/2015	0.7	0.7
Sulphate	mg/L	10/13/2015	0.7	0.7
Sulphate	mg/L	11/9/2015	0.7	0.7
Sulphate	mg/L	12/7/2015	0.7	0.7
Temperature	°C	1/5/2015	6.1	5.9
Temperature	°C	1/19/2015	6.2	6.1
Temperature	°C	1/26/2015	6.8	7.3
Temperature	°C	2/2/2015	6.4	7.3
Temperature	°C	2/10/2015	7.3	7.8
Temperature	°C	2/16/2015	6.8	7.1
Temperature	°C	2/23/2015	7.2	7.1
Temperature	°C	3/2/2015	6.5	7.3
Temperature	°C	3/9/2015	6.5	6.7
Temperature	°C	3/16/2015	6.9	7.3
Temperature	°C	3/23/2015	7.4	7.6
Temperature	°C	3/30/2015	8.4	8.9
Temperature	°C	4/7/2015	7.5	7.9
Temperature	°C	4/13/2015	8.9	8.8
Temperature	°C	4/20/2015	7.8	8.9
Temperature	°C	4/27/2015	8	8.2
Temperature	°C	5/4/2015	8.5	9.5
Temperature	°C	5/11/2015	8.5	9.9
Temperature	°C	5/19/2015	9.1	10
Temperature	°C	5/25/2015	8.7	9.9
Temperature	°C	6/1/2015	11	13
Temperature	°C	6/8/2015	12	12
Temperature	°C	6/15/2015	12	14
Temperature	°C	6/22/2015	13	14
Temperature	°C	6/29/2015	14	16

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
Temperature	°C	7/6/2015	16	17
Temperature	°C	7/13/2015	17	18
Temperature	°C	7/20/2015	17	19
Temperature	°C	7/27/2015	17	18
Temperature	°C	8/4/2015	19	20
Temperature	°C	8/10/2015	18	18
Temperature	°C	8/17/2015	19	19
Temperature	°C	8/24/2015	17	18
Temperature	°C	8/31/2015		19
Temperature	°C	9/8/2015	16	16
Temperature	°C	9/14/2015	17	16
Temperature	°C	9/21/2015	13	14
Temperature	°C	9/28/2015	14	14
Temperature	°C	10/5/2015	8.7	9.3
Temperature	°C	10/13/2015	14	14
Temperature	°C	10/19/2015	13	14
Temperature	°C	10/26/2015	13	14
Temperature	°C	11/2/2015	11	12
Temperature	°C	11/3/2015	11	
Temperature	°C	11/4/2015	11	12
Temperature	°C	11/5/2015	11	11
Temperature	°C	11/6/2015	11	11
Temperature	°C	11/7/2015	LA	
Temperature	°C	11/8/2015	LA	
Temperature	°C	11/9/2015	10	10
Temperature	°C	11/10/2015	11	10
Temperature	°C	11/11/2015	LA	
Temperature	°C	11/12/2015	LA	
Temperature	°C	11/13/2015	10	12
Temperature	°C	11/14/2015	10	10
Temperature	°C	11/15/2015	9.8	9.8
Temperature	°C	11/16/2015	9.3	10
Temperature	°C	11/17/2015	9.3	9.7
Temperature	°C	11/18/2015		8.8
Temperature	°C	11/19/2015	8.5	8.5
Temperature	°C	11/20/2015	8.7	8.8
Temperature	°C	11/21/2015	8.2	8.1
Temperature	°C	11/22/2015	8.1	8.1
Temperature	°C	11/23/2015	8.8	8.3
Temperature	°C	11/24/2015	7.9	7.9
Temperature	°C	11/25/2015	7.9	8
Temperature	°C	11/26/2015	7.6	7.3
Temperature	°C	11/27/2015	7.9	7.5
Temperature	°C	11/28/2015	7.5	7.3
Temperature	°C	11/29/2015	7.5	7.3

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
Temperature	°C	11/30/2015	7.1	6.9
Temperature	°C	12/1/2015	7.6	LA
Temperature	°C	12/2/2015	7.5	7.2
Temperature	°C	12/3/2015	7.5	7.4
Temperature	°C	12/4/2015	7.9	LA
Temperature	°C	12/5/2015	7.4	7.4
Temperature	°C	12/6/2015	7.4	7.5
Temperature	°C	12/7/2015	7.3	7.3
Temperature	°C	12/8/2015	7.9	8
Temperature	°C	12/9/2015	7.2	7.4
Temperature	°C	12/10/2015	7.5	7.7
Temperature	°C	12/11/2015	7	7.1
Temperature	°C	12/12/2015	7.1	7.2
Temperature	°C	12/13/2015	7.1	7.2
Temperature	°C	12/14/2015	7.1	7.5
Temperature	°C	12/15/2015	7.4	7.4
Temperature	°C	12/16/2015	6.9	6.8
Temperature	°C	12/17/2015	7.2	LA
Temperature	°C	12/18/2015	6.8	LA
Temperature	°C	12/19/2015	LA	6.8
Temperature	°C	12/20/2015	6.7	6.8
Temperature	°C	12/21/2015	6.9	7.5
Temperature	°C	12/22/2015	6.6	6.7
Temperature	°C	12/23/2015	6.6	6.7
Temperature	°C	12/24/2015	6.4	LA
Temperature	°C	12/26/2015	6.3	6.4
Temperature	°C	12/27/2015	6.6	6.6
Temperature	°C	12/28/2015	6	5.8
Temperature	°C	12/29/2015	6.5	6.8
Temperature	°C	12/30/2015	5.9	5.7
Temperature	°C	12/31/2015	5.9	6
THM-Total Trihalomethanes	ppb	2/18/2015	<2	8.9
THM-Total Trihalomethanes	ppb	5/19/2015		11.1
THM-Total Trihalomethanes	ppb	5/20/2015	<2.0	
THM-Total Trihalomethanes	ppb	8/18/2015	<2.0	7.9
THM-Total Trihalomethanes	ppb	11/23/2015	<2	7.8
Trichloroacetic Acid	ppb	2/18/2015	<0.5	3.8
Trichloroacetic Acid	ppb	5/19/2015		3.8
Trichloroacetic Acid	ppb	5/20/2015	<0.5	
Trichloroacetic Acid	ppb	8/18/2015	<0.5	1.6
Trichloroacetic Acid	ppb	11/23/2015	<0.5	1.7
Turbidity	NTU	1/1/2015	0.51	0.43
Turbidity	NTU	1/2/2015	0.55	0.51
Turbidity	NTU	1/3/2015	0.41	0.38
Turbidity	NTU	1/4/2015	0.44	0.39

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
Turbidity	NTU	1/5/2015	1.3	0.72
Turbidity	NTU	1/6/2015	0.8	0.68
Turbidity	NTU	1/7/2015	1	0.8
Turbidity	NTU	1/8/2015	0.52	0.46
Turbidity	NTU	1/9/2015	0.48	0.42
Turbidity	NTU	1/10/2015	0.4	0.39
Turbidity	NTU	1/11/2015	0.67	0.39
Turbidity	NTU	1/12/2015	0.48	0.38
Turbidity	NTU	1/13/2015	0.41	0.52
Turbidity	NTU	1/14/2015	0.37	0.37
Turbidity	NTU	1/15/2015	0.49	0.45
Turbidity	NTU	1/16/2015	0.53	0.34
Turbidity	NTU	1/17/2015	0.42	0.34
Turbidity	NTU	1/18/2015	0.37	0.32
Turbidity	NTU	1/19/2015	0.46	0.43
Turbidity	NTU	1/20/2015	0.44	0.37
Turbidity	NTU	1/21/2015	0.46	0.4
Turbidity	NTU	1/22/2015	0.42	0.36
Turbidity	NTU	1/23/2015	0.42	0.37
Turbidity	NTU	1/24/2015	5.1	5
Turbidity	NTU	1/25/2015		1.7
Turbidity	NTU	1/26/2015	2	2.2
Turbidity	NTU	1/27/2015	1.4	1.4
Turbidity	NTU	1/28/2015	1.1	0.88
Turbidity	NTU	1/29/2015	0.84	0.8
Turbidity	NTU	1/30/2015	0.62	0.59
Turbidity	NTU	1/31/2015	0.6	0.47
Turbidity	NTU	2/1/2015	0.56	0.55
Turbidity	NTU	2/2/2015	1.3	1.5
Turbidity	NTU	2/3/2015	0.57	0.56
Turbidity	NTU	2/4/2015	0.56	0.55
Turbidity	NTU	2/5/2015	0.57	0.52
Turbidity	NTU	2/6/2015	0.53	0.45
Turbidity	NTU	2/7/2015	0.44	0.34
Turbidity	NTU	2/8/2015	0.32	0.28
Turbidity	NTU	2/9/2015	0.57	0.54
Turbidity	NTU	2/10/2015	0.67	0.64
Turbidity	NTU	2/11/2015	1.4	1.5
Turbidity	NTU	2/12/2015	0.89	0.85
Turbidity	NTU	2/13/2015	0.72	0.7
Turbidity	NTU	2/14/2015	0.55	0.55
Turbidity	NTU	2/15/2015	0.55	0.42
Turbidity	NTU	2/16/2015	0.5	0.49
Turbidity	NTU	2/17/2015	0.59	0.45
Turbidity	NTU	2/18/2015	0.53	0.51

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
Turbidity	NTU	2/19/2015	0.44	0.52
Turbidity	NTU	2/20/2015	0.48	0.47
Turbidity	NTU	2/21/2015	0.39	0.35
Turbidity	NTU	2/22/2015	0.52	0.42
Turbidity	NTU	2/23/2015	0.45	0.42
Turbidity	NTU	2/24/2015	0.48	0.44
Turbidity	NTU	2/25/2015	0.44	0.42
Turbidity	NTU	2/26/2015	0.48	0.43
Turbidity	NTU	2/27/2015	0.48	0.44
Turbidity	NTU	2/28/2015	0.52	0.39
Turbidity	NTU	3/1/2015	0.47	0.35
Turbidity	NTU	3/2/2015	0.41	0.39
Turbidity	NTU	3/3/2015	0.41	0.4
Turbidity	NTU	3/4/2015	0.38	0.36
Turbidity	NTU	3/5/2015	0.49	0.37
Turbidity	NTU	3/6/2015	0.35	0.35
Turbidity	NTU	3/7/2015	0.36	0.32
Turbidity	NTU	3/8/2015	0.39	0.4
Turbidity	NTU	3/9/2015	0.43	0.38
Turbidity	NTU	3/10/2015	0.45	0.37
Turbidity	NTU	3/11/2015	0.43	0.42
Turbidity	NTU	3/12/2015	0.43	0.43
Turbidity	NTU	3/13/2015	0.41	0.5
Turbidity	NTU	3/14/2015	0.38	0.37
Turbidity	NTU	3/15/2015	0.5	0.45
Turbidity	NTU	3/16/2015	0.56	0.55
Turbidity	NTU	3/17/2015	0.7	0.73
Turbidity	NTU	3/18/2015	0.51	0.49
Turbidity	NTU	3/19/2015	0.5	0.51
Turbidity	NTU	3/20/2015	0.67	0.52
Turbidity	NTU	3/21/2015	0.5	0.41
Turbidity	NTU	3/22/2015	0.62	0.5
Turbidity	NTU	3/23/2015	0.77	0.68
Turbidity	NTU	3/24/2015	0.7	0.61
Turbidity	NTU	3/25/2015	0.61	0.62
Turbidity	NTU	3/26/2015	0.77	0.72
Turbidity	NTU	3/27/2015	0.6	0.61
Turbidity	NTU	3/28/2015	0.47	0.44
Turbidity	NTU	3/29/2015	0.42	0.36
Turbidity	NTU	3/30/2015	0.74	0.61
Turbidity	NTU	3/31/2015	0.67	0.61
Turbidity	NTU	4/1/2015	0.47	0.4
Turbidity	NTU	4/2/2015	0.55	0.44
Turbidity	NTU	4/3/2015	0.42	0.39
Turbidity	NTU	4/4/2015	0.38	0.48

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
Turbidity	NTU	4/5/2015	0.4	0.32
Turbidity	NTU	4/6/2015	0.43	0.38
Turbidity	NTU	4/7/2015	0.85	0.43
Turbidity	NTU	4/8/2015	0.39	0.34
Turbidity	NTU	4/9/2015	0.4	0.35
Turbidity	NTU	4/10/2015	0.44	0.44
Turbidity	NTU	4/11/2015	0.34	0.32
Turbidity	NTU	4/12/2015	0.3	0.26
Turbidity	NTU	4/13/2015	0.35	0.29
Turbidity	NTU	4/14/2015	0.51	0.4
Turbidity	NTU	4/15/2015	0.46	0.48
Turbidity	NTU	4/16/2015	0.39	0.41
Turbidity	NTU	4/17/2015	0.45	0.45
Turbidity	NTU	4/18/2015	0.34	0.3
Turbidity	NTU	4/19/2015	0.42	0.32
Turbidity	NTU	4/20/2015	0.4	0.32
Turbidity	NTU	4/21/2015	0.42	0.37
Turbidity	NTU	4/22/2015	0.36	0.32
Turbidity	NTU	4/23/2015	0.36	0.41
Turbidity	NTU	4/24/2015	0.36	0.3
Turbidity	NTU	4/25/2015	0.35	0.27
Turbidity	NTU	4/26/2015	0.32	0.28
Turbidity	NTU	4/27/2015	0.39	0.33
Turbidity	NTU	4/28/2015	0.43	0.35
Turbidity	NTU	4/29/2015	0.38	0.35
Turbidity	NTU	4/30/2015	0.35	0.32
Turbidity	NTU	5/1/2015	0.36	0.37
Turbidity	NTU	5/2/2015	0.37	0.29
Turbidity	NTU	5/3/2015	0.33	0.28
Turbidity	NTU	5/4/2015	0.47	0.35
Turbidity	NTU	5/5/2015	0.38	0.37
Turbidity	NTU	5/6/2015	0.37	0.34
Turbidity	NTU	5/7/2015	0.38	0.3
Turbidity	NTU	5/8/2015	0.37	0.36
Turbidity	NTU	5/9/2015	0.41	0.31
Turbidity	NTU	5/10/2015	0.42	0.3
Turbidity	NTU	5/11/2015	0.4	0.36
Turbidity	NTU	5/12/2015	0.36	0.36
Turbidity	NTU	5/13/2015	0.4	0.37
Turbidity	NTU	5/14/2015	0.48	0.37
Turbidity	NTU	5/15/2015	0.4	0.39
Turbidity	NTU	5/16/2015	0.41	0.3
Turbidity	NTU	5/17/2015	0.35	0.31
Turbidity	NTU	5/18/2015	0.46	0.38
Turbidity	NTU	5/19/2015	0.43	0.54

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
Turbidity	NTU	5/20/2015	0.44	0.34
Turbidity	NTU	5/21/2015	0.34	0.33
Turbidity	NTU	5/22/2015	0.43	0.37
Turbidity	NTU	5/23/2015	0.38	0.28
Turbidity	NTU	5/24/2015	0.39	0.35
Turbidity	NTU	5/25/2015	0.43	0.33
Turbidity	NTU	5/26/2015	0.4	0.36
Turbidity	NTU	5/27/2015	0.4	0.37
Turbidity	NTU	5/28/2015	0.37	0.31
Turbidity	NTU	5/29/2015	0.41	0.32
Turbidity	NTU	5/30/2015	0.41	0.28
Turbidity	NTU	5/31/2015	0.37	0.29
Turbidity	NTU	6/1/2015	0.42	0.31
Turbidity	NTU	6/2/2015	0.43	0.36
Turbidity	NTU	6/3/2015	0.47	0.38
Turbidity	NTU	6/4/2015	0.44	0.34
Turbidity	NTU	6/5/2015	0.49	0.43
Turbidity	NTU	6/6/2015	0.34	0.28
Turbidity	NTU	6/7/2015	0.37	0.34
Turbidity	NTU	6/8/2015	0.42	0.38
Turbidity	NTU	6/9/2015	0.45	0.38
Turbidity	NTU	6/10/2015	0.37	0.36
Turbidity	NTU	6/11/2015	0.37	0.34
Turbidity	NTU	6/12/2015	0.42	0.33
Turbidity	NTU	6/13/2015	0.34	0.31
Turbidity	NTU	6/14/2015	0.37	0.33
Turbidity	NTU	6/15/2015	0.4	0.29
Turbidity	NTU	6/16/2015	0.32	0.31
Turbidity	NTU	6/17/2015	0.36	0.33
Turbidity	NTU	6/18/2015	0.42	0.38
Turbidity	NTU	6/19/2015	0.42	0.36
Turbidity	NTU	6/20/2015	0.36	0.33
Turbidity	NTU	6/21/2015	0.34	0.31
Turbidity	NTU	6/22/2015	0.37	0.29
Turbidity	NTU	6/23/2015	0.33	0.33
Turbidity	NTU	6/24/2015	0.31	0.3
Turbidity	NTU	6/25/2015	0.33	0.27
Turbidity	NTU	6/26/2015	0.36	0.34
Turbidity	NTU	6/27/2015	0.27	0.24
Turbidity	NTU	6/28/2015	0.29	0.2
Turbidity	NTU	6/29/2015	0.28	0.22
Turbidity	NTU	6/30/2015	0.28	0.28
Turbidity	NTU	7/1/2015	0.3	0.23
Turbidity	NTU	7/2/2015	0.28	0.24
Turbidity	NTU	7/3/2015	0.28	0.28

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
Turbidity	NTU	7/4/2015	0.27	0.21
Turbidity	NTU	7/5/2015	0.26	0.22
Turbidity	NTU	7/6/2015	0.29	0.23
Turbidity	NTU	7/7/2015	0.37	0.29
Turbidity	NTU	7/8/2015	0.29	0.26
Turbidity	NTU	7/9/2015	0.29	0.26
Turbidity	NTU	7/10/2015	0.37	0.3
Turbidity	NTU	7/11/2015	0.34	0.24
Turbidity	NTU	7/12/2015	0.26	0.22
Turbidity	NTU	7/13/2015	0.28	0.23
Turbidity	NTU	7/14/2015	0.33	0.32
Turbidity	NTU	7/15/2015	0.36	0.29
Turbidity	NTU	7/16/2015	0.36	0.3
Turbidity	NTU	7/17/2015	0.3	0.25
Turbidity	NTU	7/18/2015	0.33	0.26
Turbidity	NTU	7/19/2015	0.28	0.2
Turbidity	NTU	7/20/2015	0.34	0.32
Turbidity	NTU	7/21/2015	0.33	0.34
Turbidity	NTU	7/22/2015	0.35	0.29
Turbidity	NTU	7/23/2015	0.35	0.32
Turbidity	NTU	7/24/2015	0.31	0.29
Turbidity	NTU	7/25/2015	0.38	0.29
Turbidity	NTU	7/26/2015	0.37	0.24
Turbidity	NTU	7/27/2015	0.37	0.31
Turbidity	NTU	7/28/2015	0.38	0.32
Turbidity	NTU	7/29/2015	0.38	0.34
Turbidity	NTU	7/30/2015	0.34	0.26
Turbidity	NTU	7/31/2015	0.35	0.29
Turbidity	NTU	8/1/2015	0.45	0.32
Turbidity	NTU	8/2/2015	0.28	0.25
Turbidity	NTU	8/3/2015	0.27	0.25
Turbidity	NTU	8/4/2015	0.29	0.26
Turbidity	NTU	8/5/2015	0.33	0.29
Turbidity	NTU	8/6/2015	0.34	0.3
Turbidity	NTU	8/7/2015	0.32	0.25
Turbidity	NTU	8/8/2015	0.33	0.28
Turbidity	NTU	8/9/2015	0.35	0.3
Turbidity	NTU	8/10/2015	0.32	0.3
Turbidity	NTU	8/11/2015	0.33	0.26
Turbidity	NTU	8/12/2015	0.34	0.26
Turbidity	NTU	8/13/2015	0.4	0.33
Turbidity	NTU	8/14/2015	0.37	0.38
Turbidity	NTU	8/15/2015	0.31	0.32
Turbidity	NTU	8/16/2015	0.27	0.24
Turbidity	NTU	8/17/2015	0.41	0.32

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
Turbidity	NTU	8/18/2015	0.3	0.31
Turbidity	NTU	8/19/2015	0.33	0.34
Turbidity	NTU	8/20/2015	0.36	0.35
Turbidity	NTU	8/21/2015	0.35	0.29
Turbidity	NTU	8/22/2015	0.32	0.31
Turbidity	NTU	8/23/2015	0.33	0.29
Turbidity	NTU	8/24/2015	0.39	0.35
Turbidity	NTU	8/25/2015	0.41	0.32
Turbidity	NTU	8/26/2015	0.4	0.37
Turbidity	NTU	8/27/2015	0.41	0.33
Turbidity	NTU	8/28/2015	0.41	0.33
Turbidity	NTU	8/29/2015	0.43	0.38
Turbidity	NTU	8/30/2015		0.33
Turbidity	NTU	8/31/2015		0.73
Turbidity	NTU	9/1/2015	2.3	1.9
Turbidity	NTU	9/2/2015	1.7	1.4
Turbidity	NTU	9/3/2015	0.81	0.76
Turbidity	NTU	9/4/2015	0.92	0.9
Turbidity	NTU	9/5/2015	0.88	0.83
Turbidity	NTU	9/6/2015	0.97	0.89
Turbidity	NTU	9/7/2015	0.85	0.69
Turbidity	NTU	9/8/2015	0.77	0.63
Turbidity	NTU	9/9/2015	0.79	0.67
Turbidity	NTU	9/10/2015	0.95	0.74
Turbidity	NTU	9/11/2015	0.78	0.68
Turbidity	NTU	9/12/2015	0.65	0.64
Turbidity	NTU	9/13/2015	0.68	0.54
Turbidity	NTU	9/14/2015	0.72	0.63
Turbidity	NTU	9/15/2015	0.69	0.47
Turbidity	NTU	9/16/2015	0.57	0.47
Turbidity	NTU	9/17/2015	0.57	0.48
Turbidity	NTU	9/18/2015	0.51	0.44
Turbidity	NTU	9/19/2015	0.53	0.46
Turbidity	NTU	9/20/2015	0.71	0.64
Turbidity	NTU	9/21/2015	0.69	0.57
Turbidity	NTU	9/22/2015	0.71	0.64
Turbidity	NTU	9/23/2015	0.6	0.53
Turbidity	NTU	9/24/2015	0.56	0.5
Turbidity	NTU	9/25/2015	0.58	0.42
Turbidity	NTU	9/26/2015	0.57	0.48
Turbidity	NTU	9/27/2015	0.58	0.42
Turbidity	NTU	9/28/2015	0.51	0.41
Turbidity	NTU	9/29/2015	0.48	0.51
Turbidity	NTU	9/30/2015	0.53	0.43
Turbidity	NTU	10/1/2015	0.57	0.44

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
Turbidity	NTU	10/2/2015	0.5	0.39
Turbidity	NTU	10/3/2015	0.51	0.51
Turbidity	NTU	10/4/2015	0.47	0.41
Turbidity	NTU	10/5/2015	0.45	0.38
Turbidity	NTU	10/6/2015	0.51	0.43
Turbidity	NTU	10/7/2015	0.44	0.42
Turbidity	NTU	10/8/2015	0.49	0.45
Turbidity	NTU	10/9/2015	0.49	0.4
Turbidity	NTU	10/10/2015	0.5	0.38
Turbidity	NTU	10/11/2015	0.53	0.37
Turbidity	NTU	10/12/2015	0.44	0.35
Turbidity	NTU	10/13/2015	0.45	0.35
Turbidity	NTU	10/14/2015	0.46	0.36
Turbidity	NTU	10/15/2015	0.41	0.37
Turbidity	NTU	10/16/2015	0.43	0.43
Turbidity	NTU	10/17/2015	0.42	0.29
Turbidity	NTU	10/18/2015	0.39	0.29
Turbidity	NTU	10/19/2015	0.38	0.35
Turbidity	NTU	10/20/2015	0.44	0.32
Turbidity	NTU	10/21/2015	0.41	0.43
Turbidity	NTU	10/22/2015	0.43	0.34
Turbidity	NTU	10/23/2015	0.37	0.31
Turbidity	NTU	10/24/2015	0.35	0.29
Turbidity	NTU	10/25/2015	0.3	0.26
Turbidity	NTU	10/26/2015	0.42	0.28
Turbidity	NTU	10/27/2015	0.41	0.28
Turbidity	NTU	10/28/2015	0.35	0.28
Turbidity	NTU	10/29/2015	0.39	0.37
Turbidity	NTU	10/30/2015	0.43	0.33
Turbidity	NTU	10/31/2015	0.5	0.44
Turbidity	NTU	11/1/2015	0.44	0.41
Turbidity	NTU	11/2/2015	0.63	0.58
Turbidity	NTU	11/3/2015	0.47	0.48
Turbidity	NTU	11/4/2015	0.43	0.38
Turbidity	NTU	11/5/2015	0.36	0.32
Turbidity	NTU	11/6/2015	0.37	0.38
Turbidity	NTU	11/7/2015	0.79	0.64
Turbidity	NTU	11/8/2015	0.97	0.93
Turbidity	NTU	11/9/2015	0.75	0.72
Turbidity	NTU	11/10/2015	0.68	0.62
Turbidity	NTU	11/11/2015	0.48	0.42
Turbidity	NTU	11/12/2015	0.56	0.53
Turbidity	NTU	11/13/2015	1	0.64
Turbidity	NTU	11/14/2015	0.69	0.53
Turbidity	NTU	11/15/2015	0.59	0.46

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
Turbidity	NTU	11/16/2015	0.85	0.55
Turbidity	NTU	11/17/2015	0.87	0.56
Turbidity	NTU	11/18/2015		0.59
Turbidity	NTU	11/19/2015	0.77	0.79
Turbidity	NTU	11/20/2015	0.79	0.73
Turbidity	NTU	11/21/2015	0.69	0.63
Turbidity	NTU	11/22/2015	0.65	0.52
Turbidity	NTU	11/23/2015	0.66	0.58
Turbidity	NTU	11/24/2015	0.63	0.56
Turbidity	NTU	11/25/2015	0.7	0.61
Turbidity	NTU	11/26/2015	0.64	0.56
Turbidity	NTU	11/27/2015	0.64	0.58
Turbidity	NTU	11/28/2015	0.53	0.49
Turbidity	NTU	11/29/2015	0.51	0.42
Turbidity	NTU	11/30/2015	0.54	0.43
Turbidity	NTU	12/1/2015	0.61	0.49
Turbidity	NTU	12/2/2015	0.7	0.53
Turbidity	NTU	12/3/2015	0.51	0.46
Turbidity	NTU	12/4/2015	0.77	0.63
Turbidity	NTU	12/5/2015	0.58	0.54
Turbidity	NTU	12/6/2015	0.53	0.52
Turbidity	NTU	12/7/2015	0.69	0.52
Turbidity	NTU	12/8/2015	0.65	0.56
Turbidity	NTU	12/9/2015	0.45	0.42
Turbidity	NTU	12/10/2015	0.58	0.57
Turbidity	NTU	12/11/2015	0.57	0.52
Turbidity	NTU	12/12/2015	0.51	0.41
Turbidity	NTU	12/13/2015	0.5	0.48
Turbidity	NTU	12/14/2015	0.9	0.7
Turbidity	NTU	12/15/2015	0.59	0.57
Turbidity	NTU	12/16/2015	0.78	0.55
Turbidity	NTU	12/17/2015	0.58	0.6
Turbidity	NTU	12/18/2015	0.58	0.51
Turbidity	NTU	12/19/2015	0.48	0.49
Turbidity	NTU	12/20/2015	0.47	0.46
Turbidity	NTU	12/21/2015	0.47	0.43
Turbidity	NTU	12/22/2015	0.56	0.54
Turbidity	NTU	12/23/2015	0.48	0.44
Turbidity	NTU	12/24/2015	0.48	0.39
Turbidity	NTU	12/26/2015	0.43	0.38
Turbidity	NTU	12/27/2015	0.4	0.37
Turbidity	NTU	12/28/2015	0.42	0.33
Turbidity	NTU	12/29/2015	0.42	0.35
Turbidity	NTU	12/30/2015	0.41	0.37
Turbidity	NTU	12/31/2015	0.37	0.35

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
UV 254 - Transmittance	%	1/2/2015	82.1	94.1
UV 254 - Transmittance	%	1/5/2015	80.4	93.4
UV 254 - Transmittance	%	1/7/2015	81.6	93.5
UV 254 - Transmittance	%	1/8/2015	82.2	94.2
UV 254 - Transmittance	%	1/9/2015	82.2	93.3
UV 254 - Transmittance	%	1/12/2015	82.5	93.7
UV 254 - Transmittance	%	1/15/2015	83	93.6
UV 254 - Transmittance	%	1/19/2015	82.7	93.2
UV 254 - Transmittance	%	1/20/2015	82.6	92.9
UV 254 - Transmittance	%	1/21/2015	81.6	92.3
UV 254 - Transmittance	%	1/22/2015	82.1	93.2
UV 254 - Transmittance	%	1/23/2015	82.8	93.2
UV 254 - Transmittance	%	1/26/2015	79.2	91.4
UV 254 - Transmittance	%	1/27/2015	80.1	91.7
UV 254 - Transmittance	%	1/28/2015	81.6	93.1
UV 254 - Transmittance	%	1/29/2015	81.4	92.7
UV 254 - Transmittance	%	1/30/2015	82.4	93.3
UV 254 - Transmittance	%	2/2/2015	82.3	92.9
UV 254 - Transmittance	%	2/4/2015	81.7	<98.9
UV 254 - Transmittance	%	2/6/2015	82.9	93.3
UV 254 - Transmittance	%	2/10/2015	82.7	93.3
UV 254 - Transmittance	%	2/11/2015	81.5	92.3
UV 254 - Transmittance	%	2/13/2015	81.7	93
UV 254 - Transmittance	%	2/16/2015	82.1	92.9
UV 254 - Transmittance	%	2/18/2015	81.9	93.4
UV 254 - Transmittance	%	2/20/2015	82.1	92.9
UV 254 - Transmittance	%	2/24/2015	82.5	93.4
UV 254 - Transmittance	%	2/27/2015	81.5	93
UV 254 - Transmittance	%	3/31/2015	81.6	93.2
UV 254 - Transmittance	%	4/1/2015	82.3	93
UV 254 - Transmittance	%	4/7/2015	80.9	92.1
UV 254 - Transmittance	%	4/10/2015	81.5	92.5
UV 254 - Transmittance	%	4/14/2015	80.5	91.8
UV 254 - Transmittance	%	4/21/2015	81.2	92.8
UV 254 - Transmittance	%	4/24/2015	81.9	94.5
UV 254 - Transmittance	%	4/29/2015	82.1	93.6
UV 254 - Transmittance	%	5/1/2015	81.5	92.6
UV 254 - Transmittance	%	5/4/2015	81.9	92.8
UV 254 - Transmittance	%	5/6/2015	81.9	93.2
UV 254 - Transmittance	%	5/8/2015	82.2	93.1
UV 254 - Transmittance	%	5/11/2015	82.2	92.7
UV 254 - Transmittance	%	5/14/2015	81.9	92.7
UV 254 - Transmittance	%	5/20/2015	82.4	92.7
UV 254 - Transmittance	%	5/22/2015	82.7	93.4
UV 254 - Transmittance	%	5/25/2015	82.3	92.9

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
UV 254 - Transmittance	%	5/27/2015	82.4	92.6
UV 254 - Transmittance	%	5/29/2015	82.3	93
UV 254 - Transmittance	%	6/2/2015	82.8	93.3
UV 254 - Transmittance	%	6/8/2015	82.9	93.4
UV 254 - Transmittance	%	6/12/2015	82.9	93.2
UV 254 - Transmittance	%	6/15/2015	83.3	93.5
UV 254 - Transmittance	%	6/22/2015	84.1	94.1
UV 254 - Transmittance	%	6/26/2015	83.8	93.6
UV 254 - Transmittance	%	6/30/2015	85.5	94.7
UV 254 - Transmittance	%	7/2/2015	84.6	94.9
UV 254 - Transmittance	%	7/6/2015	85.3	95.2
UV 254 - Transmittance	%	7/8/2015	85.7	94.8
UV 254 - Transmittance	%	7/9/2015	85	94.8
UV 254 - Transmittance	%	7/10/2015	84.8	94.3
UV 254 - Transmittance	%	7/13/2015	86.1	94.9
UV 254 - Transmittance	%	7/15/2015	85.9	95
UV 254 - Transmittance	%	7/16/2015	85.5	94.1
UV 254 - Transmittance	%	7/21/2015	86.8	95.5
UV 254 - Transmittance	%	7/22/2015	86.4	95.6
UV 254 - Transmittance	%	7/23/2015	86.7	94.9
UV 254 - Transmittance	%	7/28/2015	86.9	95.6
UV 254 - Transmittance	%	7/29/2015	86.9	95.7
UV Absorbance 254 nm	Abs/cm	1/5/2015	0.088	0.025
UV Absorbance 254 nm	Abs/cm	1/12/2015	0.079	0.025
UV Absorbance 254 nm	Abs/cm	1/19/2015	0.076	0.026
UV Absorbance 254 nm	Abs/cm	1/26/2015	0.094	0.027
UV Absorbance 254 nm	Abs/cm	2/2/2015	0.082	0.027
UV Absorbance 254 nm	Abs/cm	2/10/2015	0.078	0.024
UV Absorbance 254 nm	Abs/cm	2/16/2015	0.077	0.023
UV Absorbance 254 nm	Abs/cm	2/23/2015	0.077	0.025
UV Absorbance 254 nm	Abs/cm	3/2/2015	0.078	0.026
UV Absorbance 254 nm	Abs/cm	3/9/2015	0.079	0.024
UV Absorbance 254 nm	Abs/cm	3/16/2015	0.082	0.038
UV Absorbance 254 nm	Abs/cm	3/23/2015	0.086	0.03
UV Absorbance 254 nm	Abs/cm	3/30/2015	0.095	0.037
UV Absorbance 254 nm	Abs/cm	4/7/2015	0.083	0.027
UV Absorbance 254 nm	Abs/cm	4/13/2015	0.081	0.028
UV Absorbance 254 nm	Abs/cm	4/20/2015	0.083	0.027
UV Absorbance 254 nm	Abs/cm	4/27/2015	0.081	0.023
UV Absorbance 254 nm	Abs/cm	5/4/2015	0.082	0.027
UV Absorbance 254 nm	Abs/cm	5/11/2015	0.08	0.027
UV Absorbance 254 nm	Abs/cm	5/19/2015	0.077	0.025
UV Absorbance 254 nm	Abs/cm	5/25/2015	0.078	0.028
UV Absorbance 254 nm	Abs/cm	6/1/2015	0.076	0.025
UV Absorbance 254 nm	Abs/cm	6/8/2015	0.075	0.029

Analysis - Coquitlam	Units	Date Sampled	Source	Treated
UV Absorbance 254 nm	Abs/cm	6/15/2015	0.073	0.026
UV Absorbance 254 nm	Abs/cm	6/22/2015	0.07	0.023
UV Absorbance 254 nm	Abs/cm	6/29/2015	0.069	0.023
UV Absorbance 254 nm	Abs/cm	7/6/2015	0.065	0.018
UV Absorbance 254 nm	Abs/cm	7/13/2015	0.062	0.016
UV Absorbance 254 nm	Abs/cm	7/20/2015	0.063	0.02
UV Absorbance 254 nm	Abs/cm	7/27/2015	0.055	0.016
UV Absorbance 254 nm	Abs/cm	8/4/2015	0.054	0.016
UV Absorbance 254 nm	Abs/cm	8/10/2015	0.053	0.015
UV Absorbance 254 nm	Abs/cm	8/17/2015	0.052	0.015
UV Absorbance 254 nm	Abs/cm	8/24/2015	0.054	0.017
UV Absorbance 254 nm	Abs/cm	8/31/2015		0.016
UV Absorbance 254 nm	Abs/cm	9/8/2015	0.065	0.016
UV Absorbance 254 nm	Abs/cm	9/14/2015	0.066	0.021
UV Absorbance 254 nm	Abs/cm	9/21/2015	0.079	0.021
UV Absorbance 254 nm	Abs/cm	9/28/2015	0.067	0.022
UV Absorbance 254 nm	Abs/cm	10/5/2015	0.066	0.017
UV Absorbance 254 nm	Abs/cm	10/13/2015	0.076	0.022
UV Absorbance 254 nm	Abs/cm	10/19/2015	0.07	0.019
UV Absorbance 254 nm	Abs/cm	10/26/2015	0.066	0.018
UV Absorbance 254 nm	Abs/cm	11/2/2015	0.1	0.027
UV Absorbance 254 nm	Abs/cm	11/9/2015	0.099	0.025
UV Absorbance 254 nm	Abs/cm	11/16/2015	0.086	0.024
UV Absorbance 254 nm	Abs/cm	11/23/2015	0.082	0.024
UV Absorbance 254 nm	Abs/cm	11/30/2015	0.081	0.023
UV Absorbance 254 nm	Abs/cm	12/7/2015	0.093	0.028
UV Absorbance 254 nm	Abs/cm	12/14/2015	0.08	0.026
UV Absorbance 254 nm	Abs/cm	12/21/2015	0.082	0.026
Zinc Total	µg/L	5/5/2015	<3	<3
Zinc Total	µg/L	6/1/2015	<3	<3
Zinc Total	µg/L	10/19/2015	<3	<3
Zinc Total	µg/L	12/7/2015	<3	<3

		Point Roberts Main	Langley Main	37th Ave at Manitoba	Bose Rd & 126th Main	Ferry & Dyke Main	Maple Ridge Chamber Main	Seymour at Grandview Main
Analysis	Sampled Date	GV-029	GV-034	GV-050	GV-054	GV-066	GV-098	GV-128
Bromate mg/L	2/16/2015	<0.01			<0.01	<0.01		<0.01
Bromate mg/L	2/17/2015		<0.01					
Bromate mg/L	2/18/2015			<0.01			<0.01	
Bromate mg/L	5/20/2015	<0.01	<0.01			<0.01		
Bromate mg/L	5/21/2015			<0.01			<0.01	
Bromate mg/L	5/22/2015				<0.01			<0.01
Bromate mg/L	8/17/2015	<0.01				<0.01		
Bromate mg/L	8/18/2015				<0.01			<0.01
Bromate mg/L	8/19/2015			<0.01			<0.01	
Bromate mg/L	8/20/2015		<0.01					
Bromate mg/L	11/23/2015	<0.01			<0.01			
Bromate mg/L	11/24/2015		<0.01					
Bromate mg/L	11/25/2015			<0.01			<0.01	
Bromate mg/L	11/26/2015					<0.01		<0.01
Bromide mg/L	2/16/2015	<0.01			<0.01	<0.01		<0.01
Bromide mg/L	2/17/2015		<0.01					
Bromide mg/L	2/18/2015			<0.01			<0.01	
Bromide mg/L	5/20/2015	<0.01	<0.01			<0.01		
Bromide mg/L	5/21/2015			<0.01			<0.01	
Bromide mg/L	5/22/2015				<0.01			<0.01
Bromide mg/L	8/17/2015	<0.01				<0.01		
Bromide mg/L	8/18/2015				<0.01			<0.01
Bromide mg/L	8/19/2015			<0.01			<0.01	
Bromide mg/L	8/20/2015		<0.01					
Bromide mg/L	11/23/2015	<0.01			<0.01			
Bromide mg/L	11/24/2015		<0.01					
Bromide mg/L	11/25/2015			<0.01			<0.01	
Bromide mg/L	11/26/2015					<0.01		<0.01
Bromodichloromethane ppb	2/16/2015	<1			<1	<1		<1

		Point Roberts Main	Langley Main	37th Ave at Manitoba	Bose Rd & 126th Main	Ferry & Dyke Main	Maple Ridge Chamber Main	Seymour at Grandview Main
Analysis	Sampled Date	GV-029	GV-034	GV-050	GV-054	GV-066	GV-098	GV-128
Bromodichloromethane ppb	2/17/2015		<1					
Bromodichloromethane ppb	2/18/2015			<1			<1	
Bromodichloromethane ppb	5/20/2015	<1	<1			<1		
Bromodichloromethane ppb	5/21/2015			<1			<1	
Bromodichloromethane ppb	5/22/2015				<1			<1
Bromodichloromethane ppb	8/17/2015	1				2		
Bromodichloromethane ppb	8/18/2015				<1			<1
Bromodichloromethane ppb	8/19/2015			1			1	
Bromodichloromethane ppb	8/20/2015		1					
Bromodichloromethane ppb	11/23/2015	<1			<1			
Bromodichloromethane ppb	11/24/2015		<1					
Bromodichloromethane ppb	11/25/2015			<1			<1	
Bromodichloromethane ppb	11/26/2015					<1		<1
Bromoform ppb	2/16/2015	<1			<1	<1		<1
Bromoform ppb	2/17/2015		<1					
Bromoform ppb	2/18/2015			<1			<1	
Bromoform ppb	5/20/2015	<1	<1			<1		
Bromoform ppb	5/21/2015			<1			<1	
Bromoform ppb	5/22/2015				<1			<1
Bromoform ppb	8/17/2015	<1				<1		
Bromoform ppb	8/18/2015				<1			<1
Bromoform ppb	8/19/2015			<1			<1	
Bromoform ppb	8/20/2015		<1					
Bromoform ppb	11/23/2015	<1			<1			
Bromoform ppb	11/24/2015		<1					
Bromoform ppb	11/25/2015			<1			<1	
Bromoform ppb	11/26/2015					<1		<1
Chlorate mg/L	2/16/2015	0.04			0.01	0.03		0.01
Chlorate mg/L	2/17/2015		0.02					

		Point Roberts Main	Langley Main	37th Ave at Manitoba	Bose Rd & 126th Main	Ferry & Dyke Main	Maple Ridge Chamber Main	Seymour at Grandview Main
Analysis	Sampled Date	GV-029	GV-034	GV-050	GV-054	GV-066	GV-098	GV-128
Chlorate mg/L	2/18/2015			0.02			<0.01	
Chlorate mg/L	5/20/2015	0.01	0.01			0.04		
Chlorate mg/L	5/21/2015			0.02			<0.01	
Chlorate mg/L	5/22/2015				0.02			0.02
Chlorate mg/L	8/17/2015	0.03				0.08		
Chlorate mg/L	8/18/2015				0.02			0.06
Chlorate mg/L	8/19/2015			0.02			0.04	
Chlorate mg/L	8/20/2015		0.04					
Chlorate mg/L	11/23/2015	0.02			0.02			
Chlorate mg/L	11/24/2015		0.03					
Chlorate mg/L	11/25/2015			0.02			<0.01	
Chlorate mg/L	11/26/2015					0.03		0.08
Chloride mg/L	2/16/2015	2.9			2.4	2.8		2.2
Chloride mg/L	2/17/2015		2.7					
Chloride mg/L	2/18/2015			2.5			2.2	
Chloride mg/L	5/20/2015	2.5	2.6			2.6		
Chloride mg/L	5/21/2015			2.5			2.5	
Chloride mg/L	5/22/2015				2.5			2.9
Chloride mg/L	8/17/2015	2.6				2.9		
Chloride mg/L	8/18/2015				2.4			3.1
Chloride mg/L	8/19/2015			2.5			2.6	
Chloride mg/L	8/20/2015		2.8					
Chloride mg/L	11/23/2015	3.1			2.9			
Chloride mg/L	11/24/2015		3.1					
Chloride mg/L	11/25/2015			2.9			2.8	
Chloride mg/L	11/26/2015					3.1		3.6

Analysis	Sampled Date	Point Roberts Main GV-029	Langley Main GV-034	37th Ave at Manitoba GV-050	Bose Rd & 126th Main GV-054	Ferry & Dyke Main GV-066	Maple Ridge Chamber Main GV-098	Seymour at Grandview Main GV-128
Chlorine Free mg/L	1/5/2015	0.64			0.18	0.76		0.72
Chlorine Free mg/L	1/6/2015				0.56			
Chlorine Free mg/L	1/7/2015	0.6	0.94	0.95		0.81	0.49	
Chlorine Free mg/L	1/8/2015			0.86				
Chlorine Free mg/L	1/9/2015	0.64				0.95	0.58	
Chlorine Free mg/L	1/12/2015	0.83			0.46	0.91		0.83
Chlorine Free mg/L	1/14/2015		0.65	0.67			0.41	
Chlorine Free mg/L	1/15/2015	0.65				0.54		
Chlorine Free mg/L	1/16/2015						0.45	
Chlorine Free mg/L	1/19/2015				0.58			0.77
Chlorine Free mg/L	1/21/2015		0.71	0.55			0.39	
Chlorine Free mg/L	1/22/2015	0.75			0.52	0.63		0.82
Chlorine Free mg/L	1/23/2015		0.52					
Chlorine Free mg/L	1/26/2015				0.59			1.1
Chlorine Free mg/L	1/27/2015		1.3					
Chlorine Free mg/L	1/28/2015			0.67			0.65	
Chlorine Free mg/L	1/29/2015	0.54				0.57		
Chlorine Free mg/L	1/30/2015	0.64		0.65		0.82		1.1
Chlorine Free mg/L	2/2/2015			0.71				
Chlorine Free mg/L	2/4/2015		0.77		0.51			0.58
Chlorine Free mg/L	2/5/2015	0.68				0.79	0.62	
Chlorine Free mg/L	2/6/2015	0.74				0.77	0.36	
Chlorine Free mg/L	2/10/2015	0.47				0.57		
Chlorine Free mg/L	2/12/2015		1	0.52	0.51		0.66	0.78
Chlorine Free mg/L	2/13/2015	0.52				0.62	0.62	
Chlorine Free mg/L	2/16/2015	0.63			0.61	0.54		0.9
Chlorine Free mg/L	2/17/2015		0.86					
Chlorine Free mg/L	2/18/2015	0.57		0.67		0.82	0.55	
Chlorine Free mg/L	2/19/2015		0.91	0.59				

		Point Roberts Main	Langley Main	37th Ave at Manitoba	Bose Rd & 126th Main	Ferry & Dyke Main	Maple Ridge Chamber Main	Seymour at Grandview Main
Analysis	Sampled Date	GV-029	GV-034	GV-050	GV-054	GV-066	GV-098	GV-128
Chlorine Free mg/L	2/20/2015		0.96		0.72			0.91
Chlorine Free mg/L	2/23/2015	0.69			0.56	0.87		0.9
Chlorine Free mg/L	2/24/2015		1.1	0.54				
Chlorine Free mg/L	2/25/2015	0.73				0.51	0.68	
Chlorine Free mg/L	2/26/2015			0.82				
Chlorine Free mg/L	2/27/2015	0.71	1			0.73		0.98
Chlorine Free mg/L	3/2/2015	0.57		0.69		0.64		
Chlorine Free mg/L	3/3/2015				0.37			0.7
Chlorine Free mg/L	3/4/2015		0.92				0.62	
Chlorine Free mg/L	3/5/2015		0.4			0.66		0.61
Chlorine Free mg/L	3/6/2015			0.8	0.53			0.77
Chlorine Free mg/L	3/9/2015	0.73				0.86		
Chlorine Free mg/L	3/10/2015		0.75		0.57			1
Chlorine Free mg/L	3/11/2015	0.52	1	0.64		0.72	0.57	0.76
Chlorine Free mg/L	3/12/2015			0.71			0.64	
Chlorine Free mg/L	3/13/2015	0.68		0.71	0.62	0.82		1.1
Chlorine Free mg/L	3/17/2015	0.78				0.61		
Chlorine Free mg/L	3/18/2015		0.61	0.71	0.77			0.87
Chlorine Free mg/L	3/19/2015		1					
Chlorine Free mg/L	3/24/2015			0.6				
Chlorine Free mg/L	3/25/2015	0.79	0.97			0.89		
Chlorine Free mg/L	3/26/2015			0.75	0.42			0.67
Chlorine Free mg/L	3/27/2015		0.99					1
Chlorine Free mg/L	3/31/2015		0.88					
Chlorine Free mg/L	4/1/2015		0.9	0.8	0.55		0.63	0.86
Chlorine Free mg/L	4/2/2015	0.47				0.49		
Chlorine Free mg/L	4/7/2015	0.71		0.84		0.85		
Chlorine Free mg/L	4/9/2015		0.79		0.58		0.73	0.94
Chlorine Free mg/L	4/10/2015	0.91	0.62			0.74	0.51	

		Point Roberts Main	Langley Main	37th Ave at Manitoba	Bose Rd & 126th Main	Ferry & Dyke Main	Maple Ridge Chamber Main	Seymour at Grandview Main
Analysis	Sampled Date	GV-029	GV-034	GV-050	GV-054	GV-066	GV-098	GV-128
Chlorine Free mg/L	4/13/2015	0.67	0.42		0.63	0.88		0.66
Chlorine Free mg/L	4/15/2015		0.8	0.73				
Chlorine Free mg/L	4/16/2015	0.92				0.96	0.47	
Chlorine Free mg/L	4/17/2015		0.84	0.7	0.57		0.62	0.45
Chlorine Free mg/L	4/20/2015	0.66				0.78		
Chlorine Free mg/L	4/22/2015			1				
Chlorine Free mg/L	4/23/2015		0.8				0.37	
Chlorine Free mg/L	4/24/2015				0.66			0.74
Chlorine Free mg/L	4/28/2015	0.39	1			0.5		
Chlorine Free mg/L	4/29/2015			0.5	0.75			0.82
Chlorine Free mg/L	4/30/2015						0.38	
Chlorine Free mg/L	5/1/2015	0.55		0.74	0.56	0.82		1
Chlorine Free mg/L	5/4/2015	0.82		0.54		0.89		
Chlorine Free mg/L	5/5/2015				0.74			0.74
Chlorine Free mg/L	5/6/2015		0.85					
Chlorine Free mg/L	5/7/2015	0.55	0.82	0.62		0.9	0.56	
Chlorine Free mg/L	5/8/2015			0.68				
Chlorine Free mg/L	5/11/2015	0.64				0.71		
Chlorine Free mg/L	5/12/2015		0.87					
Chlorine Free mg/L	5/13/2015	0.66		0.61		0.7	0.63	
Chlorine Free mg/L	5/14/2015				0.58		0.53	1
Chlorine Free mg/L	5/15/2015	0.57	0.92	0.56		0.75	0.62	
Chlorine Free mg/L	5/20/2015	0.41	0.83			0.54		
Chlorine Free mg/L	5/21/2015			0.69			0.35	
Chlorine Free mg/L	5/22/2015		0.75		0.49	0.95	0.69	0.78
Chlorine Free mg/L	5/25/2015	0.42				0.77		

		Point Roberts Main	Langley Main	37th Ave at Manitoba	Bose Rd & 126th Main	Ferry & Dyke Main	Maple Ridge Chamber Main	Seymour at Grandview Main
Analysis	Sampled Date	GV-029	GV-034	GV-050	GV-054	GV-066	GV-098	GV-128
Chlorine Free mg/L	5/26/2015			0.7				
Chlorine Free mg/L	5/27/2015	0.56	0.96		0.57	0.86	0.36	0.94
Chlorine Free mg/L	5/28/2015	0.53		0.64	0.64	0.91		0.92
Chlorine Free mg/L	5/29/2015		0.74					0.95
Chlorine Free mg/L	6/1/2015	0.57			0.65	0.86		1
Chlorine Free mg/L	6/3/2015		0.73	0.61				
Chlorine Free mg/L	6/4/2015	0.43		1		0.66	0.91	
Chlorine Free mg/L	6/5/2015	0.47	0.78			0.53	0.89	
Chlorine Free mg/L	6/8/2015	0.58		0.58		0.9		
Chlorine Free mg/L	6/9/2015		0.87					
Chlorine Free mg/L	6/10/2015			0.59	0.6	0.98	0.59	0.97
Chlorine Free mg/L	6/11/2015			0.7				
Chlorine Free mg/L	6/12/2015		0.72	0.74				1
Chlorine Free mg/L	6/15/2015	0.7			0.84	0.72		1.3
Chlorine Free mg/L	6/17/2015	0.73	0.92	0.68		0.75	0.46	
Chlorine Free mg/L	6/18/2015			0.65				
Chlorine Free mg/L	6/19/2015		0.78					0.85
Chlorine Free mg/L	6/22/2015	0.54				0.67		
Chlorine Free mg/L	6/23/2015				0.57			0.99
Chlorine Free mg/L	6/24/2015	0.64	1	0.69		0.76	0.4	
Chlorine Free mg/L	6/26/2015		0.63	0.71	0.78		0.54	1.3
Chlorine Free mg/L	6/29/2015	0.49			0.8	0.74		1.3
Chlorine Free mg/L	6/30/2015			0.67				
Chlorine Free mg/L	7/2/2015	0.62	0.76			0.91	0.22	
Chlorine Free mg/L	7/3/2015		0.68	0.6				
Chlorine Free mg/L	7/6/2015		0.92					
Chlorine Free mg/L	7/7/2015						0.59	
Chlorine Free mg/L	7/8/2015			0.78				
Chlorine Free mg/L	7/9/2015	0.64			0.84	0.65		1.2

		Point Roberts Main	Langley Main	37th Ave at Manitoba	Bose Rd & 126th Main	Ferry & Dyke Main	Maple Ridge Chamber Main	Seymour at Grandview Main
Analysis	Sampled Date	GV-029	GV-034	GV-050	GV-054	GV-066	GV-098	GV-128
Chlorine Free mg/L	7/10/2015		0.71				0.52	
Chlorine Free mg/L	7/11/2015						0.5	
Chlorine Free mg/L	7/12/2015						0.88	
Chlorine Free mg/L	7/13/2015				0.69			1
Chlorine Free mg/L	7/15/2015			0.72			0.31	
Chlorine Free mg/L	7/16/2015	0.76	0.69			0.79		
Chlorine Free mg/L	7/17/2015		0.59	0.61		0.54		
Chlorine Free mg/L	7/21/2015		0.83					
Chlorine Free mg/L	7/22/2015	0.61				0.59	0.6	
Chlorine Free mg/L	7/23/2015			0.35				
Chlorine Free mg/L	7/24/2015				0.82			0.86
Chlorine Free mg/L	7/27/2015				0.79			0.98
Chlorine Free mg/L	7/28/2015			0.76				
Chlorine Free mg/L	7/29/2015		0.81				0.33	
Chlorine Free mg/L	7/30/2015	0.51		0.56		0.64		
Chlorine Free mg/L	7/31/2015			0.89	1			0.94
Chlorine Free mg/L	8/4/2015				1			1.1
Chlorine Free mg/L	8/5/2015						0.34	
Chlorine Free mg/L	8/6/2015		0.7	0.75		0.8		
Chlorine Free mg/L	8/7/2015		0.74					
Chlorine Free mg/L	8/11/2015	0.73		0.74		0.75		
Chlorine Free mg/L	8/12/2015		1.1				0.29	
Chlorine Free mg/L	8/13/2015				0.69			0.83
Chlorine Free mg/L	8/17/2015	0.37				0.55		
Chlorine Free mg/L	8/18/2015				0.5			0.89
Chlorine Free mg/L	8/19/2015		0.75	0.81			0.42	
Chlorine Free mg/L	8/20/2015		0.65					
Chlorine Free mg/L	8/21/2015		0.65					0.9
Chlorine Free mg/L	8/24/2015	0.65				0.71		

		Point Roberts Main	Langley Main	37th Ave at Manitoba	Bose Rd & 126th Main	Ferry & Dyke Main	Maple Ridge Chamber Main	Seymour at Grandview Main
Analysis	Sampled Date	GV-029	GV-034	GV-050	GV-054	GV-066	GV-098	GV-128
Chlorine Free mg/L	8/26/2015		0.85	0.77	0.9		0.54	1
Chlorine Free mg/L	8/27/2015						0.51	
Chlorine Free mg/L	8/28/2015	0.61				0.81	0.45	
Chlorine Free mg/L	8/31/2015	0.51				0.73	0.39	
Chlorine Free mg/L	9/1/2015		0.84		0.52			0.65
Chlorine Free mg/L	9/2/2015			0.7			0.33	
Chlorine Free mg/L	9/4/2015		0.75					0.7
Chlorine Free mg/L	9/9/2015		0.8					
Chlorine Free mg/L	9/10/2015	0.54		0.61		0.73		
Chlorine Free mg/L	9/11/2015				0.57		0.16	0.88
Chlorine Free mg/L	9/14/2015		1.1					
Chlorine Free mg/L	9/15/2015	0.62		0.53	0.55	0.46		0.98
Chlorine Free mg/L	9/16/2015			0.69			0.39	
Chlorine Free mg/L	9/17/2015	0.62				0.59		
Chlorine Free mg/L	9/18/2015		0.85	0.58				
Chlorine Free mg/L	9/22/2015				0.43			1.1
Chlorine Free mg/L	9/23/2015		1	0.53			0.42	
Chlorine Free mg/L	9/24/2015	0.49				0.6		
Chlorine Free mg/L	9/28/2015				0.42			1
Chlorine Free mg/L	9/29/2015	0.55				0.55		
Chlorine Free mg/L	9/30/2015			0.62			0.33	
Chlorine Free mg/L	10/1/2015		0.72					
Chlorine Free mg/L	10/2/2015			0.65				0.85
Chlorine Free mg/L	10/5/2015			0.62				
Chlorine Free mg/L	10/6/2015	0.48				0.81		
Chlorine Free mg/L	10/7/2015						0.47	
Chlorine Free mg/L	10/8/2015		0.95		0.68			1

		Point Roberts Main	Langley Main	37th Ave at Manitoba	Bose Rd & 126th Main	Ferry & Dyke Main	Maple Ridge Chamber Main	Seymour at Grandview Main
Analysis	Sampled Date	GV-029	GV-034	GV-050	GV-054	GV-066	GV-098	GV-128
Chlorine Free mg/L	10/9/2015		0.7					0.8
Chlorine Free mg/L	10/13/2015			0.68				
Chlorine Free mg/L	10/14/2015		0.88					
Chlorine Free mg/L	10/15/2015	0.43			0.55	0.7		0.82
Chlorine Free mg/L	10/16/2015						0.38	
Chlorine Free mg/L	10/19/2015	0.53				0.47		
Chlorine Free mg/L	10/21/2015	0.4		0.7		0.74	0.43	
Chlorine Free mg/L	10/22/2015				0.42			0.78
Chlorine Free mg/L	10/23/2015	0.5	0.75			0.56		
Chlorine Free mg/L	10/26/2015	0.39				0.55		
Chlorine Free mg/L	10/27/2015			0.61	0.37			0.43
Chlorine Free mg/L	10/28/2015	0.54	0.71			0.72	0.32	
Chlorine Free mg/L	11/2/2015			0.37	0.47			1.2
Chlorine Free mg/L	11/3/2015	0.42				0.67		
Chlorine Free mg/L	11/4/2015		0.44	0.68			0.24	
Chlorine Free mg/L	11/5/2015			0.65	0.47			0.6
Chlorine Free mg/L	11/6/2015		0.67					0.76
Chlorine Free mg/L	11/9/2015	0.19				0.7		
Chlorine Free mg/L	11/12/2015		0.82	0.44	0.5		0.37	0.75
Chlorine Free mg/L	11/13/2015	0.47				0.49		
Chlorine Free mg/L	11/17/2015	0.42	0.99		0.43	0.53		0.82
Chlorine Free mg/L	11/18/2015			0.69			0.29	
Chlorine Free mg/L	11/19/2015		1.1		0.65			0.52
Chlorine Free mg/L	11/20/2015	0.24				0.85	0.46	
Chlorine Free mg/L	11/23/2015	0.36			0.43	0.7		1.3
Chlorine Free mg/L	11/24/2015		0.78					
Chlorine Free mg/L	11/25/2015			0.52			0.42	
Chlorine Free mg/L	11/26/2015	0.57			0.6	0.57		1.1
Chlorine Free mg/L	11/30/2015					0.57		0.75

		Point Roberts Main	Langley Main	37th Ave at Manitoba	Bose Rd & 126th Main	Ferry & Dyke Main	Maple Ridge Chamber Main	Seymour at Grandview Main
Analysis	Sampled Date	GV-029	GV-034	GV-050	GV-054	GV-066	GV-098	GV-128
Chlorine Free mg/L	12/1/2015		0.73					
Chlorine Free mg/L	12/2/2015			0.64	0.57		0.54	0.53
Chlorine Free mg/L	12/3/2015	0.51	0.69			0.69		0.73
Chlorine Free mg/L	12/4/2015			0.32				
Chlorine Free mg/L	12/7/2015			0.61			0.37	
Chlorine Free mg/L	12/9/2015		0.74				0.2	
Chlorine Free mg/L	12/10/2015	0.7				0.77		
Chlorine Free mg/L	12/15/2015	0.6				0.58		
Chlorine Free mg/L	12/16/2015		0.83	0.61			0.55	
Chlorine Free mg/L	12/17/2015				0.46			0.91
Chlorine Free mg/L	12/18/2015			0.83	0.61			1.2
Chlorine Free mg/L	12/22/2015	0.69			0.35	0.74		0.68
Chlorine Free mg/L	12/23/2015		0.68				0.42	
Chlorine Free mg/L	12/26/2015			0.55				
Chlorine Free mg/L	12/29/2015	0.74			0.65	0.83		0.86
Chlorine Free mg/L	12/30/2015				0.55			0.85
Chlorine Free mg/L	12/31/2015		1.1				0.4	
Chlorodibromomethane ppb	2/16/2015	<1			<1	<1		<1
Chlorodibromomethane ppb	2/17/2015		<1					
Chlorodibromomethane ppb	2/18/2015			<1			<1	
Chlorodibromomethane ppb	5/20/2015	<1	<1			<1		
Chlorodibromomethane ppb	5/21/2015			<1			<1	
Chlorodibromomethane ppb	5/22/2015				<1			<1
Chlorodibromomethane ppb	8/17/2015	<1				<1		
Chlorodibromomethane ppb	8/18/2015				<1			<1
Chlorodibromomethane ppb	8/19/2015			<1			<1	
Chlorodibromomethane ppb	8/20/2015		<1					
Chlorodibromomethane ppb	11/23/2015	<1			<1			
Chlorodibromomethane ppb	11/24/2015		<1					

		Point Roberts Main	Langley Main	37th Ave at Manitoba	Bose Rd & 126th Main	Ferry & Dyke Main	Maple Ridge Chamber Main	Seymour at Grandview Main
Analysis	Sampled Date	GV-029	GV-034	GV-050	GV-054	GV-066	GV-098	GV-128
Chlorodibromomethane ppb	11/25/2015			<1			<1	
Chlorodibromomethane ppb	11/26/2015					<1		<1
Chloroform ppb	2/16/2015	24			27	23		33
Chloroform ppb	2/17/2015		27					
Chloroform ppb	2/18/2015			20			41	
Chloroform ppb	5/20/2015	50	44			24		
Chloroform ppb	5/21/2015			29			30	
Chloroform ppb	5/22/2015				37			42
Chloroform ppb	8/17/2015	34				28		
Chloroform ppb	8/18/2015				24			34
Chloroform ppb	8/19/2015			31			36	
Chloroform ppb	8/20/2015		37					
Chloroform ppb	11/23/2015	32			20			
Chloroform ppb	11/24/2015		43					
Chloroform ppb	11/25/2015			20			40	
Chloroform ppb	11/26/2015					24		24
Dibromoacetic Acid ppb	2/16/2015	<0.5			<0.5	<0.5		<0.5
Dibromoacetic Acid ppb	2/17/2015		<0.5					
Dibromoacetic Acid ppb	2/18/2015			<0.5			<0.5	
Dibromoacetic Acid ppb	5/20/2015	<0.5	<0.5			<0.5		
Dibromoacetic Acid ppb	5/21/2015			<0.5			<0.5	
Dibromoacetic Acid ppb	5/22/2015				<0.5			<0.5
Dibromoacetic Acid ppb	8/17/2015	<0.5				<0.5		
Dibromoacetic Acid ppb	8/18/2015				<0.5			<0.5
Dibromoacetic Acid ppb	8/19/2015			<0.5			<0.5	
Dibromoacetic Acid ppb	8/20/2015		<0.5					
Dibromoacetic Acid ppb	11/23/2015	<0.5			<0.5			
Dibromoacetic Acid ppb	11/24/2015		<0.5					
Dibromoacetic Acid ppb	11/25/2015			<0.5			<0.5	

		Point Roberts Main	Langley Main	37th Ave at Manitoba	Bose Rd & 126th Main	Ferry & Dyke Main	Maple Ridge Chamber Main	Seymour at Grandview Main
Analysis	Sampled Date	GV-029	GV-034	GV-050	GV-054	GV-066	GV-098	GV-128
Dibromoacetic Acid ppb	11/26/2015					<0.5		<0.5
Dichloroacetic Acid ppb	2/16/2015	11			<1	11		15
Dichloroacetic Acid ppb	2/17/2015		17					
Dichloroacetic Acid ppb	2/18/2015			8			11	
Dichloroacetic Acid ppb	5/20/2015	25	22			9		
Dichloroacetic Acid ppb	5/21/2015			14			25	
Dichloroacetic Acid ppb	5/22/2015				20			19
Dichloroacetic Acid ppb	8/17/2015	27				11		
Dichloroacetic Acid ppb	8/18/2015				16			22
Dichloroacetic Acid ppb	8/19/2015			22			18	
Dichloroacetic Acid ppb	8/20/2015		26					
Dichloroacetic Acid ppb	11/23/2015	18			9			
Dichloroacetic Acid ppb	11/24/2015		30					
Dichloroacetic Acid ppb	11/25/2015			10			23	
Dichloroacetic Acid ppb	11/26/2015					10		9
HAA - Total Haloacetic Acid ppb	2/16/2015	31.4			12.8	28.3		45
HAA - Total Haloacetic Acid ppb	2/17/2015		49.7					
HAA - Total Haloacetic Acid ppb	2/18/2015			21.4			33.2	
HAA - Total Haloacetic Acid ppb	5/20/2015	72.6	59.5			23.9		
HAA - Total Haloacetic Acid ppb	5/21/2015			35.5			73.7	
HAA - Total Haloacetic Acid ppb	5/22/2015				51.2			51.3
HAA - Total Haloacetic Acid ppb	8/17/2015	76.1				27.8		
HAA - Total Haloacetic Acid ppb	8/18/2015				44.4			61.7
HAA - Total Haloacetic Acid ppb	8/19/2015			56.5			62.7	
HAA - Total Haloacetic Acid ppb	8/20/2015		71.4					
HAA - Total Haloacetic Acid ppb	11/23/2015	50.3			21.7			
HAA - Total Haloacetic Acid ppb	11/24/2015		80.4					
HAA - Total Haloacetic Acid ppb	11/25/2015			25.7			74.3	
HAA - Total Haloacetic Acid ppb	11/26/2015					28.5		27.7

		Point Roberts Main	Langley Main	37th Ave at Manitoba	Bose Rd & 126th Main	Ferry & Dyke Main	Maple Ridge Chamber Main	Seymour at Grandview Main
Analysis	Sampled Date	GV-029	GV-034	GV-050	GV-054	GV-066	GV-098	GV-128
Monobromoacetic Acid ppb	2/16/2015	<1			<1	<1		<1
Monobromoacetic Acid ppb	2/17/2015		<1					
Monobromoacetic Acid ppb	2/18/2015			<1			<1	
Monobromoacetic Acid ppb	5/20/2015	<1	<1			<1		
Monobromoacetic Acid ppb	5/21/2015			<1			<1	
Monobromoacetic Acid ppb	5/22/2015				<1			<1
Monobromoacetic Acid ppb	8/17/2015	<1				<1		
Monobromoacetic Acid ppb	8/18/2015				<1			<1
Monobromoacetic Acid ppb	8/19/2015			<1			<1	
Monobromoacetic Acid ppb	8/20/2015		<1					
Monobromoacetic Acid ppb	11/23/2015	<1			<1			
Monobromoacetic Acid ppb	11/24/2015		<1					
Monobromoacetic Acid ppb	11/25/2015			<1			<1	
Monobromoacetic Acid ppb	11/26/2015					<1		<1
Monochloroacetic Acid ppb	2/16/2015	6			12	5		11
Monochloroacetic Acid ppb	2/17/2015		12					
Monochloroacetic Acid ppb	2/18/2015			4			4	
Monochloroacetic Acid ppb	5/20/2015	8	9			4		
Monochloroacetic Acid ppb	5/21/2015			6			9	
Monochloroacetic Acid ppb	5/22/2015				7			7
Monochloroacetic Acid ppb	8/17/2015	12				6		
Monochloroacetic Acid ppb	8/18/2015				15			12
Monochloroacetic Acid ppb	8/19/2015			13			11	
Monochloroacetic Acid ppb	8/20/2015		14					
Monochloroacetic Acid ppb	11/23/2015	10			3			
Monochloroacetic Acid ppb	11/24/2015		12					
Monochloroacetic Acid ppb	11/25/2015			7			12	
Monochloroacetic Acid ppb	11/26/2015					6		8
pH pH units	2/16/2015	7			7.1	7.1		7.2

		Point Roberts Main	Langley Main	37th Ave at Manitoba	Bose Rd & 126th Main	Ferry & Dyke Main	Maple Ridge Chamber Main	Seymour at Grandview Main
Analysis	Sampled Date	GV-029	GV-034	GV-050	GV-054	GV-066	GV-098	GV-128
pH pH units	2/17/2015		7.1					
pH pH units	2/18/2015			7			7.2	
pH pH units	5/20/2015	7.2	7			7.2		
pH pH units	5/21/2015			7.2			7.2	
pH pH units	5/22/2015				7.2			7.2
pH pH units	8/17/2015	7.2				7.4		
pH pH units	8/18/2015				7.2			7.2
pH pH units	8/19/2015			7.3			7.1	
pH pH units	8/20/2015		7.1					
pH pH units	11/23/2015	7.1			7.1			
pH pH units	11/24/2015		7.1					
pH pH units	11/25/2015			7.1			7.1	
pH pH units	11/26/2015					7		7.1
Sodium Total µg/L	2/16/2015	1480			4570	1490		6250
Sodium Total µg/L	2/17/2015		6340					
Sodium Total µg/L	2/18/2015			1350			6190	
Sodium Total µg/L	5/20/2015	5040	5750			1920		
Sodium Total µg/L	5/21/2015			3730			6120	
Sodium Total µg/L	5/22/2015				5550			6130
Sodium Total µg/L	8/17/2015	5160				2380		
Sodium Total µg/L	8/18/2015				5470			6190
Sodium Total µg/L	8/19/2015			1910			5580	
Sodium Total µg/L	8/20/2015		5770					
Sodium Total µg/L	11/23/2015	3030			1600			
Sodium Total µg/L	11/24/2015		6490					
Sodium Total µg/L	11/25/2015			1520			6250	
Sodium Total µg/L	11/26/2015					1700		2300
Temperature °C	1/5/2015							7.1
Temperature °C	11/2/2015			12	12			12

		Point Roberts Main	Langley Main	37th Ave at Manitoba	Bose Rd & 126th Main	Ferry & Dyke Main	Maple Ridge Chamber Main	Seymour at Grandview Main
Analysis	Sampled Date	GV-029	GV-034	GV-050	GV-054	GV-066	GV-098	GV-128
Temperature °C	11/3/2015	13				12		
Temperature °C	11/4/2015		12	11			LA	
Temperature °C	11/5/2015			13	12			12
Temperature °C	11/6/2015		13					12
Temperature °C	11/9/2015	13				11		
Temperature °C	11/12/2015		10	9.7	11		13	11
Temperature °C	11/13/2015	12				12		
Temperature °C	11/17/2015	14	11		11	11		10
Temperature °C	11/18/2015			9			10	
Temperature °C	11/19/2015		10		10			11
Temperature °C	11/20/2015	12				8.3	11	
Temperature °C	11/23/2015	13			7.9	9.3		8.5
Temperature °C	11/24/2015		9.2					
Temperature °C	11/25/2015			7.8			10	
Temperature °C	11/26/2015	11			8.2	7		8.7
Temperature °C	11/30/2015					7.7		8.1
Temperature °C	12/1/2015		8.2					
Temperature °C	12/2/2015			6.9	7.4		9.9	8.6
Temperature °C	12/3/2015	9	10			7.3		9.1
Temperature °C	12/4/2015			8.1				
Temperature °C	12/7/2015			8.2			10	
Temperature °C	12/9/2015		8.3				10	
Temperature °C	12/10/2015	9.7				6.7		
Temperature °C	12/15/2015	9.5				7.3		
Temperature °C	12/16/2015		7.8	8.2			7.6	
Temperature °C	12/17/2015				6.7			7.1
Temperature °C	12/18/2015			6.8	6.7			7.1

		Point Roberts Main	Langley Main	37th Ave at Manitoba	Bose Rd & 126th Main	Ferry & Dyke Main	Maple Ridge Chamber Main	Seymour at Grandview Main
Analysis	Sampled Date	GV-029	GV-034	GV-050	GV-054	GV-066	GV-098	GV-128
Temperature °C	12/22/2015	9.1			7.3	7.7		7.6
Temperature °C	12/23/2015		7.7				8.8	
Temperature °C	12/26/2015			7.2				
Temperature °C	12/29/2015	8.4			6.9	6.5		7.1
Temperature °C	12/30/2015				5.5			6.5
Temperature °C	12/31/2015		6.2				6.5	
THM-Total Trihalomethanes ppb	2/16/2015	24			27.8	23.1		34
THM-Total Trihalomethanes ppb	2/17/2015		27.9					
THM-Total Trihalomethanes ppb	2/18/2015			20.3			42	
THM-Total Trihalomethanes ppb	5/20/2015	50.8	44.7			24.7		
THM-Total Trihalomethanes ppb	5/21/2015			29			30.8	
THM-Total Trihalomethanes ppb	5/22/2015				37.2			42.6
THM-Total Trihalomethanes ppb	8/17/2015	35.9				29.4		
THM-Total Trihalomethanes ppb	8/18/2015				25			34.7
THM-Total Trihalomethanes ppb	8/19/2015			32.3			36.9	
THM-Total Trihalomethanes ppb	8/20/2015		38.3					
THM-Total Trihalomethanes ppb	11/23/2015	33.5			21.3			
THM-Total Trihalomethanes ppb	11/24/2015		44.6					
THM-Total Trihalomethanes ppb	11/25/2015			21.5			42.4	
THM-Total Trihalomethanes ppb	11/26/2015					25.2		25.2
Trichloroacetic Acid ppb	2/16/2015	13.6			<0.5	10.9		19.5
Trichloroacetic Acid ppb	2/17/2015		21.1					
Trichloroacetic Acid ppb	2/18/2015			8.5			16.4	
Trichloroacetic Acid ppb	5/20/2015	39.3	28.9			10.1		
Trichloroacetic Acid ppb	5/21/2015			14.5			39.8	
Trichloroacetic Acid ppb	5/22/2015				23.9			25
Trichloroacetic Acid ppb	8/17/2015	36.6				10.1		
Trichloroacetic Acid ppb	8/18/2015				13.2			27
Trichloroacetic Acid ppb	8/19/2015			21.5			33.4	

		Point Roberts Main	Langley Main	37th Ave at Manitoba	Bose Rd & 126th Main	Ferry & Dyke Main	Maple Ridge Chamber Main	Seymour at Grandview Main
Analysis	Sampled Date	GV-029	GV-034	GV-050	GV-054	GV-066	GV-098	GV-128
Trichloroacetic Acid ppb	8/20/2015		30.5					
Trichloroacetic Acid ppb	11/23/2015	21.6			7.7			
Trichloroacetic Acid ppb	11/24/2015		37.8					
Trichloroacetic Acid ppb	11/25/2015			7.5			38	
Trichloroacetic Acid ppb	11/26/2015					10.8		9.7
Turbidity NTU	1/5/2015	0.23			5.9	0.13		0.59
Turbidity NTU	1/6/2015				0.6			
Turbidity NTU	1/7/2015	0.15	0.63	0.11		0.11	0.54	
Turbidity NTU	1/8/2015			0.12				
Turbidity NTU	1/9/2015	0.2				0.13	0.38	
Turbidity NTU	1/12/2015	0.14			0.2	0.13		0.49
Turbidity NTU	1/14/2015		0.36	0.14			0.4	
Turbidity NTU	1/15/2015	0.17				0.1		
Turbidity NTU	1/16/2015						0.35	
Turbidity NTU	1/19/2015				0.14			0.39
Turbidity NTU	1/21/2015		0.41	0.11			0.36	
Turbidity NTU	1/22/2015	0.18			0.17	0.08		0.37
Turbidity NTU	1/23/2015		0.33					
Turbidity NTU	1/26/2015				0.11			1.2
Turbidity NTU	1/27/2015		1.2					
Turbidity NTU	1/28/2015			0.16			0.95	
Turbidity NTU	1/29/2015	0.2				0.17		
Turbidity NTU	1/30/2015	0.28		0.11		0.17		0.69
Turbidity NTU	2/2/2015			0.11				
Turbidity NTU	2/4/2015		0.55		0.22			0.66
Turbidity NTU	2/5/2015	0.15				0.14	0.47	
Turbidity NTU	2/6/2015	0.14				0.12	0.53	
Turbidity NTU	2/10/2015	0.18				0.15		
Turbidity NTU	2/12/2015		0.51	0.13	0.18		0.72	0.5

		Point Roberts Main	Langley Main	37th Ave at Manitoba	Bose Rd & 126th Main	Ferry & Dyke Main	Maple Ridge Chamber Main	Seymour at Grandview Main
Analysis	Sampled Date	GV-029	GV-034	GV-050	GV-054	GV-066	GV-098	GV-128
Turbidity NTU	2/13/2015	0.42				0.11	0.64	
Turbidity NTU	2/16/2015	0.22			0.49	0.09		0.41
Turbidity NTU	2/17/2015		0.52					
Turbidity NTU	2/18/2015	0.16		0.09		0.1	0.43	
Turbidity NTU	2/19/2015		0.43	0.12				
Turbidity NTU	2/20/2015		0.45		0.11			0.44
Turbidity NTU	2/23/2015	0.19			0.16	0.1		0.41
Turbidity NTU	2/24/2015		0.42	0.15				
Turbidity NTU	2/25/2015	0.15				0.1	0.38	
Turbidity NTU	2/26/2015			0.21				
Turbidity NTU	2/27/2015	0.15	0.46			0.09		0.37
Turbidity NTU	3/2/2015	0.13		0.09		0.1		
Turbidity NTU	3/3/2015				0.42			0.43
Turbidity NTU	3/4/2015		0.42				0.38	
Turbidity NTU	3/5/2015		0.36			0.09		0.41
Turbidity NTU	3/6/2015			0.12	0.19			0.37
Turbidity NTU	3/9/2015	0.12				0.13		
Turbidity NTU	3/10/2015		0.4		0.17			0.4
Turbidity NTU	3/11/2015	0.27	0.4	0.12		0.1	0.41	0.36
Turbidity NTU	3/12/2015			0.09			0.36	
Turbidity NTU	3/13/2015	0.13		0.12	0.34	0.1		0.4
Turbidity NTU	3/17/2015	0.15				0.15		
Turbidity NTU	3/18/2015		0.52	0.11	0.44			0.59
Turbidity NTU	3/19/2015		0.58					
Turbidity NTU	3/24/2015			0.12				
Turbidity NTU	3/25/2015	0.1	0.75			0.09		

		Point Roberts Main	Langley Main	37th Ave at Manitoba	Bose Rd & 126th Main	Ferry & Dyke Main	Maple Ridge Chamber Main	Seymour at Grandview Main
Analysis	Sampled Date	GV-029	GV-034	GV-050	GV-054	GV-066	GV-098	GV-128
Turbidity NTU	3/17/2015	0.15				0.15		
Turbidity NTU	3/18/2015		0.52	0.11	0.44			0.59
Turbidity NTU	3/19/2015		0.58					
Turbidity NTU	3/24/2015			0.12				
Turbidity NTU	3/25/2015	0.1	0.75			0.09		
Turbidity NTU	3/26/2015			0.2	0.46			0.48
Turbidity NTU	3/27/2015		0.68					0.59
Turbidity NTU	3/31/2015		0.57					
Turbidity NTU	4/1/2015		0.43	0.12	0.56		0.46	0.44
Turbidity NTU	4/2/2015	0.11				0.11		
Turbidity NTU	4/7/2015	0.13		0.14		0.11		
Turbidity NTU	4/9/2015		0.43		0.77		0.34	0.45
Turbidity NTU	4/10/2015	0.16	0.41			0.14	0.43	
Turbidity NTU	4/13/2015	0.19	0.32		0.25	0.16		0.33
Turbidity NTU	4/15/2015		0.34	0.16				
Turbidity NTU	4/16/2015	0.2				0.26	0.67	
Turbidity NTU	4/17/2015		0.33	0.17	0.42		0.3	0.48
Turbidity NTU	4/20/2015	0.2				0.15		
Turbidity NTU	4/22/2015			0.16				
Turbidity NTU	4/23/2015		0.45				0.62	
Turbidity NTU	4/24/2015				0.23			0.37
Turbidity NTU	4/28/2015	0.18	0.38			0.25		
Turbidity NTU	4/29/2015			0.12	0.25			0.35
Turbidity NTU	4/30/2015						0.34	
Turbidity NTU	5/1/2015	0.12		0.16	0.23	0.14		0.33
Turbidity NTU	5/4/2015	0.12		0.13		0.11		
Turbidity NTU	5/5/2015				0.24			0.42
Turbidity NTU	5/6/2015		7.5					
Turbidity NTU	5/7/2015	0.13	0.37	0.15		0.19	0.33	

		Point Roberts Main	Langley Main	37th Ave at Manitoba	Bose Rd & 126th Main	Ferry & Dyke Main	Maple Ridge Chamber Main	Seymour at Grandview Main
Analysis	Sampled Date	GV-029	GV-034	GV-050	GV-054	GV-066	GV-098	GV-128
Turbidity NTU	5/8/2015			0.11				
Turbidity NTU	5/11/2015	0.24				0.18		
Turbidity NTU	5/12/2015		0.43					
Turbidity NTU	5/13/2015	0.14		0.13		0.09	0.47	
Turbidity NTU	5/14/2015				0.18		0.42	0.24
Turbidity NTU	5/15/2015	0.16	0.55	0.09		0.13	0.36	
Turbidity NTU	5/20/2015	0.37	0.44			0.1		
Turbidity NTU	5/21/2015			0.23			0.66	
Turbidity NTU	5/22/2015		0.49		0.41	0.11	0.72	0.35
Turbidity NTU	5/25/2015	0.28				0.14		
Turbidity NTU	5/26/2015			0.17				
Turbidity NTU	5/27/2015	0.22	0.28		0.39	0.13	0.35	0.34
Turbidity NTU	5/28/2015	0.18		0.16	0.3	0.14		0.32
Turbidity NTU	5/29/2015		0.39					0.34
Turbidity NTU	6/1/2015	0.23			0.28	0.24		0.3
Turbidity NTU	6/3/2015		0.41	0.15				
Turbidity NTU	6/4/2015	0.19		0.27		0.14	0.3	
Turbidity NTU	6/5/2015	0.22	0.41			0.13	0.5	
Turbidity NTU	6/8/2015	0.26		0.33		0.25		
Turbidity NTU	6/9/2015		0.42					
Turbidity NTU	6/10/2015			0.19	0.22	0.32	0.38	0.47
Turbidity NTU	6/11/2015			0.23				
Turbidity NTU	6/12/2015		0.3	0.26				0.29
Turbidity NTU	6/15/2015	0.37			0.23	0.18		0.26
Turbidity NTU	6/17/2015	0.46	0.45	0.21		0.25	0.3	
Turbidity NTU	6/18/2015			0.26				
Turbidity NTU	6/19/2015		0.28					0.4
Turbidity NTU	6/22/2015	0.29				0.31		
Turbidity NTU	6/23/2015				0.32			0.32

		Point Roberts Main	Langley Main	37th Ave at Manitoba	Bose Rd & 126th Main	Ferry & Dyke Main	Maple Ridge Chamber Main	Seymour at Grandview Main
Analysis	Sampled Date	GV-029	GV-034	GV-050	GV-054	GV-066	GV-098	GV-128
Turbidity NTU	6/24/2015	0.28	0.28	0.18		0.22	0.32	
Turbidity NTU	6/26/2015		0.28	0.23	0.21		0.3	0.21
Turbidity NTU	6/29/2015	0.13			0.21	0.18		0.22
Turbidity NTU	6/30/2015			0.24				
Turbidity NTU	7/2/2015	0.43	0.26			0.23	0.29	
Turbidity NTU	7/3/2015		0.25	0.17				
Turbidity NTU	7/6/2015		0.33					
Turbidity NTU	7/7/2015						0.24	
Turbidity NTU	7/8/2015			0.15				
Turbidity NTU	7/9/2015	0.19			0.28	0.28		0.28
Turbidity NTU	7/10/2015		0.25				0.25	
Turbidity NTU	7/11/2015						0.25	
Turbidity NTU	7/12/2015						0.23	
Turbidity NTU	7/13/2015				0.29			0.48
Turbidity NTU	7/15/2015			0.2			0.26	
Turbidity NTU	7/16/2015	0.15	0.37			0.22		
Turbidity NTU	7/17/2015		0.31	0.14		0.13		
Turbidity NTU	7/21/2015		0.33					
Turbidity NTU	7/22/2015	0.17				0.15	0.38	
Turbidity NTU	7/23/2015			0.18				
Turbidity NTU	7/24/2015				0.29			0.26
Turbidity NTU	7/27/2015				0.28			0.34
Turbidity NTU	7/28/2015			0.23				
Turbidity NTU	7/29/2015		0.32				0.29	
Turbidity NTU	7/30/2015	0.27		0.24		0.18		
Turbidity NTU	7/31/2015			0.34	0.3			0.51

		Point Roberts Main	Langley Main	37th Ave at Manitoba	Bose Rd & 126th Main	Ferry & Dyke Main	Maple Ridge Chamber Main	Seymour at Grandview Main
Analysis	Sampled Date	GV-029	GV-034	GV-050	GV-054	GV-066	GV-098	GV-128
Turbidity NTU	8/4/2015				0.3			0.42
Turbidity NTU	8/5/2015						0.27	
Turbidity NTU	8/6/2015		0.33	0.3		0.28		
Turbidity NTU	8/7/2015		0.29					
Turbidity NTU	8/11/2015	0.29		0.23		0.23		
Turbidity NTU	8/12/2015		0.34				0.26	
Turbidity NTU	8/13/2015				0.38			0.27
Turbidity NTU	8/17/2015	0.25				0.19		
Turbidity NTU	8/18/2015				0.23			0.27
Turbidity NTU	8/19/2015		0.33	0.5			0.29	
Turbidity NTU	8/20/2015		0.28					
Turbidity NTU	8/21/2015		0.27					0.3
Turbidity NTU	8/24/2015	0.36				0.24		
Turbidity NTU	8/26/2015		0.43	0.54	0.3		0.43	0.35
Turbidity NTU	8/27/2015						0.34	
Turbidity NTU	8/28/2015	0.18				0.24	0.3	
Turbidity NTU	8/31/2015	0.24				0.31	0.32	
Turbidity NTU	9/1/2015		0.84		0.61			0.37
Turbidity NTU	9/2/2015			0.14			0.83	
Turbidity NTU	9/4/2015		1					0.62
Turbidity NTU	9/9/2015		1.1					
Turbidity NTU	9/10/2015	0.15		0.26		0.16		
Turbidity NTU	9/11/2015				0.18		0.72	0.33
Turbidity NTU	9/14/2015		0.69					
Turbidity NTU	9/15/2015	0.09		0.21	0.12	0.13		0.47
Turbidity NTU	9/16/2015			0.1			0.56	
Turbidity NTU	9/17/2015	0.15				0.14		
Turbidity NTU	9/18/2015		0.8	0.1				
Turbidity NTU	9/22/2015				0.24			0.5

		Point Roberts Main	Langley Main	37th Ave at Manitoba	Bose Rd & 126th Main	Ferry & Dyke Main	Maple Ridge Chamber Main	Seymour at Grandview Main
Analysis	Sampled Date	GV-029	GV-034	GV-050	GV-054	GV-066	GV-098	GV-128
Turbidity NTU	9/23/2015		0.61	0.11			0.5	
Turbidity NTU	9/24/2015	0.11				0.13		
Turbidity NTU	9/28/2015				0.14			0.47
Turbidity NTU	9/29/2015	0.16				0.18		
Turbidity NTU	9/30/2015			0.14			0.4	
Turbidity NTU	10/1/2015		0.45					
Turbidity NTU	10/2/2015			0.12				0.39
Turbidity NTU	10/5/2015			0.28				
Turbidity NTU	10/6/2015	0.23				0.17		
Turbidity NTU	10/7/2015						0.41	
Turbidity NTU	10/8/2015		0.42		0.49			0.37
Turbidity NTU	10/9/2015		0.38					0.38
Turbidity NTU	10/13/2015			0.15				
Turbidity NTU	10/14/2015		0.34					
Turbidity NTU	10/15/2015	0.18			0.3	0.12		0.36
Turbidity NTU	10/16/2015						0.36	
Turbidity NTU	10/19/2015	0.12				0.12		
Turbidity NTU	10/21/2015	0.16		0.2		0.13	0.4	
Turbidity NTU	10/22/2015				0.43			0.46
Turbidity NTU	10/23/2015	0.13	0.42			0.16		
Turbidity NTU	10/26/2015	0.14				0.1		
Turbidity NTU	10/27/2015			0.28	0.27			0.28
Turbidity NTU	10/28/2015	0.12	0.32			0.15	0.33	
Turbidity NTU	11/2/2015			0.34	0.35			0.55
Turbidity NTU	11/3/2015	0.15				0.16		
Turbidity NTU	11/4/2015		0.39	0.15			0.43	
Turbidity NTU	11/5/2015			0.22	0.16			0.38
Turbidity NTU	11/6/2015		0.42					0.34
Turbidity NTU	11/9/2015	0.29				0.19		

		Point Roberts Main	Langley Main	37th Ave at Manitoba	Bose Rd & 126th Main	Ferry & Dyke Main	Maple Ridge Chamber Main	Seymour at Grandview Main
Analysis	Sampled Date	GV-029	GV-034	GV-050	GV-054	GV-066	GV-098	GV-128
Turbidity NTU	11/12/2015		0.48	0.16	0.13		0.73	0.47
Turbidity NTU	11/13/2015	0.14				0.16		
Turbidity NTU	11/17/2015	0.09	0.86		0.18	0.1		0.57
Turbidity NTU	11/18/2015			0.12			0.56	
Turbidity NTU	11/19/2015		0.6		0.21			0.27
Turbidity NTU	11/20/2015	0.13				0.16	0.49	
Turbidity NTU	11/23/2015	0.24			4.7	0.13		0.48
Turbidity NTU	11/24/2015		0.62					
Turbidity NTU	11/25/2015			0.18			0.61	
Turbidity NTU	11/26/2015	0.13			0.16	0.1		0.21
Turbidity NTU	11/30/2015					0.09		0.43
Turbidity NTU	12/1/2015		0.47					
Turbidity NTU	12/2/2015			0.15	0.12		0.43	0.42
Turbidity NTU	12/3/2015	0.12	0.48			0.1		0.37
Turbidity NTU	12/4/2015			0.24				
Turbidity NTU	12/7/2015			0.09			0.48	
Turbidity NTU	12/9/2015		0.64				0.65	
Turbidity NTU	12/10/2015	0.16				0.12		
Turbidity NTU	12/15/2015	0.17				0.15		
Turbidity NTU	12/16/2015		0.56	0.12			0.66	
Turbidity NTU	12/17/2015				0.17			0.18
Turbidity NTU	12/18/2015			0.15	0.2			0.12
Turbidity NTU	12/22/2015	0.2			4.7	0.08		0.42
Turbidity NTU	12/23/2015		0.44				0.45	
Turbidity NTU	12/26/2015			0.15				
Turbidity NTU	12/29/2015	0.13			0.12	0.09		0.41
Turbidity NTU	12/30/2015				0.1			0.32
Turbidity NTU	12/31/2015		0.45				0.37	