

**Subject: FW: Hoskins Road Watermain**

**Date:** Tue, 16 Apr 2002 16:52:19 -0700

**From:** Ernie Crist <CristE@dnv.org>

**To:** "FONVCA (E-mail)" <fonvca@fonvca.org>

Hello:

This too you might find interesting.

Ernie

> -----Original Message-----

> *From:* Robert Huffman

> *Sent:* Tuesday, April 16, 2002 4:48 PM

> *To:* Mayor and Council - DNV

> *Cc:* Richard Zerr

> *Subject:* Hoskins Road Watermain

>

> *Councillor Crist: In answer to your questions from earlier today:*

>

> *All sections of watermain on Hoskins from Arborlynn to Westover are  
> asbestos-cement pipe, with installation dates ranging from 1960 to 1976.*

> *The section of main in question at 2422 Hoskins was installed in 1962.*

> *The District has 365 km of watermains.*

>

>

>

> *Councillor Mackay-Dunn: You asked about the issues raised during public  
> input last night regarding other recent watermain problems in the area.*

>

> *There have not been any watermain breaks on Hoskins in the past 4 years.*

> *There was a break on a different section at Ross Road in March 1998 and*

> *another break on a different section north of Ross Road in September 1997.*

>

>

> *The residents may have been referring to water service leaks (leaks or  
> breaks in the 3/4" copper water service pipe connecting the house to the  
> watermain). We had quite a bad one on October 8, 2001 at 2776 Hoskins,  
> where the copper pipe had completely broken. There was another one near  
> the Cooper's home at 2454 Hoskins on April 5, 2001, and also one at 3673  
> Hoskins on August 17, 2000. Water service leaks have no bearing on the  
> longevity of the watermain.*

>

> *In the surrounding area, there was a watermain break at 2315 Kilmarnock on  
> April 10, 2001.*

>

> *I hope this answers your questions.*

>

> *Yours truly,*

>

> *Bob Huffman,*

> *Manager, Utilities*

>

>



[Part 1.2](#)

**Type:** application/ms-tnef  
**Encoding:** base64